

CITY OF OZARK CONSTRUCTION SPECIFICATIONS FOR PUBLIC IMPROVEMENTS



2024 EDITION
CITY OF OZARK, MISSOURI

* Changes from the previous edition are noted in red.

TABLE OF CONTENTS

<u>Section</u>	<u>Description</u>	<u>No. of Pages</u>
01090	Definitions and Standards	5
01200	Project Meetings, Submittals and Certification	2
01300	Submittals	3
01530	Temporary Barriers and Controls	6
02200	Site Preparation and Earthwork	16
02222	Trenching and Backfilling for Utilities	10
02512	Asphalt Concrete Pavement	4
02525	Curbs, Gutters, Sidewalks, Driveway Approaches & Paved Drainage	8
02605	Manholes and Wet wells and Grease Interceptors	6
02610	Sanitary Sewer Pipe	4
02615	Pressure Pipe	5
02620	Pipe Installation and Testing	16
02640	Valves, Hydrants and Accessories	6
02675	Disinfection of Piping	4
02720	Storm Drainage System	6
02831	Chain-Link Fences and Gates	8
02930	Seeding and Sodding	8
03200	Concrete Reinforcement	4
03300	Concrete	23
11151	Submersible Wastewater Pumping Station	31
12000	Right-of-Way Technical Specifications	12

SECTION 01090 – DEFINITIONS AND STANDARDS

PART 1 - GENERAL

1.01 DEFINITIONS:

- A. Basic definitions of general terms used in these Construction Specifications for Public Improvements are covered in this Section.
1. Agreement: The agreement, written contract or otherwise, between Developer and Contractor covering the Work to be performed, including any Public Improvements. The City of Ozark shall not be a party to the Agreement between the Developer and the Contractor.
 2. City: The City of Ozark, Missouri. The governmental entity that will assume ownership of the completed Work from the Developer/Owner following the City's inspection of the completed Work and finding that the completed Work meets all of the requirements set forth by the City for the construction of public improvements within the City.
 3. City Public Works and Planning & Development Departments: The City departments representing the City during all phases of the Project. The Planning and Development Department shall be the designated contact between the Developer and the City. The Public Works Department will perform reviews of Developer submitted construction drawings, will conduct periodic and final inspections of the Public Improvements Work, and will issue notices of approval and acceptance, when appropriate, of the Public Improvements Work.
 4. Construction Easement: The land provided temporarily for use during the construction of the work.
 5. Construction Specifications. The official City's General Conditions and Technical Specifications used on public improvements within the City and such other areas outside the corporate boundaries that may contract with the City for the provision of services. This document contains data for public improvements from the beginning stage of a project through the actual construction and acceptance of the project
 6. Contractor: Any person, firm or corporation with whom the Developer/Owner enters into an Agreement to perform the Work for the Project, including any Public Improvements.
 7. Developer/Owner: The person, firm, or corporation owning the property being developed and owning the Public Improvements Work until the Work is completed, approved and accepted by the City. The person, firm, or corporation who will transfer ownership of the Public Improvements Work to the City upon completion of the Work and the approval and acceptance thereof by the City.
 8. Design Standards. The official City's design standards used for public improvements within the City and such other areas outside the corporate boundaries which may contract with the City for the provision of services. This document contains minimum design data for public improvements to be complied with in the design of public improvements.

SECTION 01090 – DEFINITIONS AND STANDARDS

9. Engineer: Engineer of Record, Developer's Engineering Consultant, Developer's Engineering Representative: The person, firm, or corporation, licensed to perform engineering services in the State of Missouri, whom the Developer/Owner employs to prepare drawings and specifications covering the Work, including any Public Improvements, and whom the Developer may designate as a representative to communicate with the City Planning & Development Department.
10. Harmful substances are contaminated soils and liquids containing micro-organisms that can cause infection and are toxic, such as paints, cleaners, blood and etc.
11. MoDNR: Missouri Department of Natural Resources.
12. MoDOT: Missouri Department of Transportation.
13. Or Equal: In order to establish a basis of quality for items of the work, certain processes, equipment, proprietary products or materials and their manufacturer may be mentioned by name. Such mention is not intended to exclude other processes, equipment, proprietary products or materials and their manufacturers, provided they are satisfactory proven by the Contractor, to be equal in quality and performance to the same specified prior to their inclusion in the work.
14. Owner, or Developer shall mean the individual, corporation, partnership, joint venture, association or other legal entities associated with the construction of an improvement under a permit granted by the City.
15. Permit Holder shall mean the individual or other legal entity who obtain the permit(s) required by city/building codes for the accomplishment of the Work.
16. Plans shall mean the official drawings, standard plans, profiles, and typical cross sections all as specified in the Special Provisions and supplemental drawings or reproduction thereof, approved and furnished by the City which show the location, character, dimensions and details of the work
17. Project: The total construction of which the Work to be provided under the Construction Specifications may be the whole, or part as indicated elsewhere in the Construction Specifications or on the City's approved construction drawings.
18. Right of Way Manager: The appropriate governmental entity responsible for the management and oversight of a public right of way affected by the proposed work. For the City roads, it is the Public Works Director or his designee. For County roads, it is the Christian County Road Department Administrator or his designee. For Ozark Special Road District Roads, it is the Ozark Special Road District Commission. For State roads, it is the Missouri Department of Transportation District 8, Engineer, or his designee.
19. Sediment Control Officer, (as designated in the Stormwater Pollution Prevention Plan), is the individual responsible for inspecting best management practices, (BMP's), and enforcing

SECTION 01090 – DEFINITIONS AND STANDARDS

the erosion control and stormwater portions of the Stormwater Pollution Prevention Plan, (SWPPP).

20. Standard Drawing Details. The official Standard Drawing Details used on public Improvements within the City and such other areas outside the corporate boundaries which may contract with the City for the provision of services. This document contains drawing details for public improvements to be followed and included in design drawings.
21. Work: The entire completed construction of the various separately identifiable parts thereof required to be furnished under the Construction Specifications and the City approved construction drawings. Work includes and is the result of performing or furnishing labor and furnishing and incorporating materials and equipment into the construction, and performing or furnishing services and furnishing documents, all as required by the Construction Specifications.

1.02 SPECIFICATION FORMAT AND CONTENT EXPLANATIONS:

- A. Specification Format: The Construction Specifications are organized into Divisions and Sections based on the Construction Specifications Institute's (CSI) 16 -Division format and Master format numbering system. Some portions may not fully comply and no particular significance will be attached to such compliance or noncompliance.
 1. Divisions and Sections: For convenience, a basic unit of Construction Specification Text is a "Section," each unit of which is numbered and named. These are recognized as the present industry consensus on uniform organization and sequencing of specifications. The Section title is not intended to limit meaning or content of Section, or to be fully descriptive of requirements specified therein, or to be an integral part of text.
 2. Section Numbering: Used for identification and to facilitate cross-references in Construction Specifications. Sections are placed in numeric sequence; however, numbering sequence is not complete, and listing of Sections in Table of Contents at beginning of Construction Specifications must be consulted to determine numbers and names of Specification Sections in these Construction Specifications.
 3. Page Numbering: Numbered independently for each Section. Section number is shown with page number at bottom of each page, to facilitate location of text.
 4. Parts: Each Section of Construction Specifications generally has been subdivided into three basic "parts" for uniformity and convenience (PART 1 - GENERAL, PART 2– PRODUCTS and PART 3 - EXECUTION). These "Parts" do not limit the meaning of text within. Some Sections may not contain all three "Parts" when not applicable, or may contain more than three "Parts" to add clarity to organization of Section.
 5. Underscoring of Titles: Used strictly to assist reader of Specification in scanning text for keywords in content. No emphasis on or relative importance is intended except where underscoring may be used in body of text to emphasize a duty, critical requirement, or similar situation.

SECTION 01090 – DEFINITIONS AND STANDARDS

B. Specification Content:

1. These Construction Specifications use certain conventions in the use of language and the intended meaning of certain terms, words, and phrases when used in particular situations or circumstances. These conventions are explained as follows:
 - a. Imperative and Streamlined Language: These Construction Specifications are written in imperative and abbreviated form. This imperative language of the technical Sections is directed at the Contractor, unless specifically noted otherwise. Incomplete sentences shall be completed by inserting “shall,” “the Contractor shall,” and “shall be,” and similar mandatory phrases by inference in the same manner as they are applied to notes on the drawings. The words “shall be” shall be supplied by inference where a colon (:) is used within sentences or phrases. Except as worded to the contrary, fulfill (perform) all indicated requirements whether stated imperatively or otherwise.
 - b. Specifying Methods: The techniques or methods of specifying requirements varies throughout the text, and may include “prescriptive,” “compliance with standards,” “performance,” “proprietary,” or a combination of these. The method used for specifying one unit of Work has no bearing on requirements for another unit of Work.
 - c. Abbreviations: Throughout the Construction Specifications are abbreviations implying words and meanings which shall be appropriately interpreted. Specific abbreviations have been established, principally for lengthy technical terminology. These are normally defined at first instance of use. Organizational and associated names and titles of general standards are also abbreviated.

1.03 STANDARDS AND ABBREVIATIONS:

- A. Applicability of Standards: Except where the Construction Specifications include more stringent requirements, applicable construction industry standards have the same force and effect as if bound or copied directly into the Construction Specifications. Such standards are made a part of the Construction Specifications by reference and are stated in each section.
 1. Referenced standards, referenced directly in Construction Specifications or by governing regulations, have precedence over non referenced standards which are recognized in industry for applicability to the Work.
 2. Where an applicable code or standard has been revised and reissued after the date of the Construction Specifications and before performance of Work affected, the revised or reissued code or standard shall apply.
 3. Where compliance with two or more standards is specified, and they establish different or conflicting requirements for minimum quantities or quality levels, the most stringent requirement will be enforced, unless the Construction Specifications indicate otherwise. Refer requirements that are different but apparently equal, and uncertainties as to which quality level is more stringent, to the City for a decision before proceeding.

SECTION 01090 – DEFINITIONS AND STANDARDS

4. In every instance the quantity or quality level shown or specified shall be the minimum to be provided or performed. The actual installation may comply exactly, within specified tolerances, with the minimum quantity or quality specified, or it may exceed that minimum within reasonable limits. In complying with these requirements, indicated numeric values are minimum or maximum values, as noted, or appropriate for the context of the requirements. Refer instances of uncertainty to the City for a decision before proceeding.
5. Each entity engaged in construction on the Project is required to be familiar with industry standards applicable to that entity's construction activity. Copies of applicable standards are not bound with the Construction Specifications. Where copies of standards are needed for performance of a required construction activity, the Contractor shall obtain copies directly from the publication source.

B. Abbreviations and Names: Trade association names and titles of general standards are frequently abbreviated. Where such acronyms or abbreviations are used in the Construction Specifications, they mean the recognized name of the trade association, standard generating organization, authority having jurisdiction, or other entity applicable to the context of the text provision.

PART 2 - PRODUCTS – Not applicable

PART 3 - EXECUTION – Not applicable.

END OF SECTION 01090

SECTION 01200 – PROJECT MEETINGS AND CERTIFICATION

PART 1 - GENERAL

1.01 SUMMARY: This Section includes the following requirements:

- A. Project Meetings:
 - 1. Preconstruction conference.
- B. Certification:
 - 1. Engineer's Final Certification of Completion.

1.02 PROJECT MEETINGS

- A. Preconstruction Conference:
 - 1. The Public Works Department will administer a meeting prior to commencement of any improvements to establish a working understanding between the parties as to their relationships during conduct of the Work. The developer/owner or his representative shall be responsible for contacting the Public Works Department to request the pre-construction conference. Public Works Department will schedule and notify the parties of the date and time of the pre-construction conference.
 - 2. Preconstruction conference shall be attended by:
 - a. Responsible Contractor and or superintendent/representative.
 - b. Representatives of principal Subcontractors and Suppliers.
 - c. Public Works Director or his representative and appropriate Public Works Staff.
 - d. Developer/Owner or his representative.
 - 3. Agenda:
 - a. Projected construction schedules.
 - b. Critical Work sequencing.
 - c. Project coordination.
 - d. Procedures and Processing of:
 - (1) Field decisions.
 - (2) Substitutions.

SECTION 01200 – PROJECT MEETINGS AND CERTIFICATION

(3) Submittals.

- e. Designated truck routes.
- f. Spoil/waste sites.
- g. Borrow pit sites.
- h. Procedures for testing.
- i. Procedures for maintaining record documents.
- j. All environmental and sediment control requirements.
- k. Other items as required.

4. Location of Meeting: Public Works Field Office.

B. Coordination meetings as required.

1.03 CERTIFICATION:

A. Engineer's Final Certification of Completion:

1. The Engineer of Record shall perform site inspections as necessary to provide the City with a Certificate of Completion. Certificate shall state that all improvements have been constructed in general compliance with the City approved construction drawings and Construction Specifications. Certificate of Completion shall bear the name, signature, current date and Missouri Registration Number of the Engineer.
2. Upon satisfactory completion of any sanitary sewer or water mains, the Engineer of Record shall compete and submit all required documentation and testing data to the City and MoDNR to achieve acceptance and authorization for the sanitary sewer or water mains to be placed in service.

PART 2 - PRODUCTS - Not applicable.

PART 3 - EXECUTION - Not applicable.

END OF SECTION 01200

SECTION 01300 – SUBMITTALS

PART 1 - GENERAL

1.01 SUMMARY:

- A. This Section includes definitions, descriptions, transmittal, review of “Compliance” submittals, and record drawings.
- B. Related Work Specified Elsewhere:
 - 1. Project Meetings: SECTION 01200.

1.02 GENERAL INFORMATION:

- A. Definitions:
 - 1. Compliance Submittals include shop drawings and product data which are prepared by the Contractor, Subcontractor, Manufacturer, or Supplier and submitted by the Contractor with approval by the Engineer of Record to the City as a basis for approval of the use of equipment and materials proposed for incorporation in the Work or needed to describe installation, operation, maintenance, or technical properties.
 - a. Shop drawings include custom-prepared data of all types including drawings, diagrams, material schedules, templates, instructions, and similar information not in standard printed form applicable to other projects.
 - b. Product data includes standard printed information on materials, products and systems; not custom-prepared for this Project, other than the designation of selections from available choices.
 - 2. Contractor shall maintain in a safe place at the site one record copy of all Drawings, Specifications and Addenda in good order and annotated to show all changes made during construction. Upon completion of the Work, these record documents will be delivered to the Engineer of Record who shall provide paper, autocad.dwg, (2010 or later version), and pdf copies of the revised drawings to the City. The drafting of the record, (as-built), drawings shall comply with all of the same criteria as the construction drawings and shall be corrected to show the project as constructed. The drawings shall accurately and completely denote all changes made during the course of the work. The Engineer of Record shall gather field notes and shall conduct field surveys of all items, (fire hydrants, valves, manholes, storm boxes, exposed storm pipe ends, storm water detention basins etc.) to ensure the accuracy of the record, (as-built) drawings. Where changes occur, the Engineer of record shall verify and certify in writing that all design criteria are still met.
 - 3. Refer to ARTICLE 1.03 of this Part for detailed lists of documents and specific requirements.

SECTION 01300 – SUBMITTALS

B. Quality Requirements:

1. Submittals such as shop drawings and product data shall be of the quality for Legibility and reproduction purposes. Every line, character, and letter shall be clearly legible.
2. Documents shall be submitted in an organized manner to the Engineer for review. Any variations from specified materials/equipment/procedures shall be approved by the City. One copy of each Engineer “Approved” shop drawing shall be submitted to the City upon completion of the work. Any unapproved material/equipment shall be removed and replaced with material/equipment specified herein.

C. Language and Dimensions:

1. All words and dimensional units shall be in the English language.
2. Metric dimensional unit equivalents may be stated in addition to the English units.

D. Submittal Completeness:

1. Submittals shall be complete with respect to dimensions, design criteria, materials of construction and other information specified to enable the City/Engineer to review the information effectively. All plan and drawing submittals shall meet the criteria outlined in the latest addition of the Design Standards.

E. Submittal Procedure:

1. Documents shall be submitted to the Engineer prior to being submitted to the City.
2. Submit documents to the City after approval by the Engineer.

1.03 COMPLIANCE SUBMITTALS:

A. Items shall include, but not be limited to, the following:

1. Manufacturer’s specifications.
2. Catalogs, or parts thereof, of manufactured equipment.
3. Shop fabrication and erection drawings.
4. Concrete mix design information.
5. All drawings, catalogs or parts thereof, manufacturer’s specifications and data, samples, instructions, and other information specified or necessary.
6. Record drawings.

SECTION 01300 – SUBMITTALS

PART 2 - PRODUCTS - Not applicable.

PART 3 - EXECUTION - Not applicable.

END OF SECTION 01300

SECTION 01530 - TEMPORARY BARRIERS AND CONTROLS

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes General Requirements for:
 - 1. Protection of Work.
 - 2. Protection of existing property.
 - 3. Barriers.
 - 4. Environmental controls.
 - 5. Traffic control and use of roadways.
- B. Related Work Specified Elsewhere:
 - 1. Site Preparation and Earthwork: SECTION - 02200.
 - 2. Trenching and Backfilling for Utilities: SECTION - 02222.
 - 3. Right-of-Way Technical Specifications: SECTION -12000
- C. See Details in the Standard Drawing Details.

PART 2 - PRODUCTS - Not Applicable.

PART 3 - EXECUTION

3.01 PROTECTION OF WORK AND PROPERTY:

- A. General:
 - 1. Provide protection at all times against rain, wind, storms, frost, freezing, condensation, or heat so as to maintain all Work and equipment and materials free from injury or damage. At the end of each day all new Work likely to be damaged shall be appropriately protected.
 - 2. Notify the Public Works Department immediately at any time operations are stopped due to conditions which make it impossible to continue operations safely or to obtain proper results.
 - 3. Construct and maintain all necessary temporary drainage and do all pumping necessary to keep excavations, floors, pits, trenches, manholes, and ducts free of water.

SECTION 01530 - TEMPORARY BARRIERS AND CONTROLS

B. Property Other than Developer's/Owner's:

1. Report immediately to the owners thereof and promptly repair damage to existing facilities resulting from construction operations.
2. Names and telephone numbers of representatives of agencies and utilities having jurisdiction over streets and utilities in the Work area can be obtained from the City for the agencies listed below. Concerned agencies or utilities shall be contacted a minimum of 48 hours prior to performing Work, or closing streets and other traffic areas. Notify 1-800 DIG-RITE 48 hours prior to excavating near underground utilities or pole lines.
 - (a) Water
 - (b) Gas
 - (c) Sanitary sewers
 - (d) Storm drains
 - (e) Pipeline companies
 - (f) Telephone
 - (g) Electric
 - (h) Municipal streets
 - (i) Fire
 - (j) Police
 - (k) Cable Television
 - (l) Right of Way Manager
3. Operation of valves or other appurtenances on existing utilities, when required, shall be by or under the direct supervision of the owning utility.
4. Where fences are to be breached on private property, the owners thereof shall be contacted and arrangements made to ensure proper protection of any livestock or property thus exposed.
5. The applicable requirements specified for protection of the Work shall also apply to the protection of existing property of others.

SECTION 01530 - TEMPORARY BARRIERS AND CONTROLS

6. When required by the Public Works Director, video-taping and documentation of the condition of neighboring properties not owned by the City or Developer shall be accomplished by the Contractor to document existing conditions.
7. Before acceptance of the Work by the City, restore all property affected by Contractor's operations to the original or better condition.

3.02 BARRIERS

A. General:

1. Furnish, install, and maintain suitable barriers as required to prevent public entry, protect the public, and to protect the Work, existing facilities, trees, and plants from construction operations. Barriers shall be required on all unattended excavations and at the direction of the Right of Way Manager. Remove all barriers and controls when no longer required.
2. Barrier materials may be new or used, suitable for the intended purpose, but must not violate requirements of applicable codes and standards or regulatory agencies.
3. Barriers shall be of a neat and reasonable uniform appearance, structurally adequate for the required purposes.
4. Maintain barriers in good repair and clean condition for adequate visibility.
5. Relocate and adjust barriers as required by progress of Work.
6. Repair damage caused by installation and restore all disturbed area(s) to original or better condition.
7. Clean the total Work area.

3.03 ENVIRONMENTAL CONTROLS

A. Dust Control:

1. Provide positive methods and apply dust control materials to minimize raising dust from construction operations; and to prevent airborne dust from dispersing into the atmosphere.

B. Water and Erosion Control:

1. Provide methods to control surface water to prevent damage to the Project, the site, or adjoining properties.
2. Provide required temporary construction entrances and all silt and sediment controls prior to any land disturbance. Sediment basins and any required detention facilities shall also be installed prior to other land disturbance.

SECTION 01530 - TEMPORARY BARRIERS AND CONTROLS

3. The contractor is responsible for controlling erosion and discharge of sediment from the site at all times during construction. The contractor shall provide necessary measures during all phases of his operations regardless of whether they are specifically noted on the plans and shall maintain and replace controls as necessary during the course of his operations. These necessary measures include cleaning both interior and adjacent streets as required after each rainfall and at the end of construction. The contractor shall be responsible for cleaning all accumulated sediment from storm drains prior to final approval.
4. The contractor's Sediment Control Officer, (as designated in the Stormwater Pollution Prevention Plan), is responsible for inspecting best management practices, (BMP's), both weekly and after rains in accordance with the MoDNR, and the City's land disturbance permits. The Sediment Control Officer is responsible for maintaining copies of the Sediment and Erosion Control Plan, the Stormwater Pollution Prevention Plan, (SWPPP) and the weekly inspection report on site at all times.
5. Plan and execute construction and earthwork by methods to control surface drainage from cuts and fills, pits, tunnels, and other construction areas, and borrow and waste disposal areas, to prevent erosion and sedimentation. and to direct drainage to proper runoff. Hold the areas of bare soil exposed at one time to a minimum.
6. Provide, operate, and maintain hydraulic equipment of adequate capacity to control surface and groundwater.
7. Dispose of drainage water in a manner to prevent flooding, erosion, or other damage to any portion of the site or to adjoining areas.
8. All disturbed land area not receiving permanent stabilization such as pavement or facilities shall be revegetated and have vegetation established prior to removal of temporary sediment controls.

C. Debris Control and Clean-Up:

1. Keep the premises free at all times from accumulations of debris, waste materials, and rubbish caused by construction operations. Contractor's employee's responsibilities shall include:
 - a. Adequate trash receptacles about the site, emptied promptly when filled.
 - b. Periodic cleanup; to avoid hazards of interference with operations at the site and to maintain the site in a reasonably neat condition.
 - c. The keeping of construction materials such as forms and scaffolding neatly stacked.
2. Prohibit overloading of trucks to prevent spillage on access and haul routes. Provide periodic inspection of traffic areas to enforce requirements.

SECTION 01530 - TEMPORARY BARRIERS AND CONTROLS

D. Pollution Control:

1. Provide methods, means, and facilities required to prevent contamination of soil, water, or atmosphere by the discharge of hazardous or toxic substances from construction operations. Provide concrete wash out areas when applicable.
2. Provide equipment and personnel and perform emergency measures required to contain any spillages, and to remove contaminated soils or liquids. Excavate and dispose of any contaminated earth off-site in approved locations deemed acceptable by the appropriate regulatory agency, and replace with suitable compacted fill and topsoil.
3. Take special measures to prevent harmful substances such as contaminated soils and liquids from entering public waters, sanitary sewers, or storm sewers.

3.04 TRAFFIC CONTROL AND USE OF ROADWAYS

A. Traffic Control:

1. The contractor shall be responsible for providing, operating, and maintaining equipment, services, and personnel, with traffic control and protective devices, as required to expedite vehicular traffic flow on haul routes, at site entrances, on-site access roads, and parking areas. This includes traffic signals and signs, flagmen, flares, lights, barricades, and other devices or personnel as necessary to adequately protect the public. Flashers and barricades shall be a type approved by the Right of Way Manager and shall be as per Part VI of the latest edition of the Manual on Uniform Traffic Control Devices. All proposed traffic control measures shall be submitted a minimum of 48 hours in advance for review and approval by the Right of Way Manager.
2. The Contractor shall take every precaution to protect pedestrian and vehicular traffic. Whenever, in the opinion of the Right of Way Manager, the Contractor has not provided sufficient or proper safety precautions and safeguards, he shall do so immediately and to whatever extent the Right of Way Manager deems advisable.
3. Consult with governing authorities to establish public thoroughfares which will be used as haul routes and site access. All operations shall meet the approval of owners or agencies having jurisdiction.
4. Streets may not be closed to through traffic unless otherwise provided for in the Special Provisions. Streets shall not be closed to traffic until such closure has been approved by the Right of Way Manager. Any street closures that may be permitted shall be made in such a manner as to provide for maximum public safety and public convenience, and shall be opened to through traffic at such time as the work has been completed, or as the Right of Way Manager may direct.
5. Provide and maintain suitable detours or other temporary expedients if necessary. Detours both outside and within the limits of the project such as side street crossings, temporary

SECTION 01530 - TEMPORARY BARRIERS AND CONTROLS

bridges over freshly placed concrete, utilization of one or more lanes of the construction for maintenance of traffic, and such related facilities for the maintenance of traffic shall be the sole responsibility of the Contractor. All detour signage shall conform to the standards set forth in the Manual on Uniform Traffic Control Devices, (MUTCD).

6. Local traffic shall be provided access to private properties at all time, except during some urgent stages of construction when it is impracticable to carry on the construction and maintain traffic simultaneously, such as for the placing and curing of pavement and deep excavations which prohibit safe travel of vehicular traffic. No private driveway may be closed without the approval of the Right of Way Manager, unless written permission has been provided to the Contractor by the owner of the property affected. Emergency traffic such as police, fire and disaster units shall be provided reasonable access at all times. The Contractor shall be liable for any damages which may result from his failure to provide such reasonable access.
7. Bridge over open trenches where necessary to maintain traffic.
8. Remove temporary equipment and facilities when no longer required. Restore grounds to original, better, or specified condition when no longer required.

B. Maintenance of Roadways:

1. Repair/replace roads, walkways, and other traffic areas damaged by operations. Keep traffic areas as free as possible of excavated materials and maintain in a manner to eliminate dust, mud, and hazardous conditions.
2. All operations and repairs shall meet the approval of owners or agencies having jurisdiction.

END OF SECTION 01530

SECTION 02200 - SITE PREPARATION AND EARTHWORK

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes site preparation activities and certain items of earthwork common to other related Work.
- B. Related Work Specified Elsewhere:
 - 1. Trenching and Backfilling for Utilities: SECTION 02222.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Association of State Highway and Transportation Officials, (AASHTO).
 - a. M80 – Standard Specification for Coarse Aggregate for Hydraulic Cement Concrete.
 - b. T104 – Standard Method of test for Soundness of Aggregate by Use of Sodium Sulfate or Magnesium Sulfate.
 - 2. American Society for Testing and Materials (ASTM):
 - a. D698-Laboratory Compaction Characteristics of Soil Using Standard Effort.
 - b. D1556-Density and Unit Weight of Soil in Place by Sand Cone Method.
 - c. D2167- Density and Unit Weight of Soil in Place by the Rubber Balloon Method.
 - d. D3786-Bursting Strength of Textile Fabrics - Diaphragm Bursting Strength.
 - e. D4254-Minimum Index Density and Unit Weight of Soils and Calculation of Relative Density.
 - f. D4491-Water Permeability of Geo-textiles by Permittivity.
 - g. D4632-Grab Breaking Load and Elongation of Geo-textiles.
 - h. D4751-Determining the Apparent Opening Size of a Geo-textile.
 - i. D4833-Index Puncture Resistance of Geomembranes, and Related Products.
 - j. D6938-In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth)

SECTION 02200 - SITE PREPARATION AND EARTHWORK

PART 2 - PRODUCTS

2.01 EARTHWORK

- A. Materials suitable for use in embankment, structural backfill and fill include material free of debris, roots, organic matter, and frozen matter; and free of stone having any dimension greater than 2 inches in areas requiring a high degree of compaction or 4 inches in other embankment and fill areas:
 - 1. Cohesion-less materials include gravels, gravel-sand mixtures, sands, and gravelly sands exclusive of clayey material:
 - a. Free-draining.
 - b. Materials for which impact compaction will not produce well-defined, moisture density relationship curve.
 - c. Maximum density by impact methods will generally be less than by vibratory methods.
 - d. For which generally less than 15 percent by dry weight, of soil particles pass the No. 200 sieve.
 - 2. Cohesive materials include silts and clays generally exclusive of sands and gravel:
 - a. Materials for which impact compaction will produce a well-defined, moisture-density relationship curve.
- B. Materials unsuitable for use in embankment and fill include all material that contains debris, roots, organic matter, frozen matter, stone (with any dimension greater than 2 inches in areas requiring a high degree of compaction or 4 inches in other embankment and fill areas), or other materials that are determined by the Public Works Director or his representative during routine or random inspections to be too wet or otherwise unsuitable.
- C. Waste materials include excess usable materials and materials unsuitable for use in the Work.
- D. Borrow materials include all fill materials, structural backfill and topsoil obtained from locations on or off the jobsite.

2.02 RIPRAP

- A. Riprap Material:
 - 1. All stone shall be durable and of suitable quality to ensure permanence in the structure and in the climate in which it is to be used.
 - 2. Boulders or quarried rock may be used and shall be graded as per the construction drawings/specifications.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

3. Quantity of rock with an elongation greater than 3:1 shall not exceed 20% of the mass. No stone shall have an elongation greater than 4:1.
 4. Stone shall be free from cracks, seams or other defects that would tend to increase its deterioration from natural causes.
 5. Objectionable quantities of dirt, sand, clay, and rock fines will not be permitted. Final determination of objectionable quantities will be made by the Public Works Director.
 6. Not more than 10% of the stone shall show splitting, crumbling, or spalling when subjected to five cycles of the sodium soundness test as required by AASHTO T104.
 7. Contractor may be required to furnish a sample of stone as part of the submittal process to the Public Works Department for acceptance.
- B. Bedding material for riprap shall conform to all applicable requirements of AASHTO M80 and shall be reasonably well-graded within the following limits: Crushed rock conforming to the gradation specified may be used.

<u>Sieve Size</u>	<u>Percent Passing By Weight</u>
4-inch	100
3-inch	80-100
2-inch	70-90
3/4-inch	45-60
No. 4	20-30
No. 10	5-15
No. 40	0-5

2.03 STRUCTURAL BACKFILL

- A. Crushed rock conforming to the following gradation may be needed.

<u>Sieve Size</u>	<u>Percent Passing by Weight</u>
1-1/2-inch	100
1-inch	75-95
1/2-inch	55-75
No. 4	35-55
No. 10	25-45
No. 40	14-30
No. 200	4-10

- B. Structural backfill material shall be subject to approval of the Public Works Director and arranged for by the Contractor.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

2.04 FILTER FABRIC

- A. Filter fabric of non-woven geo-textile conforming to, American Society for Testing and Materials (ASTM), D3786, D4491, D4632, D4751 and D4833.

2.05 SOIL STERILANT

- A. Sterilant shall be Krover as manufactured by E.I. DuPont De Nemours and Co or equal.

2.05 TOP SOIL

- A. Materials:
 - 1. Those materials obtained from excavation which is most suitable and stockpiled for such purpose:
 - 2. Borrow when required.
 - 3. Topsoil shall be a fertile, friable, and loamy soil of uniform quality, free from materials such as hard clods, stiff clay, and stone with any dimension greater than 1 inch, and similar impurities. Relatively free from grass, roots, weeds, and other objectionable plant material.

PART 3 – EXECUTION

3.01 GENERAL

- A. Any disturbance of land exceeding one acre in size requires a Land Disturbance Permit from MoDNR and the City. In addition, all related documentation including the security deposit shall be submitted and approved by the City prior to any land disturbance.
- B. All required erosion control Best Management Practices, (BMP's) including sediment basins shall be installed prior to any land disturbance. All BMPs shall be maintained throughout the construction project and shall remain in place until disturbed areas are stabilized with vegetation or permanent surfaces to the satisfaction of the Public Works Director. After stabilization, requests for termination of Land Disturbance Permits and refund of security deposits may be submitted.
- C. The contractor shall adhere to any and all statutes regarding the notification of utilities prior to beginning any work. Relocation or protection of any existing utilities shall be governed by the applicable section of these Construction Specifications. The relocation and/or protection of any utility that is shown on the plans, that lies within a utility easement and is endangered by this construction shall be the responsibility of the contractor.
- D. The contractor shall make every reasonable effort to protect private facilities. These facilities may not be shown on the plans. When these facilities are disturbed or damaged by work, the

SECTION 02200 - SITE PREPARATION AND EARTHWORK

contractor shall make necessary arrangements for repairs to the facilities for continuous service prior to the close of that work day.

- E. It shall be the responsibility of the contractor to protect all property lot corners and control monuments. Should it be necessary to disturb such monument, whether stake, pin, bar, disk, box, or other, it remains the responsibility of the contractor to reference such markers prior to removal, reset them, and file such relocations or monumentation documents as the law may require. Any such references, removal, replacement and certification of monuments shall be performed by a surveyor registered and licensed in the State of Missouri. A copy of all such certification documents shall be provided to the City prior to approval of the project.
- F. Grading, excavation, and backfilling for all improvements, shall be made to the lines, grades and cross section indicated by the plans. In addition, to any erosion control measures shown on the plans, the contractor shall schedule and conduct his operation in such a manner and shall provide any necessary control facilities to protect downstream and adjacent properties from pollution, sedimentation or erosion caused by the grading operations. Any pollution or damage occurring as a result of the work shall be the responsibility of the contractor.
- G. During construction, the graded area shall be maintained by the contractor in such condition that it will be well drained at all times. Roadway ditches, channel changes, inlet and outlet ditches and other ditches in connection with the roadway shall be cut and maintained to the required cross section. All drainage work shall be performed in proper sequence with other operations. All ditches and channels shall be kept free of debris or obstructions.

3.02 SITE PREPARATION

A. Clearing and Grubbing:

- 1. Perform selective clearing and grubbing as indicated or as necessary to perform excavation, trenching, embankment, borrow, and other Work required, and as directed by the Engineer.
 - a. Clearing:
 - (1) Includes felling and disposal of trees, brush, and other vegetation. Trees, brush and vegetation shall not be buried on the job site.
 - (2) Conduct Work in a manner to prevent damage to property and to provide for the safety of employees and others.
 - (3) Keep operations within property lines as indicated.
 - b. Grubbing:
 - (1) Includes removal and disposal of tree stumps and roots larger than 3 inches in diameter. Stumps and roots shall not be buried on the job site.
 - (2) Remove to a depth of at least 18 inches below existing grade elevation

SECTION 02200 - SITE PREPARATION AND EARTHWORK

(3) Backfill all excavated depressions with approved material and grade to drain.

B. Protection of Trees:

1. Protect tops, trunks, and roots of existing trees on Project site which are to remain, as follows:
 - a. Box fence around, or otherwise protect trees before any construction work is started.
 - b. Do not permit heavy equipment or stockpiles within branch spread.
 - c. Trim or prune to obtain working space in lieu of complete removal when possible. Conduct operation as follows:
 - (1) With experienced personnel.
 - (2) Conform to good horticultural practice.
 - (3) Preserve natural shape and character.
 - (4) Protect cuts with approved tree paint.
 - d. Grade around trees as follows:
 - (1) Trenching: Where trenching is required around trees which are to remain, avoid cutting the tree roots by careful hand tunneling under or around the roots. Avoid injury to or prolonged exposure of roots.
 - (2) Raising Grades: Where existing grade at a tree is below the new finished grade and fill not exceeding 16 inches is required, place 1 to 2 inches of clean, washed gravel directly around the tree trunk. Extend gravel out from trunk on all sides at least 18 inches and finish 2 inches above finished grade at tree. Install gravel before earth fill is placed. Do not leave new earth fill in contact with any tree trunks.
 - (3) Lowering Grades: Re-grade by hand to elevation required around existing trees in areas where new finished grade is to be lowered. As required, cut the roots cleanly 3 inches below finished grade and cover scars with tree paint.
 - e. Remove when damage occurs and survival is doubtful as determined by the Public Works Director.

C. Stripping:

1. Remove topsoil from all areas within limits of the construction easement and properly stockpiled and protected for reuse as required on the site.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

D. Debris:

1. Dispose of debris from clearing, grubbing, stripping, and demolition at a location off the job site as arranged for by the Contractor.

3.03 EARTHWORK

A. Excavation:

1. Perform excavation as indicated or as required to complete the work. Normally materials to be excavated are earth and other materials which can be removed by power shovel, bulldozer, or other normal equipment, but not requiring the use of explosives or drills.
2. All suitable material removed by excavation shall be used as far as practicable in the formation of embankment as required to complete the work. The contractor shall sort all excavating material and stockpile when necessary, so as to provide suitable materials for embankments.
3. Rock encountered within the full width of a roadway, shall be under-graded to an elevation of 6 inches below the finished subgrade elevation. Rock shall be removed in such a manner as to not leave excessive water pockets in the surface. Areas under-graded shall be backfilled with either rock fragments or spalls, or a granular type material having a plasticity index not to exceed 10 and a gradation such that at least 50 percent of the material will be retained on the No. 4 Sieve and no more than 40 percent will pass the No. 10 Sieve.
4. Blasting:
 - a. Drill and blast, including pre-split blasting, rock not removable by other excavation methods, in a manner that completes the excavation to lines indicated or acceptable and required for access, with the least disturbance to adjacent material. All blasting schedules and times shall be provided to the City for approval a minimum of 24 hours in advance.
 - b. Blasting shall be performed only by persons who are qualified, competent, and thoroughly experienced in the use of explosives for rock excavation.
 - c. Locate charge holes properly and drill to correct depth for the charges used.
 - d. Limit charges in size to minimum required for reasonable removal of material by excavating equipment.
 - e. Determine spacing of drill holes, size of explosive charges, time delays and blasting techniques, including the use of approved explosion mats, to avoid excessive over break or damage to adjacent structures, equipment, utilities, or buried pipeline and conduit.
 - f. Contractor shall monitor blasting operations at necessary locations throughout all blasting activities. Peak particle velocities and/or displacements at adjacent structures,

SECTION 02200 - SITE PREPARATION AND EARTHWORK

equipment, exposed or buried, pipelines and conduits shall not exceed the level of criteria as determined by United States Department of Interior, Bureau of Mines in their Figure B-1 from Report of Investigations 8507 by D.E. Siskind, et. al., unless otherwise directed by City/Engineer.

- g. Contractor shall assume full liability for any damage to adjacent structures, equipment, new construction, utilities, or buried pipelines and conduit caused by blasting operations.
- h. Blasting near utilities shall be subject to approval of owning agency.
- i. Before delivery of any explosives at jobsite, Contractor must have obtained a blasting endorsement on his public liability and property damage insurance policy.
- j. Remove overblast rock materials to competent rock and replace as directed by Engineer.

5. Dewatering:

- a. Control grading around excavations to prevent surface water from flowing into excavation areas.
- b. Drain or pump as required continually maintaining all excavations and trenches free of water or mud from any source, and discharging to approved drains or channels. Commence when water first appears and continue until Work is complete to the extent that no damage will result from hydrostatic pressure, flotation, or other causes.
- c. Use pumps of adequate capacity to ensure rapid drainage of area, and construct and use drainage channels and sub-drains with pumps as required.
- d. Remove sub grade materials rendered unsuitable by excessive wetting and replace with approved backfill material.

6. Stockpiling:

- a. Stockpiling in amounts sufficient for and in a manner to segregate materials suitable for the following:
 - (1) Top soiling.
 - (2) Constructing embankments and fills.
 - (3) Backfilling.
- b. Do not obstruct or prevent access to:
 - (1) Roads and driveways, (Stockpiling in public right-of-ways shall only be permitted by permission of the Right of Way Manager.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

(2) Utility control devices.

(3) Ditches or natural drainage channels.

- c. Perform in a manner to avoid endangering the work, stability of banks or structures, or health of trees and shrubs to be saved.
- d. Maintain safe distance between toe of stockpile and edge of excavation or trench.
- e. Stockpile in other areas or off site when adjacent structures, easement limitations, or other restrictions prohibit sufficient storage adjacent to the Work. Off-site areas shall be arranged for by Contractor and/or Developer/Owner.

7. Waste Materials:

- a. Remove waste materials from Work area as excavated.
- b. Deposit such materials in locations and within areas approved by City/Engineer and as indicated.
- c. Place excavated rock in the interior of waste area fills so that it will not be exposed to view.
- d. Grade waste areas and leave them free draining and with an orderly and neat appearance.

B. Embankments:

- 1. Construct embankments to the contours and elevations indicated, using suitable City/Engineer approved material from excavations and borrow areas: Material removed from borrow areas shall be arranged for by the contractor. Borrow areas shall be graded to drain and to present a neat appearance. Place embankment only on sub grades approved by City/Engineer. Do not place snow, ice, or frozen earth infill; do not place fill on a frozen surface.
- 2. Where embankments, regardless of height, are placed against hillsides or existing embankments, either of which have a slope steeper than 1 vertical to 4 horizontal, the existing slope shall be benched or stepped in approximately 24 inches rises as the new fill is brought up in 12-inch maximum layers or lifts. The material bladed out, the bottom of the area cut into, and the embankment material being placed, shall be compacted to the required density. The existing surface upon which embankment material is to be placed shall have all unstable and unsuitable material removed before starting the embankment work.
- 3. Where embankments 2 feet or less in depth are to be placed on areas covered by existing pavement, the existing pavement shall be removed and the cleared ground surface shall be compacted to the specified density. Where embankments greater than 2 feet in depth are to

SECTION 02200 - SITE PREPARATION AND EARTHWORK

be placed on areas covered by existing pavement, the existing pavement shall be broken into pieces not larger than 6 inches maximum dimension, left in place and the embankment started thereon.

4. Earth shall be placed in successive horizontal layers distributed uniformly over the full width of the embankment area. Each layer of materials shall not exceed 12 inches maximum in thickness (loose state) and shall be compacted to not less than the required density before the next layer is placed thereon. As the compaction of each layer progresses, continuous blading, or dozing will be required to level the surface and to insure uniform compaction. Embankment construction shall not be performed when material contains frost, is frozen or is snow covered.
5. When earth and stone or rock fragments are mixed in the embankment, all stones or rock fragments exceeding the thickness of the compacted lift shall be disposed of by being incorporated into the embankment outside the limits of the proposed surfaced areas. The thickness of the layer in these areas may be increased if necessary to accommodate the rocks, but shall not exceed 15 inches in thickness (loose state). The stones or rock fragments are to be placed so there will be no nesting.
6. When the excavated material consists predominantly of stone or rock fragments of such size that the material cannot be placed in layers of the thickness prescribed, such material shall be placed in the embankment in layers having a thickness of approximate average size of the larger rocks but not to exceed 24 inches. Rock or boulders too large to permit placing in a 24-inch layer shall be reduced in size as necessary to permit placement. Rock shall not be dumped in place but shall be distributed by blading or dozing in a manner to insure proper placement in final position in the embankment.

C. Subgrades:

1. Excavate or fill as required to construct sub grades to the elevations and grades indicated. Coordinate required inspections with the Public Works Department. Remove all unsuitable material and replace with City/Engineer approved fill materials. Perform all wetting, drying, shaping, and compacting required to prepare a suitable sub grade.
2. Sub grade for Fills and Embankment: Roughen by disking or scarifying. Wet or dry top 6 inches, as required, to bond with fill or embankment.
3. Sub grade for Roadways, Drives and Parking Areas:
 - a. Extend sub grade the full width of the roadbed plus one foot outside the edges of the overlying course to be placed.
 - b. Roadway/drives/parking area embankment earth (fill) materials shall be placed in horizontal layers not exceeding twelve (12) inches unless otherwise approved by the City/Engineer and shall be compacted as specified before the next layer is placed. Effective spreading equipment shall be used on each lift to obtain uniform thickness prior to compaction.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

4. The newly finished subgrade shall be repaired from action of the elements or others. Any settlement or erosion that occurs prior to placing the pavement thereon, shall be repaired and the specific lines, grades and cross-section reestablished. Any subgrade that has become unacceptable shall be reworked as necessary to restore the subgrade to shape, tolerance, density, and moisture content range for such density, immediately prior to the placing of the pavement. The Contractor shall protect all existing improvements from damage resulting from his subgrade operation. Any improvement damaged shall be repaired or replaced by the Contractor at his own expense. Subgrade clean-up shall follow the work progressively. The Contractor shall remove from the project site all rubbish, equipment, tools, surplus or discarded material and temporary construction items.

D. Site Grading:

1. Excavate, fill, compact fill, and rough grade to bring Project area outside of structures to sub grades as follows:
 - a. For surfaced areas, to underside of respective surfacing or base course:
 - (1) Prepare sub grades as specified in this Section.
 - b. For lawn and planted areas, to 4 inches below finished grade.
2. Rock:
 - a. Includes rock encountered in grading areas outside of structures.
 - b. Excavate rock to depths as follows:
 - (1) Under surfaced areas, to 6 inches below the top of respective sub grades.
 - (2) Under lawn and planted areas, to 24 inches below finished grade:
 - (a) Boulder or protruding rock outcrop shall be left undisturbed where indicated.
 - c. Backfill to grade with approved earth fill compacted-in-place:
 - (1) Achieve minimum density specified for particular location.
3. Fill:
 - a. Fill as required to raise existing grades outside of structure areas to the new grades as indicated.
 - b. Such fill shall be performed as specified in PART 3, paragraph 3.03, B. – Embankment, this Section.
 - c. Remove all debris subject to termite attack, rot, or corrosion from areas to be filled.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

4. Rough Grading:

- a. All areas within the Project, including excavated and filled sections, and adjacent transition areas shall be reasonably smooth, compacted, and free from irregular surface changes.
- b. Degree of finish shall be that ordinarily obtained from blade grader or scraper operations, except as otherwise specified.
- c. Finished rough grades shall generally be not more than 0.5 foot above or below established grade or approved cross sections with due allowance for topsoil and sod.
- d. Tolerance for areas within 10 feet of structures and areas to be paved shall not exceed 0.15 foot above or below established sub grade.
- e. Finish all ditches, swales, and gutters to drain readily.
- f. Unless otherwise indicated, slope the sub grade evenly to provide drainage away from structure walls in all directions at a grade not less than $\frac{1}{4}$ inch per foot.
- g. Provide a suitable grading radius at top and bottom of banks and at other breaks in grade.

E. Top-soiling:

1. Includes placement of topsoil on all areas to be re-vegetated and not specified to receive paving or other surface treatment (including borrow or waste areas).
2. Subgrade Treatment:
 - a. Clear site of vegetation heavy enough to interfere with proper grading and tillage operations.
 - b. Clear surfaces of all stones or other objects larger than 3 inches in thickness or diameter, all roots, brush, wire, grade stakes, or other objectionable material.
 - c. Loosen sub grade by disking or scarifying to a depth of 2 inches wherever compacted by traffic or other causes to permit bonding of the topsoil to the sub grade.
3. Placement of Topsoil:
 - a. Distribute over required areas without compaction in upper 1 foot, other than that obtained with spreading equipment.
 - b. To extent material is available within following limits:
 - (1) Not less than 4 inches in depth.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

- (2) Do not exceed 2 feet in depth.
- c. Shape cuts, fills, and embankments to contours indicated.
- d. Grade to match contours of adjacent areas and permit good, natural drainage.
- e. Provide gentle mound over trenches.
- 4. Maintenance:
 - a. After topsoil has been spread, clear surface of stones or other objects larger than 1 inch in thickness or diameter and all other objects that might interfere with planting and maintenance operations.
 - b. Protect top soiled areas from the elements until grass is established and repair eroded areas as required.
 - c. Promptly remove topsoil or other dirt dropped upon paved surfacing.

3.04 RIPRAP

A. Foundation Preparation:

- 1. Trim and dress areas requiring riprap to conform to cross sections indicated within an allowable tolerance of ± 3 inches from the theoretical slope lines and grades.
- 2. Where such areas are below the allowable minus tolerance limit, they shall be brought to grade by filling with bedding material.
- 3. Do not place bedding on the base until the base has been approved.

B. Filter Blanket Placement:

- 1. Place filter blanket only on foundation approved by City/Engineer. Material for filter blanket shall consist of filter fabric meeting the requirements of this section.
- 2. Filter fabric will be inspected by City/Engineer at the time of installation and will be rejected if damaged during manufacture, transportation or storage. The filter fabric shall be placed with its long dimension horizontal and shall be laid smooth and free of tension, stress, folds, wrinkles or creases.
 - a. Strips shall be placed to provide not less than 18 inches of overlap at each joint.
 - b. Contractor shall anchor filter fabric to prevent dislocation during placement of riprap. The method of anchoring shall be submittal for approval by the City/Engineer.
 - c. Tracked or wheeled equipment will not be permitted on slopes covered with filter fabric.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

d. Filter fabric shall be left exposed no more than one week prior to riprap placement.

C. Placement of Riprap:

1. Place on the slopes within the limits as indicated.
2. Place stone for riprap on the prepared base in such a manner as to produce a reasonably well-graded mass of rock with a minimum practicable percentage of voids.
3. Place to its full course thickness in one operation in a manner to avoid displacing the bedding material.
4. Finished riprap shall be free from objectionable pockets of small stones and clusters of larger stones. Riprap shall be hand-place only if necessary to secure the desired results.
5. Maximum deviation from slope lines and grades indicated shall not exceed 6 inches. Maximum deviation shall not be continuous over an area greater than 10 square feet.
6. Maintain the riprap until approved and replace any material displaced by any cause.

3.05 SOIL STERILANT

A. Apply soil sterilant to the following areas:

1. Pump Station areas prior to placement of crushed rock surfacing.
2. Along base of fencing:
 - a. Width of treated area shall not exceed 12 inches.

B. Apply according to manufacturer's recommendations.

3.06 FIELD QUALITY CONTROL

A. Compaction:

1. Contractor shall, through services of an independent testing laboratory, provide adequate tests for all embankments, fills, structural backfill and sub grades under this. Project to determine conformance with specified density relationships. A copy of all test results shall be provided to the City.
2. The moisture content of the soil at the time of compaction shall be uniform and shall be such that the soil can be compacted to the requirements of the type of compaction as designated on the drawings or as directed by the City/Engineer. When the moisture content of the soil is not satisfactory to the City/Engineer, water shall be added or the material aerated, whichever is needed to adjust the soil to the proper moisture content. In no case, shall water be added without the consent of the City/Engineer.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

3. After removal of roadway excavation material to the required section, all material between lines 1 foot outside the curbs shall be compacted to a density of at least ninety-five (95) percent of the maximum density for the material used for a depth of at least six (6) inches below the finished subgrade elevation and within the tolerance of the moisture for the type of material at ninety-five (95) percent of maximum density, as determined by the standard proctor test (ASTM D698) and with a tolerance of minus 3 percent and plus 2 percent of the optimum moisture at maximum density as determined by the Moisture Density Curve obtained. Any further compacted layers shall be accomplished in the same manner as specified. Compaction of low plasticity or non-plastic, fine-grained material shall be considered adequate when additional passes of the roller do not bring the tamping feet closer to the surface of the lift, provided the entire weight of the roller is supported on the tamping feet and none by material directly in contact with the drum. Sand and gravel which cannot be compacted satisfactorily with a sheep-foot roller shall be rolled with a pneumatic-tired roller. Each lift shall be rolled until no further consolidation is evident.
4. Proof rolling of roadway subgrade with a heavy rubber-tired roller or other approved equipment will be required when ordered by the City. Proof rolling shall be done after specified compaction has been obtained. Areas found to be weak (exhibit excessive pumping and those areas which fail shall be ripped, scarified, wetted or dried if necessary and re-compacted to the requirements for density and moisture at the contractor's expense. The operating weight of the roller shall be not less than 12-1/2 tons per wheel. Tires shall be inflated to a minimum pressure of 70 pounds per square inch and a maximum pressure of 90 pounds per square inch.
5. The subgrade for sidewalk pavements shall be compacted to a density equivalent to the density of the immediately surrounding soil in areas not requiring fill. In areas where fill is required, the subgrade shall be compacted to ninety-five (95) percent of the maximum dry density as determined by ASTM D698 for cohesive soils or seventy (70) percent relative density as determined by ASTM D4254 for non-cohesive soils.
6. Before placing any embankment, the surface of the existing ground shall be prepared and moistened as required, and the top 6 inches compacted to a density of 90 percent as prescribed by the following paragraph.
7. All embankment shall be compacted to a density of at least 90 percent of the maximum density for the material used as determined by ASTM D-698 and within a tolerance of minus three percent and plus two percent of the optimum moisture at maximum density as determined by the Moisture Density Curve obtained.
8. In-place density and moisture content of the embankment will be determined by either ASTM D1556, or by ASTM D2167, or by, ASTM D6938 as appropriate.

B. Subgrades:

1. City/Engineer will inspect all subgrades to determine conformance with indicated lines and grades.

SECTION 02200 - SITE PREPARATION AND EARTHWORK

2. Subgrades for roadways, drives, parking areas, and railroads shall have a maximum deviation of not more than ½ inch in any 10 feet when tested with a 10-foot straightedge applied parallel with and at right angles to the centerlines of sub grade areas, except that sub grades to receive aggregate-type surfacing shall have a maximum deviation of not more than 1 inch.

3.06 PROTECTION OF THE WORK

A. Maintenance:

1. Contractor shall protect newly graded and top soiled areas from actions of the elements.
2. Contractor shall fill and repair settling or erosion occurring prior to landscaping and shall re-establish grades to the required elevations and slopes.

B. Correction of Backfill Settlement:

1. Developer shall be responsible for correcting any settlement of backfill and damages created thereby within 1 year after acceptance of the Work by the City.
2. Developer shall make repairs within 10 calendar days from and after due notification by the City of backfill settlement and resulting damage.
3. Developer shall make own arrangements for access to the site for purposes of repair.

END OF SECTION 02200

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

PART 1 – GENERAL

1.01 SUMMARY

A. This Section includes:

1. Excavation, sheeting, bracing, and all operations necessary for the preparation of trenches for bedding of pipes and pipe appurtenances, conduit, and buried cable.
2. Pipe embedment and encasements.
3. Backfilling of trenches.

B. Related Work Specified Elsewhere:

1. Site Preparation and Earthwork: SECTION 02200.
2. Concrete: SECTION 03300.

C. See the related Standard Details in the Standard Drawing Details.

1.02 REFERENCES

A. Applicable Standards:

1. American Association of State Highway and Transportation Officials (AASHTO):
 - a. T104 - Soundness of Aggregate by Use of Sodium Sulfate or Magnesium Sulfate.
2. American Society for Testing and Materials (ASTM):
 - a. D4253 –Maximum Index Density and Unit Weight of Soils Using a Vibratory Table.
 - b. D4254 - Minimum Index Density and Unit Weight of Soils and Calculation of Relative Density.
3. Occupational Safety and Health Administration (OSHA):
 - a. Part 1926 - Safety and Health Regulations for Construction.
4. State of Missouri Standard Specifications for Highway Construction.

1.03 SUBMITTALS

A. Submit as specified in DIVISION 1.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

B. Includes, but not limited to, the following:

1. Steel reinforcement for concrete encasement.
2. Steel reinforcement for concrete cradle.
3. Concrete Submittals as specified in Section 03300.

C. Where selecting an option for excavation, trenching and shoring design from local, state, or federal safety regulations such as “OSHA Part 1926” or successor regulations, which request design by a registered professional engineer, the Contractor shall submit to the Engineer of Record (for information only and not for engineer approval) the following:

1. Copies of design calculations and notes for sloping, benching, support systems, shield systems, and other protective systems approved by a professional engineer registered in the State of Missouri and obtained by Contractor.
2. Documents provided with evidence of Registered Professional Engineer’s seal, signature, and date in accordance with appropriate State of Missouri licensing requirements.

PART 2 - PRODUCTS

2.01 GRANULAR PIPE EMBEDMENT

A. Material:

1. Coarse Aggregate No. 1 of the State of Missouri Standard Specifications for Highway Construction.
2. Gravel or crushed stone which shall not have a loss of more than 15% after five cycles when tested for soundness with sodium sulfate as described in AASHTO T104.

B. Gradation:

Percent Passing	Sieve Size
100	3/4-inch
60-100	1/2-inch
0-5	No. 4

2.02 EARTH PIPE EMBEDMENT FOR GROUNDWATER BARRIER

A. Barrier material shall be soil meeting classification GC, SL, CL, or ML-CL.

2.03 TRENCH BACKFILL MATERIALS

A. Obtain from the following:

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

1. Trenches and other excavations included in the Project.
 2. Borrow from location off jobsite.
 3. As specified for pipe embedment.
 4. Combination of above.
- B. Free from organic matter, refuse, ashes, cinders, frozen, or other unsuitable material.
- C. Gravel, rock, or shale particle size limited as follows:
1. Not to exceed 1 inch in greatest dimension within 12 inches of pipe or conduit and 2 inches in the upper 18 inches of trench.
 2. Maximum dimensions one-half the depth of layer to be compacted in other areas.
- D. Contain sufficient fine materials to provide a dense mass free of voids and capable of satisfactory compaction.
- E. Have moisture content enabling satisfactory placement and compaction.
- F. Blended or otherwise processed to provide required gradation and moisture content.
- G. Use granular material as specified for pipe embedment and trench stabilization unless otherwise indicated.

2.04 COMPACTED GRANULAR BACKFILL

- A. Compacted granular backfill may be flowable fill or graded gravel as described below:
1. Flowable fill for compacted backfill shall be used for cuts in existing roadways, as approved by the City.
 2. Gravel for compacted backfill shall conform to the following gradation.

<u>Percent Sieve Size</u>	<u>Passing by Weight</u>
1 inch	100
¾ inch	85-100
3/8 inch	50-80
No. 4	35-60
No. 40	15-30
No. 200	5-10

3. The gravel mixture shall contain no clay lumps or organic matter.
4. Other gradations may be submitted for approval to the City.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

2.05 ENCASEMENT OR CARRIER PIPE MATERIALS

A. Smooth Steel Pipe:

1. Smooth wall casing conduit pipe shall be of welded steel construction and shall be new material with a minimum yield of 35,000 psi.
2. Smooth wall casing pipe shall have a wall thickness as per details in the Standard Drawing Details.

B. Carrier Pipe Spacers:

1. Carrier pipe spacers shall be as per details in the Standard Drawing Details. The ends of the carrier pipe shall be sealed with end casing seals.

PART 3 - EXECUTION

3.01 TRENCHING

A. Equipment and Methods:

1. Types of Equipment and methods may be at Contractor's option, where structures or other facilities are not endangered.
2. Equipment and methods shall be subject to approval of jurisdictional agency where stability or usefulness of other facilities may be impaired.
3. Perform by hand methods when required to save or protect trees, culverts, utilities, or other structures above or below ground.
4. Ledge rock, boulders, and large stones shall be removed to provide a minimum clearance of four inches (4") below and on each side of all pipe(s) with an outside diameter of sixteen inches (16") and smaller when placed in a soil trench.
5. Maximum length of open trench shall be limited to 200 feet in advance and to 200 feet behind pipe installation, except as approved by City/Engineer.

B. Side Walls:

1. Make vertical within specified trench-width limitations below a horizontal plane 12 inches above top of pipe.
2. Vertical or sloped (stepped) as required for stability, above a horizontal plane 12 inches above top of pipe.
3. Sheet and brace where necessary. Comply with all safety requirements.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

4. Excavate without undercutting.

C. Trench Depth:

1. Depth shall be sufficient to provide the minimum bedding requirements for the pipe being placed.
2. Do not exceed the indicated depth where conditions of bottom are satisfactory.
3. Increase depth as necessary to remove unsuitable supporting materials.
4. Minimum depth of cover over top of pressure pipe is 42 inches.
5. Maximum depth of cover over top of pressure pipe shall be 60 inches. Justification shall be provided for review and approval where additional depth is required.

D. Trench Bottom:

1. Protect and maintain when suitable natural materials are encountered.
2. Remove rock fragments and materials disturbed during excavation or raveled from trench walls.
3. Restore to proper sub grade with trench-stabilization material when over excavated:
 - a. Correct when trench is over excavated without authority or to stabilize bottom rendered unsuitable through negligence or improper operations.
 - b. Placement of Trench Stabilization Material:
 - (1) Compact in lifts not exceeding 6-inch loose thickness:
 - (a) With pneumatic or vibratory equipment.
 - (b) To density specified for granular pipe embedment.

E. Trench Width:

1. Trenches shall be excavated to a width which will provide adequate working space and sidewall clearances for proper pipe installation, jointing, and embedment. Minimum trench widths shall be as per the Standard Drawing Details.
2. Specified minimum sidewall clearances are not minimum average clearance but are minimum clear distances which will be required from the pipe side wall to the trench excavation wall or the trench protective system.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

3. Cutting trench banks on slopes to reduce earth load to prevent sliding and caving shall be done only in areas where the increased trench width will not interfere with surface features or encroach on right-of-way limits
- F. Trenching in Fill Areas: Perform trenching in fill areas only after compacted fill has reached an elevation of not less than 1 foot above the top of the pipe.
- G. Cutting Concrete Surface Construction: Cuts in concrete pavement and concrete base pavements shall be no larger than necessary to provide adequate working space for proper installation of pipe and appurtenances. Cutting shall be started with a concrete saw in a manner which will provide a clean groove to the full depth of the pavement, along each side of the trench and along the perimeter of cuts for structures.
1. Concrete pavement and concrete base pavement over trenches excavated for pipelines shall be removed so that a shoulder not less than six inches in width at any point is left between the cut edge of the pavement and the top edge of the trench. Trench width at the bottom shall not be greater than at the top and no undercutting will be permitted. Pavement cuts shall be made to and between straight or accurately marked curved lines which, unless otherwise required, shall be parallel to the center line of the trench. See Standard Drawing Details.
 2. Pavement removal for connections to existing lines or structures shall not exceed the extent necessary for the installation.
 3. Where the trench parallels the length of concrete walks and the trench location is all or partially under the walk or bike path, the entire walk or bike path shall be removed and replaced. Where the trench crosses drives, walks or bike path, curbs, or other surface construction, the surface construction shall be removed and subsequently replaced between existing joints or between saw cuts as specified for pavement.

3.02 PIPE EMBEDMENTS AND ENCASEMENTS

- A. Class B bedding shall be used for all Polyvinyl Chloride (PVC) and Ductile Iron Pipe (DIP) pipelines. Class A arch encasement is not required unless improper trenching or unexpected trench conditions require its use. Concrete cradle and concrete encasement shall be provided where indicated as required.
- B. Granular Pipe Embedment:
1. Place granular embedment as follows:
 - a. Level bottom layer at proper grade to receive and uniformly support pipe barrel throughout its length.
 - b. Form depression under each joint so that no part of bell or coupling is in contact with trench when pipe is placed in position.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

- c. Add second layer simultaneously to both sides of the pipe with care to avoid displacement.
- d. Complete promptly after completion of jointing operations and City/Engineer approval to proceed.
- e. Substitute for any part of earth backfill to within 2 feet of final grade at Contractor's option.

2. Compact granular embedment as follows:

- a. In lifts not exceeding 6 inches in compacted depth.
- b. Rod, space, or use pneumatic or vibratory equipment:
 - (1) As required to obtain not less than 95% of the maximum density as determined by ASTM Method D4253 and D4254.
 - (2) Throughout depth of embedment.

3. See Standard Detail for Embedment of Pipe in the Standard Drawing Details.

C. Arch and Total Concrete Encasement:

- 1. Include in locations indicated or where approved by City/Engineer to correct over width trench condition.
- 2. Form to dimensions indicated or construct full width of trench.
- 3. Start and terminate encasement at a pipe joint:
 - a. Exclude joints from encasement:
 - (1) Applies only to joints at either end of encasement.
- 4. Install keyed construction joints coincident with pipe joints at 30- to 36-foot intervals. Provide separation of at least 75% of cross-section area at construction joints. Do not run horizontal steel through joint.
- 5. Suitably support and block pipe to maintain position and prevent flotation.
- 6. Place arch encasement promptly after installation of granular embedment.
- 7. Protect against damage from heavy equipment with layer of earth. Use hand methods to a horizontal plane 12 inches above top of encasement.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

D. Concrete Cradle:

1. Include in locations indicated and where designated by Engineer to reinforce unstable trench bottom.
2. Place on undisturbed trench bottom or on stabilized sub base.
3. Form to dimensions indicated or construct full width of trench.
4. Start and terminate concrete cradle at a pipe joint:
 - a. Exclude joints from cradle:
 - (1) Applies only to joints at either end of cradle.
5. Place without horizontal construction joints other than indicated.
6. Suitably support and block pipe to maintain position and prevent flotation.
7. Provide anchorage where indicated.

3.03 BACKFILLING

A. Placement:

1. All utilities shall be inspected and approved by the City prior to backfilling. A minimum of twenty-four hours' notice shall be provided for inspections.
2. Complete promptly after City/Engineer approval to proceed:
 - a. Upon completion of pipe embedment.
 - b. Only after concrete encasement has obtained 70% of design strength. Determination of design-strength percentage obtained shall be as specified in SECTION 03300.
3. Use hand methods to a horizontal plane 12 inches above top of pipe-barrel conduit or duct banks.
4. Use approved mechanical methods where hand backfill is not required.
5. Place in layers of thickness within compacting ability of equipment used.
6. Until compacted depth over conduit exceeds 3 feet, do not drop fill material over 5 feet. The distance may be increased 2 feet for each additional foot of cover. Backfill conduit trenches in layers of 4 to 8 inches.

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

7. Tracer wire shall be placed under all water and sewer mains and services. The tracer wire shall be properly grounded at all ends and at 500' maximum intervals.
8. Appropriate warning tape shall be placed 18" to 24" below finish grade at all water, sewer and force mains and services.
9. The top portion of backfill beneath established lawn areas shall be finished with at least twelve (12) inches of topsoil corresponding to, or better, than, that underlying adjoining lawn areas.

B. Compacted Granular Backfill:

1. Compacted granular and flow able backfill (Section 02222-2.04) shall be required for the full depth of the trench above the embedment and to within six inches of finish grade or to the base of pavements in the following locations, as approved by the City.
 - a. Where beneath pavements, driveways, curbs, parking lots, sidewalks.
 - b. Where in streets, roads, alleys or shoulders.
 - c. Where trench walls are within two feet of the back of the street curb.
 - d. When the trench for one pipe passes beneath the trench for another pipe, backfill for the lower trench shall be compacted to the level of the bottom of the upper trench."
2. The backfill shall be compacted by a suitable vibratory roller or platform vibrator to not less than 95 percent of the maximum density.

C. Temporary Street Repairs:

1. Reference is made to details in the Standard Drawing Details, specifying temporary trench backfill measures required within streets, roads, alleys or highway shoulders.

D. Uncompacted Backfill:

1. Compaction of trench backfill above pipe embedment in locations other than those specified will not be required except to the extent necessary to prevent future settlement. Uncompacted earth backfill material to be placed above embedments shall be free of brush, roots more than two inches in diameter, debris, or other corrosive material, but may contain rubble and detritus from rock excavation, stones and boulders, in certain portions of the trench depth. Uncompacted backfill material above embedments shall be placed by methods, acceptable to the Engineer, which will not impose excessive concentrated or unbalanced loads, shock, or impact on, and which will not result in displacement of, installed pipe. Compact masses of stiff clay or other consolidated material more than one cubic foot in volume shall not be permitted to fall more than five feet into the trench unless cushioned by at least two feet of loose backfill above pipe embedment. No uncompacted trench backfill material containing rocks, or rock excavation detritus, shall be placed in the upper

SECTION 02222 – TRENCHING AND BACKFILLING FOR UTILITIES

18 inches of the trench, nor shall any stone larger than eight inches in its greatest dimension be placed within three feet of the top of pipe. Large stones may be placed in the remainder of the trench backfill only if well separated and so arranged that no interference with backfill settlement will result.

3.04 TUNNEL EXCAVATION Pipelines shall be constructed in tunnels or bores in conformity with the following requirements.

A. Smooth Steel Casing Pipe:

1. Casing conduit shall be installed by jacking into place. Earth and/or rock displaced by The conduit shall be removed through the interior of the pipe by hand, auger or other Acceptable means.
2. Sections of the casing conduit in its final position shall be straight and true in alignment and grade as required by the drawings.
3. There shall be no void space between the earth and the outside of the casing.

B. Carrier Pipe Spacers:

1. Suitable thread lubricant shall be used on all stainless steel fasteners to prevent galling.
2. Maximum spacing of the spacers shall be as per Standard Drawing Details with a maximum distance from female end of joint of 12 inches.

C. End Seals:

1. Both ends of each casing conduit shall be sealed per manufacturer's recommendations.
2. End seal shall be secured to the casing and carrier pipes with all stainless steel worm gear clamps.
3. Lubricants approved by the end seal manufacturer maybe used to aid in installation of the end seal.

3.05 FIELD QUALITY CONTROL

- A. Concrete: Contractor shall test all concrete for use in encasements, cradles, and concrete cut-off walls to determine conformance with Specifications. Method of test shall be as specified in SECTION 03300.
- B. Contractor will, through services of an independent laboratory, test all granular bedding and backfill at intervals as required to verify conformance with specified density relationships. A copy of all test results shall be provided to the City/Engineer.

END OF SECTION 02222

SECTION 02512 – ASPHALTIC CONCRETE PAVEMENT

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes asphaltic concrete pavement for roads.
- B. Related Work Specified Elsewhere:
 - 1. Site Preparation and Earthwork: SECTION 02200.
- C. See Details in the Standard Drawing Details.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. Missouri Standard Specifications for Highway Construction.
 - a. Section 304 - Aggregate Base Course.
 - b. Section 401 - Plant Mix Bituminous Base and Pavement
 - c. Section 401.2.2 - Recycled Asphaltic Material
 - d. Section 403 - Asphalt Concrete Pavement.
 - e. Section 404 - Bituminous Mixing Plant.
 - f. Section 407 - Tack Coat.
 - g. Section 408 - Prime Coat.
 - 2. American Society for Testing and Materials, (ASTM);
 - a. D2950 – Density of Bituminous Concrete in Place by Nuclear Method.

1.03 SUBMITTALS

- A. Submit as specified in DIVISION 1.
- B. Mix Design:
 - 1. Contractor shall provide mix designs and a job mix formula for each mixture specified. Mix designs shall be accomplished by a qualified, independent, commercial testing laboratory.

SECTION 02512 – ASPHALTIC CONCRETE PAVEMENT

2. Furnish copies of the proposed job mix formula, including the laboratory test report, to City/Engineer for approval not less than 30 days prior to beginning production of paving mixture. Test reports shall indicate the following:
 - a. Gradation: Each component aggregate and combined aggregates.
 - b. Asphalt cement content in percent of total mix by weight.
 - c. Graphic plots of:
 - (1) Density versus asphalt content.
 - (2) Stability versus asphalt content.
 - (3) Percent voids total mix versus asphalt content.
 - (4) Flow versus asphalt content.
- C. Submit certificates accompanied by a copy of the refinery test report for bituminous materials for:
 1. Tack coat.
 2. Asphalt cement.
- D. Samples:
 1. Core or saw undamaged samples from the completed pavement courses.
 - a. Core samples shall be not less than 6-inch diameter and shall be full depth of the layer to be tested.
 - b. Take three sample from each day's production or from each 300 tons of mixture placed, whichever is the greater number of samples.
 - c. Deliver the samples to an independent laboratory for testing. Samples may be tested for density and extraction.
 2. Replace pavement at sample location with fresh bituminous mixture and thoroughly compact repaired area.

1.04 TESTING

- A. Completed pavement will be tested at the expense of the contractor to determine density, gradation, and asphalt content, (by extraction).

SECTION 02512 – ASPHALTIC CONCRETE PAVEMENT

1. Density shall be determined by the direct transmission nuclear method in accordance with ASTM D2950 or as specified in the Missouri Standard Specifications for Highway Construction.
 2. The mixture shall be tested at least once every 1000 tons of production or a minimum of once per day for the gradation, density, deleterious content and the asphalt content.
- B. Contractor shall perform such other tests as he deems necessary to assure production of asphaltic concrete conforming to specified quality.
- C. Contractor shall test surface smoothness by applying a 10-foot straightedge both parallel and at right angles to the centerline of paved areas:
1. Test at 50-foot (maximum) intervals, or more frequently when requested by the City.
 2. The City will observe straightedge testing.
 3. A properly calibrated rolling straightedge of the “Skorch” type may be used at the Contractor’s option.

1.05 TOLERANCES

- A. Density of completed pavement shall not be less than the following percentage of the density of the laboratory mix design:
1. All Lifts; 95% minimum.
- B. Smoothness shall be such that variation from a 10-foot straightedge does not exceed the following limits:
1. Final Lift of Base Course: 1/2-inch.
 2. Surface Course: 1/4-inch.

PART 2 - PRODUCTS

2.01 GENERAL

- A. Equipment and Materials shall conform to the requirements of Missouri Standard Specifications for Highway Construction.

2.02 MATERIAL

- A. Base Rock
1. Aggregate: Type 1 per the latest edition of MoDOT’s Standard Specifications for Highway Construction, Section 1007.

SECTION 02512 – ASPHALTIC CONCRETE PAVEMENT

B. Bituminous Material:

1. Asphalt Cement: Penetration grade 60 to 70 or 85 to 100.
2. Tack Coat: shall comply with the latest edition of MoDOT's Standard Specifications for Highway Construction, Section 407.
3. Any Prime Coat required shall comply with the latest edition of MoDOT's Standard Specifications for Highway Construction, Section 408.

C. Asphaltic Concrete Mixture:

1. Mixtures
 - a. Black Base Course: Section 401 Plant Mix Bituminous Base or Section 403 Asphaltic Concrete Pavement, Type SP190 or Type SP250, Missouri Standard Specifications for Highway Construction.
 - b. Surface Course: Section 401, Type BP-2 or Section 403, Type SP125, Missouri Standard Specifications for Highway Construction.

PART 3 - EXECUTION

3.01 GENERAL

- A. Performance shall conform to the requirements of Missouri Standard Specifications for Highway Construction, Sections 304, 401 and 403.
- B. Where a new street is to connect to an existing street, all deteriorated or cracked asphalt within five (5) feet of the connection point shall be removed to a point where sound material is found. If full-depth pavement removal is required, the subgrade will be recompact to 95% of standard density.

3.02 TACK COAT

- A. Apply tack coat to the surface of all existing pavement and all previously placed asphalted concrete lifts or courses before placing the succeeding lift.
- B. Apply at the following rates:
 1. Emulsion: Minimum 0.02 and maximum 0.10 gallon per square yard.
 2. Liquid Asphalt: 0.15 ± 0.05 gallon per square yard.

END OF SECTION 02512

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

PART 1 - GENERAL

1.01 SUMMARY

- A. This section includes concrete curbs, gutters, sidewalks, driveway approaches, and paved Drainage where indicated.
- B. Related Work Specified Elsewhere:
 - 1. Storm Drainage System: SECTION 02720
 - 2. Concrete: SECTION 03300.
- C. See related Details in the Standard Drawing Details.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Concrete Institute (ACI):
 - a. 305 - Hot-Weather Concreting.
 - b. 306 - Cold-Weather Concreting.
 - 2. American Society for Testing and Materials (ASTM):
 - a. A615 - Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
 - b. A616 - Rail-Steel Deformed and Plain Bars for Concrete Reinforcement.
 - c. C309 - Liquid Membrane-Forming Compounds for Curing Concrete.
 - d. D1751 - Preformed Expansion Joint Fillers for Concrete Paving and Structural Construction (Non-extruding and Resilient Bituminous Types).
 - e. D1752 - Preformed Sponge Rubber Cork and Recycled PVC Expansion Joint Fillers for Concrete Paving and Structural Construction.
 - f. D6690 - Joint and Crack Sealer, Hot-Applied, for Concrete and Asphalt Pavement.
 - 3. Federal Specifications (FS):
 - a. TT-S-00227 - Sealing Compound; Elastomeric Type, Multi Component. (For caulking, sealing, and glazing in buildings and other structures.)

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

1.03 WEATHER LIMITATIONS

- A. Concrete shall not be placed upon frozen subgrade. All concrete shall be effectively protected from freezing until a minimum compressive strength of 3000 psi has been attained. The contractor shall provide a method, meeting the approval of the Public Works Director, of monitoring the concrete that demonstrates that the concrete has been protected from freezing. Regardless of precautions taken, the contractor shall assume all risks, and all frozen concrete shall be replaced at the contractor's expense.
 - 1. Conform to ACI 306 when temperature is below 40°F within a 24-hour period after placement of concrete.
 - 2. Conform to ACI 305 when temperature is above 90°F, or is likely to rise above 90°F within a 24-hour period after placement of concrete.
- B. To protect against rain, the contractor shall have on location at all times material for the protection of the edges and surface of the unhardened concrete. The contractor shall protect the concrete from damage due to rain. Failure to properly protect unhardened concrete may constitute cause for the removal and replacement of defective concrete at the contractor's expense.

PART 2 - PRODUCTS

2.01 CONCRETE

- A. All curbs and gutters and sidewalks shall be constructed with 4,000 psi concrete as specified in SECTION 03300.
- B. Reinforcing steel as specified in SECTION 03200.
- C. Concrete slump reduced as necessary for slip-form construction, construction on steep slopes, and consolidation of concrete in curb back sections.

2.02 JOINT DOWELS

- A. Smooth round dowels having at least one-half the length of each dowel coated to ensure that no bond is developed between dowel and concrete.
- B. Conform to ASTM A615, Intermediate Grade or ASTM A616, Regular Grade.

2.03 DETECTABLE WARNING TILES

- A. Detectable warning Surfaces and their components shall be manufactured and/or supplied in a safety yellow color homogenous throughout the tile and matching the pattern shown in Standard Detail Drawings with a slip resistant surface, such as that manufactured by “Armor-Tile” or equal. The coloring shall be made an integral part of the detectable warning surface.

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

- B. Truncated domes shall have a diameter of 0.9 inches at the bottom, a diameter of 0.4 inches at the top, a height of 0.2 inches and a center to center spacing of 2.35 inches measured along diagonal of a square alignment.

2.04 EXPANSION JOINT FILLER

- A. Preformed material cut and shaped to the required cross-section.
- B. Thickness of ½ inch unless otherwise indicated.
- C. Conform to ASTM D1751 for all expansion joints except for those in sidewalks.
- D. Conform to ASTM D1752, Type II or Type III, for expansion joints in sidewalks.

2.05 JOINT SEALER

- A. Conform to ASTM D6690 for all joints required to be sealed except those in sidewalks.
- B. For Expansion Joints in Sidewalks:
 - 1. Conform to FS TT-S-00227.
 - 2. Non-tracking after initial cure.
 - 3. Two-component, cold-applied.
 - 4. Compatible with preformed expansion joint filler.
 - 5. Black or gray color.

2.06 CURING COMPOUND Conform to ASTM C309, Type I or Type I-D.

2.07 FORMS

- A. Wood or metal.
- B. Straight and strong enough to resist springing during placement of concrete.
- C. Sufficient bearing surface to prevent tipping.
- D. Height equal to full depth of section to be constructed.

2.08 SLIP-FORM MACHINE

- A. Designed to produce finished concrete items true to line, grade, and cross section.

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

- B. Designed to extrude and compact concrete by means of extrusion form accurately shaped to the required cross-section.
- C. Line and grade controlled automatically from erected taut wire or string line.
- D. Equipped with trailing side form when necessary to support material behind the extrusion plate.
- E. Equipped with finishing devices to produce type of finish specified.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Sub grade preparation is as specified in SECTION 02200.

3.02 INSTALLATION

A. Forms:

- 1. Use flexible forms for all curved form lines except:
 - a. Curves having a radius of 200 feet or greater may be formed in 10-foot or shorter chords.
 - b. Curves having a radius of 100 feet to 200' may be formed in 5-foot or shorter chords.
- 2. Thoroughly clean oil, securely stake, brace, and hold forms to line and grade.
- 3. Remove forms from front face of curb section at the time necessary to permit finishing concrete. Leave other forms in place not less than 12 hours after placement of concrete.

B. Joints:

- 1. Contraction Joints:
 - a. Construct at locations indicated and as follows:
 - (1) Divide concrete curb, curb and gutter, driveway approaches, and paved drainage into monolithic sections not greater than 15 feet in length.
 - (2) Match contraction joint spacing of adjacent Portland cement concrete pavement.
 - (3) Divide sidewalks into approximately square areas.
 - b. Form contraction joints by the following methods:

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

- (1) Cut a groove in the fresh concrete to a depth of at least one-fourth the section thickness by use of a jointer having a radius of 1/8 inch and thickness not exceeding 1/8 inch.
 - (2) Saw the hardened concrete before shrinkage cracking occurs. Depth of cut shall not be less than 1/4 the section thickness and width of key shall not exceed 3/16-inch.
2. Expansion Joints:
 - a. Construct at the following locations:
 - (1) Locations as indicated.
 - (2) All points of curvature and points of tangency of curves having a radius of 100 feet or less, and at intervals not exceeding 50 feet in tangent sections for hand laid sidewalks and not more than 100 feet for machine laid sidewalks.
 - (3) Locations matching expansion joint spacing of adjacent Portland cement concrete pavement.
 - (4) Locations where curb, curb and gutter, sidewalk, driveway approaches, or paved drainage abut each other or other structures and slabs.
 - b. Stake, support, and secure local transfer dowels and preformed joint filler in position to prevent displacement during placing and finishing operations.
 - c. Round edges of joints with an edging tool of 1/8 inch radius.
3. Key Joints: Construct at locations indicated for paved drainage and curb and gutter adjacent to Portland cement concrete pavement.
4. Construction Joints:
 - a. Locate to coincide with contraction, expansion, or key joints.
 - b. When concrete placement is interrupted between joint locations for a sufficient time for the concrete to take its initial set, remove concrete to the nearest joint location before resuming placement.
 - c. Make transverse construction joints in paved drainage having a thickness of 6 inches or greater by either key joints or expansion joints.

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

C. Concrete:

1. Placing Concrete:

- a. Place only on compacted and City/Engineer approved sub grade and base. All sub-grade and base shall be inspected and approved by the City prior to placing concrete.
- b. Lightly moisten surface of dry sub grade before placing concrete.
- c. Place concrete in manner to avoid displacement of forms and joint materials.
- d. Tamp or vibrate concrete sufficiently to eliminate all voids and bring the mortar to the top for finishing.

2. Finishing Concrete:

- a. Edge concrete with proper edging tools.
- b. Tool radii as soon as possible after concrete has taken its initial set.
- c. Remove curb face forms and rub with rubbing block and water until all blemishes, forms, and tool marks have been removed.
- d. Float-finish with wood float or other approved means until concrete is true to line, grade, and cross section, and is uniform in texture.
- e. Brush with a hard bristle broom as follows:
 - (1) Curb and curb and gutter parallel to the line of curb.
 - (2) Sidewalk perpendicular to its longitudinal axis.
- f. Do not use mortar topping or sand and cement dryer.

D. Tolerances:

1. Applies to conventional and slip-form construction.
2. Alignment deviation of finished concrete Work not to exceed ¼ inch in 10 feet from true line and grade.

3.03 SLIP-FORM CONSTRUCTION

- A. Prepare sub grade to a sufficient additional width as necessary to provide support and tracking for the slip-form machine.

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

- B. Adjust slump (reduce) and control concrete mix as necessary to provide satisfactory slip form construction.
- C. Use supplementary hand-finishing operation when necessary to produce uniform finishes free from blemishes and of the types and textures specified.

3.04 CONCRETE CURING AND PROTECTION

- A. Curing:
 - 1. Spray all exposed surfaces after finishing with curing compound.
 - 2. Apply curing compound at a rate of not less than 1 gallon per 225 square feet of surface area.
 - 3. Apply second coat at a rate of not less than 1 gallon per 275 square feet 30 minutes after first-coat application when the atmospheric temperature exceeds 100°F.
- B. Protection
 - 1. Protect the finished Work from damage until final acceptance.
 - 2. Repair, replace, or clean all concrete damaged or discolored prior to final acceptance.

3.05 SEALING JOINTS

- A. Seal all expansion joints and contraction joints ¼ inch or greater in width.
- B. Do not seal portions of expansion joints located in vertical parts of curbs.
- C. Remove curing compound and other material from joint surfaces before sealing. Joint shall be clean and surface dry at time of sealant application.
- D. Apply joint sealant using methods and equipment necessary to ensure complete filling of the joint space without voids or air bubbles.
- E. Apply sealant to conform to sealant manufacturer's instructions.
- F. Fill each joint with sealer from 1/8" below to level with adjacent concrete surface.
- G. Protect adjacent surfaces to prevent contamination with sealant material.
- H. Protect sealant until it has set up or cured sufficiently to preclude pickup or tracking.

SECTION 02525 – CURBS, GUTTERS, SIDEWALKS, DRIVEWAY APPROACHES, AND PAVED DRAINAGE

3.06 DETECTABLE WARNING SURFACES

- A. Detectable warning surfaces consisting of truncated domes aligned in a square grid pattern shall be provided where a curb ramp or landing connects to a crosswalk.
- B. The detectable warning surfaces shall be located so that the nearest edge is between 6 and 8 inches from the back of the curb line and shall extend a minimum of 24 inches in the direction of travel and the full width of the curb ramp, normally 5 feet.
- C. There shall be a minimum of 70 percent contrast in light reflectance between the detectable warning and the adjoining surface.
- D. See Standard Drawing Details.

END OF SECTION 02525

SECTION 02605 – MANHOLES, WET WELLS AND GREASE INTERCEPTORS

PART I - GENERAL

1.01 SUMMARY

- A. This Section includes the following structures and related appurtenances:
 - 1. Manholes. (Sewer lamp holes are prohibited).
 - 2. Pumping station wet wells.
- B. Related Work Specified Elsewhere:
 - 1. Concrete: SECTION 03300.
 - 2. Submersible Wastewater Pumping Station: SECTION 11151.
- C. See Details in the Standard Drawing Details.
- D. Submittals; Drawings and data covering precast concrete sections and castings shall be submitted in accordance with the submittal section.
- E. Delivery and Handling; Precast concrete sections shall not be delivered to the job until representative concrete control cylinders have attained a strength of at least 80 percent of the specified minimum.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Society for Testing and Materials (ASTM):
 - a. A48 - Gray Iron Castings.
 - b. C76 - Reinforced Concrete Culvert, Storm Drain and Sewer Pipe.
 - c. C443 - Joints for Concrete Pipe and Manholes, Using Rubber Gaskets.
 - d. C478 – Circular Precast Reinforced Concrete Manhole Sections.
 - e. C497- Standard Test Methods for Concrete Pipe, Manhole Sections or Tile
 - f. D3575 – Flexible Cellular Materials Made from Olefin Polymers
 - 2. Federal Specifications, (FS):
 - a. SS-S-00210 – Sealing Compound, Preformed Plastic, for Expansion Joints and pipe joints.

SECTION 02605 – MANHOLES, WET WELLS AND GREASE INTERCEPTORS

PART 2 – PRODUCTS

2.01 MATERIALS

- A. Concrete: Reinforced, 4000 psi. Conform to SECTION 03300.
- B. Castings:
 - 1. Manhole frames and covers.
 - a. ASTM A48, Class 30B, pattern as specified for each structure under PART 3, this Section.
 - b. Interchangeable within same pattern.
 - 2. Conform to drawings in all essentials of design. Weight shall be within 10 percent of that listed for pattern.
 - 3. Machine-bearing surfaces to provide even seating.
 - 4. Coat with Blackhawk Liquid Asphalt or equal.
- C. Gasket material shall meet FS SS-S-OO210 and be K.T. Snyder “Ram-Nek” or equal.
- D. Grade adjustment rings shall be manufactured from Expanded Polypropylene, (EPP), meeting D-3575. The rings shall be manufactured by a high compression molding process producing a finished density of 7.5 pcf or greater. The rings shall be ARPRO or equal. Concrete adjustment rings are not permitted.

PART 3 - EXECUTION

3.01 MANHOLES

- A. The flow-line angle for manholes shall not be less than 90 degrees. Manholes shall be installed at the end of each line; at all changes in grade, size, or alignment; at all line intersections; and at a distance not greater than four hundred (400) feet for sewers fifteen (15) inches or less in diameter and not greater than five hundred (500) feet for larger sewers. Manholes shall have eccentric cone unless otherwise approved by the City. Construction shall conform to the following and details in the Standard Drawing Details:
 - 1. Manholes shall either be precast manholes with cast-in-place base or precast concrete base or cast-in-place reinforced concrete manholes.
 - a. Precast manholes shall conform to ASTM C478 and C497.
 - b. Minimum wall thickness equal to 1/12 of inside diameter plus one inch.

SECTION 02605 – MANHOLES, WET WELLS AND GREASE INTERCEPTORS

- c. Precast cone section shall be eccentric.
- d. Precast manholes shall be provided with mastic gasket to seal joints between sections.
- e. Drop connections for precast manholes shall not enter the manhole at a joint.
2. Submit compliance submittal for precast and cast-in-place reinforced concrete manholes prior to installation.
3. Repair any leaks or remove entire work and rebuild to obtain watertight construction. Any repair method must be approved by the City.

B. Manhole Frames and Lids:

1. Type A and Type C frames and lids shall be suitable for traffic areas.
2. Type B frames and lids shall be suitable for non-traffic areas and shall be installed in areas where type A and C frames and lids are not specified.
3. Type C frame and lid shall be bolt-down type. Type C lids shall be installed in all areas subject to flooding and as determined by the Public Works Director.
4. All frames should be set so that top of lid is two inches, (maximum), higher than finish grade, matching improved surfaces as per Design Standards or as directed by the City. If at any time, the finish grade is adjusted or top soil or sod is added, then the frame/lid shall be readjusted to the new grade by the individual responsible for the change in grade. The adjusted manhole may require retesting for leakage as per Section 02620.
5. Type C frames and lids shall be bolted to each manhole by four anchor bolts. Bolt holes shall be located 90 degrees apart.
6. Type A, B and C frames and lids shall be anchored to the manhole by mastic gasket material.

C. Connections:

1. Install all piping using an “A-Lok” flexible rubber entrance hole gasket joint.
2. Provide stub outs, located to provide appropriate drop through manhole, for future connections where indicated.
3. Place pipe stub in manhole wall with bell or coupling outside manhole wall to provide flexible joint. Stubs shall not be less than 3’-0” nor more than 5’-0”.
4. Include plug or stopper capable of withstanding 10 feet (4.3 psi) internal or external pressure without leakage for future connections.

SECTION 02605 – MANHOLES, WET WELLS AND GREASE INTERCEPTORS

5. Connections of new pipe to existing structure shall be made with an “A-Lok” flexible connector. A-Lok connection shall be installed in strict conformance with manufacturer’s recommendations.

D. Manhole Base:

1. Form invert channel with 4000 psi Type II Portland cement concrete.
2. Make changes in direction of flow with smooth curves of as large a radius as size of manhole permits.
3. Make changes in size and grade smoothly and uniformly.
4. Slope floor of manhole adjacent to channels as indicated in Standard Details.
5. Finish channel bottom smoothly without roughness, irregularity or pockets.
6. The minimum drop of invert from inlet to outlet shall be 0.2’ inlet to outlet in standard and shallow manholes. The maximum drop shall be 2.0’.
7. If cast-in-place concrete bases are used, concrete shall be placed on undisturbed earth in accordance with applicable requirements of the concrete specification section.
8. If precast concrete bases are used, the subgrade materials shall be excavated to undisturbed earth and to a uniform elevation which will permit at least 4 inches of granular embedment material, as specified in the earthwork specification section, to be installed and compacted. The surface of the granular material shall be carefully graded and the base section accurately set so that connecting pipes will be on proper line and grade. The elevation of the granular material shall be adjusted as required until proper grade and alignment of the base section has been attained.
9. No wedging or blocking under precast concrete bases will be permitted.
10. In no case shall the invert section through a manhole be greater than that of the outgoing pipe. The shape of the invert shall conform exactly to the lower half of the pipe it connects.

E. Waterproofing:

1. Apply 1 coat of **Blackhawk Liquid Asphalt** coating to exterior walls, including bottom of the base, on all manholes from base to finish grade.
2. No grouting shall be permitted on manholes and rings except lift holes shall be grouted.

- F. Corrosion Protection for Manholes: Where corrosive conditions due to septicity or other causes are anticipated, corrosion protection as approved by the Public Works Director shall be provided on the interior of the manholes. Corrosive conditions are considered to be present where sewer mains are 12” or larger in size or where discharge is occurring from a force main.

SECTION 02605 – MANHOLES, WET WELLS AND GREASE INTERCEPTORS

Where discharge is from a force main an additional two manholes downstream shall be lined. The interior protection shall be epoxy made up of a minimum of 90% solids. A concrete admixture of “Con-Shield” or equivalent may be substituted for epoxy lining.

3.02 PUMPING STATION WET WELLS

- A. Design: Construct wet wells of reinforced concrete pipe conforming to ASTM C76, Class III.
 - 1. Minimum inside diameter 72 inches.
 - 2. Minimum wall thickness equal to 1/12 of inside diameter plus one inch.
 - 3. Submit compliance submittal for wet wells prior to installation.
- B. Joints: Conforming to ASTM C443.
- C. Top:
 - 1. Provide 6' minimum diameter reinforced concrete wet well top with opening for wet well mounted pumping station or with embedded access hatch for submersible pumping stations.
 - 2. Aluminum access hatches shall be furnished and installed where indicated on the drawings and as specified herein. Access hatches shall be of the size indicated on the drawings and shall be manufactured by Bilco Company, Halliday Products, or equal.
- D. Bottom:
 - 1. Provide 6' minimum diameter reinforced concrete bottom.
 - 2. Provide six inches of compacted granular fill beneath bottom.
 - 3. Provide concrete fill, on 1:1 slope, at bottom of wet well to form wet well bottom sump.
 - 4. The placement of the wet well bottom shall conform to the same requirements as indicated in Section 3.01.D.7, 8, and 9; and the applicable sections located in the concrete specification section.”
- E. Connections:
 - 1. Install all piping using an “A-Lok” flexible rubber entrance hole gasket joint.
 - 2. Place pipe stub in wet well wall with bell or coupling outside wet well wall to provide flexible joint.
- F. Waterproofing: Apply exterior waterproofing as specified for Manholes in this Section.

SECTION 02605 – MANHOLES, WET WELLS AND GREASE INTERCEPTORS

3.03 GREASE INTERCEPTORS

- A. Grease interceptors shall be provided on kitchen drain lines from institutions, hotels, restaurants, school lunch rooms, nursing homes and facilities, and other establishments from which significant amounts of grease may be discharged to the treatment facility.
- B. Grease interceptors should be located as close to the fixtures being served as possible and should receive only the waste streams from grease-producing fixtures. Sanitary waste streams, garbage grinder waste streams and other waste streams which do not include grease should be excluded from passing through the grease interceptors. This separation is mandatory for new construction or replacement facilities
- C. Grease interceptors shall be provided with a manhole or opening of sufficient size to permit inspection and cleaning. When the grease interceptors are located below ground, the access opening shall be extended to grade. The opening shall be fitted with a tight-fitting cover which will prevent the entrance of insects and vermin.
- D. The grease interceptor should be constructed of materials similar to septic tanks and be properly baffled on both the inlet and outlet. See details in Standard Drawing Details.
- E. A sampling manhole shall be provided at the outlet of the grease interceptor.

END OF SECTION 02605

SECTION 02610 – SANITARY SEWER PIPE

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes all gravity sanitary sewer pipe, fittings and specials.
- B. Related Work Specified Elsewhere:
 - 1. Trenching and Backfilling for Utilities; SECTION 02222.
 - 2. Pipe Installation and Testing: SECTION 02620.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Society for Testing and Materials (ASTM):
 - a. A746 - Ductile Iron Gravity Sewer Pipe.
 - b. D1784 - Rigid Poly, (Vinyl Chloride) (PVC) Compounds and Chlorinated Poly (Vinyl Chloride) (CPVC) Compounds.
 - c. ASTM D2321 - Standard Practice for Underground Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications
 - d. D2412 - Determination of External Loading Characteristics of Plastic Pipe by Parallel-Plate Loading.
 - e. D2680 - Standard Specification for Acrylonitrile-Butadiene-Styrene (ABS) and Poly Vinyl Chloride (PVC) Composite Sewer Piping
 - f. D3034 –PSM Polyvinyl Chloride Sewer Pipe and Fittings.
 - g. D3212 – Joints for Drain and Sewer Plastic Pipes Using Flexible Elastomeric Seals
 - h. F477 - Elastomeric Seals, (Gaskets) for Joining Plastic Pipe.
 - 2. American Water Works Association (AWWA):
 - a. C110 - Ductile-Iron and Gray-Iron Fittings.
 - b. C111 - Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
 - c. C104/A21.4 – Cement-Mortar Lining for Ductile-Iron Pipe and Fittings.

SECTION 02610 – SANITARY SEWER PIPE

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.
- B. Submit the following for acceptance prior to fabrication:
 - 1. Pipe and joint details.
 - 2. Special, fitting and coupling details.
 - 3. Laying and installation schedule.
 - 4. Manufacturer's design calculations.
- C. Certificates and Affidavits:
 - 1. Submit as specified in accordance with the submittal section.
 - 2. Furnish the following prior to shipment:
 - a. Affidavit of compliance with applicable standard.
 - b. Test certificates.

1.04 QUALITY ASSURANCE

- A. Manufacturer:
 - 1. Experienced in the design, manufacture and commercial supplying of the specific material for a minimum period of five years.
 - 2. Experienced in the design, manufacture, and commercial supplying of the specific size of pipe for a minimum period of one year.
 - 3. Certify to above minimum experience requirements.

PART 2 - PRODUCTS

2.01 PIPE REQUIREMENTS

- A. Furnish pipe of materials, joint types, sizes, and strength classes indicated or specified. Higher strengths may be furnished at Contractor's option. Furnish maximum pipe lengths produced by the manufacturer.
- B. Pipe shall be designed to withstand all stresses resulting from external loads including both earth load (120 lb/cu. ft.) and truck loads based on AASHTO H-20 truck (submit manufacturer's design calculations).

SECTION 02610 – SANITARY SEWER PIPE

- C. Pipe Bedding: As specified. Embedment materials for bedding, haunching and initial backfill, Class I, II or III as described in ASTM D2321, shall be used and carefully compacted for all flexible pipe provided the proper strength pipe is used with the specified bedding to support the anticipated load based on the type of soil encountered and potential groundwater conditions. Except as described in ASTM D2680, the bedding, haunching and initial backfill requirements for composite pipe shall be the same as for plastic pipe.
- D. Pipe Marking:
1. All pipe, fittings and specials shall be marked conforming to the applicable standard specification under which the pipe is manufactured and as otherwise specified.
- E. Pipe Gaskets: All elastomeric gaskets and seals shall be synthetic rubber.
- F. Length of Pipe: Furnish the maximum pipe lengths as manufactured by the manufacturer.

2.02 POLYVINYL CHLORIDE PIPE (PVC)

- A. Design and Manufacture of Pipe:
1. PVC Pipe shall conform to ASTM D 3034, SDR 35 with minimum 46 psi stiffness per ASTM D2412 rating for bury depths up to 10 feet.
 2. All materials used in the manufacture of pipe, fittings and accessories shall conform to ASTM D1784, Class 12454-B.
 3. PVC Pipe shall conform to ASTM D3034. SDR 21 with minimum 46 psi stiffness per ASTM D2412 rating for bury depths exceeding 10 feet.
 4. Tees shall be SDR-26 for SDR-35 mains and SDR-21 for SDR-21 mains. Sewer services shall be Schedule 40 PVC.
- B. Joints:
1. Provide push-on joints conforming to ASTM D3212 with elastomeric seals conforming to ASTM F477.
 2. Field cut joints and connections to other piping material shall be made with Can-Tex “C-T Adapters” with stainless steel bands or equal.

2.03 DUCTILE-IRON PIPE

- A. Design and Manufacture of Pipe:
1. Ductile iron gravity sewer pipe shall conform to ANSI A21.51, AWWA C151, ASTM A536, Grade 60-42-10; thickness Class 50, ASTM A746, Pressure Class 350.

SECTION 02610 – SANITARY SEWER PIPE

2. With laying condition Type 5.
3. Use E' of 700 and bedding angle of 150 degrees.
4. With a maximum 5 percent design deflection for trench load calculations.
5. Net calculated thickness shall include standard casting tolerances plus 0.08-inch additional service allowance.
6. Select special class thickness next above total calculated thickness.

B. Dimensions:

1. The minimum pressure class for ductile iron pipe shall be 350 psi.

C. Joints:

1. Provide push-on joints conforming to ANSI A21.11 and AWWA C111 except gasket shall be synthetic rubber. Natural rubber will not be acceptable.

D. Fittings:

1. Conform to AWWA C110 and be ductile iron.
2. Provide all specials, taps, and plugs as specified or indicated.

E. Lining:

1. Line all pipe, fittings and specials with cement lining conforming to ANSI A21.4. Clean interior to SSPC-5 quality and 1.5-2.5 mils profile depth. Lining is to extend from edge of plain end to the gasket seat in the bell socket.

F. Coating:

1. All pipe and fittings shall be coated with 1.5-2.5 mils of Bituminous Coating per Manufacturer's Standard unless otherwise required by the Public Works Director.

PART 3 – EXECUTION

3.01 **INSTALLATION** Specified in SECTION 02620.

3.02 **FIELD TESTING** Specified in SECTION 02620.

END OF SECTION 02610

SECTION 02615 - PRESSURE PIPE

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes all pressure pipe, fittings, specials and appurtenances.
- B. Related Work Specified Elsewhere:
 - 1. Trenching and Backfilling for Utilities; SECTION 02222.
 - 2. Pipe Installation and Testing: SECTION 02620.
 - 3. Valves, Hydrants and Accessories: SECTION 02640.
 - 4. Disinfection of Piping; SECTION 02675.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Water Works Association (AWWA):
 - a. C110 - Ductile-Iron and Gray-Iron Fittings.
 - b. C111 - Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
 - c. C150 - Thickness Design of Ductile-Iron Pipe.
 - d. C151 - Ductile-Iron Pipe, Centrifugally Cast
 - e. C900 - Polyvinyl Chloride (PVC) Pressure pipe and Fabricated Fittings, 4 inches through 12 inches for Water Transmission and Distribution.
 - f. C905 – Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings, 14 inches through 48 inches for Water Transmission and Distribution.
 - g. M23 – Manual, Pipe Design and Installation of PVC Pipe.
 - 2. American Society for Testing and Materials (ASTM):
 - a. D2241 - Polyvinyl Chloride (PVC) Pressure Rated Pipe, (SDR Series).
 - b. D2737 – Polyethylene (PE) Plastic Tubing.

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.

SECTION 02615 - PRESSURE PIPE

B. Submit the following for acceptance prior to fabrication:

1. Pipe and joint details.
2. Special, fitting and coupling details.
3. Laying and installation schedule.
4. Specifications, data sheets and affidavits of compliance for protective shop coatings and linings.
5. Manufacturer's design calculations.

C. Certificates and Affidavits: Furnish the Following Prior to Shipment:

1. Affidavit of compliance with applicable standard.
2. Test certificates.

1.04 QUALITY ASSURANCE

- A. Manufacturers shall be experienced in the design and manufacture of pipe, fittings, and specials or appurtenances for a minimum period of 5 years.

1.05 STORAGE AND HANDLING

- A. Pipe, fittings, and accessories shall be handled in accordance with Chapter 6 of the AWWA Manual M23, to ensure installation in sound, undamaged condition. Pipe shall not be stored in direct sunlight.

PART 2 - PRODUCTS

2.01 PIPE REQUIREMENTS

- A. Furnish pipe of materials, joint types and sizes as indicated or specified.
- B. Pipe Marking: All pipe and fittings shall be marked conforming to the applicable standard specification under which the pipe is manufactured and as otherwise specified.

2.02 DUCTILE-IRON PIPE

- A. Design and Manufacture of Pipe:
1. Ductile-iron pipe shall conform to AWWA C150 and C151 except as otherwise specified.
 2. With laying condition Type 5.

SECTION 02615 - PRESSURE PIPE

- a. Use E' of 700 and bedding angle of 150°.
 - b. 3% deflection limit.
 - c. Add service allowance and standard casting tolerances of AWWA C150.
 - d. Select standard pressure-class thickness or special thickness class next above total calculated thickness.
- B. Dimensions: The minimum thickness as defined by pressure class for mechanical or push on-type joint ductile iron pipe shall be 350 psi.
- C. Joints:
- 1. Push-On:
 - a. All pipes shall be provided with push-on joints unless otherwise noted.
 - 2. Restrained:
 - a. Provide restrained joint pipe where required.
 - b. Provide restrained joints of following approved types:
 - (1) Restrained mechanical joint.
 - (2) Restrained push-on joint.
 - (3) Boltless or bolted ball and socket joint.
 - (4) Anchored couplings.
 - c. Retainer glands shall be Megalug manufactured by EBAA Iron, Inc. or equal.
 - d. Fittings:
 - (1) Fittings shall be ductile iron and conform to AWWA C110 with a pressure rating of not less than that specified for pipe.
 - (2) Fittings for pipe with mechanical joints shall have mechanical joints.
 - (3) Fittings for pipe with push-on joints shall have mechanical joints.
 - (4) Include all specials, taps, plugs, flanges and wall fittings as required.
 - (5) Service line fittings shall be as follows:

SECTION 02615 - PRESSURE PIPE

(a) Saddles - Brass, A. Y. McDonald Model 3892 or equal.

(b) Curb Stops - Ball type, A. Y. McDonald Model 76101 or equal.

e. Lining:

(1) Line all pipe, fittings and specials with cement lining where full pipe flow is present. Lining shall extend from edge of plain end to the gasket seat in the bell socket.

f. Coating:

(1) All buried iron pipe and fittings shall be coated with manufacturer's standard bituminous coating.

2.03 POLYVINYL CHLORIDE PRESSURE PIPE

A. Design and Manufacture of Pipe:

1. PVC pipe shall conform to ASTM D2241, Pressure Class 200 with a thickness class of SDR 21.

B. Fittings:

1. Fittings shall be ductile iron and conform to AWWA C153.

2. Fittings shall be mechanical joint.

C. Joints:

1. Joints of PVC pipe to PVC pipe shall be push-on type and meet the requirements of ASTM D 2241.

2. Joints of PVC pipe to ductile iron shall meet the requirements of AWWA C111.

3. Gaskets shall be synthetic rubber. Natural rubber will not be acceptable.

D. Service Line:

1. A service connection shall be provided for each lot between the water main and the meter setter. The service line shall be a minimum 1-inch diameter 200 PSI, SDR-9 PE 3408, ASTM-D2737, CTS-OD pipe.

2.04 GASKETS

A. Provide all gaskets, bolts, lubricant, and other accessories required to install pipe, fitting and specials complete and ready for service.

SECTION 02615 - PRESSURE PIPE

PART 3 - EXECUTION

3.01 **INSTALLATION** Specified in SECTION 02620.

3.02 **FIELD TESTING** Specified in SECTION 02620.

END OF SECTION 02615.

SECTION 02620 - PIPE INSTALLATION AND TESTING

PART 1 - GENERAL

1.01 SUMMARY

A. This Section includes:

1. Handling, installation and testing of pipe, fittings, specials and appurtenances as indicated or specified.
2. Concrete anchor and thrust blocks.
3. Sewer service connections.
4. Water service connections, meters and related items.
5. Tracer wire and utility indicator tape.

B. Related Work Specified Elsewhere:

1. Manholes and Wet wells: SECTION 02605.
2. Sanitary Sewer Pipe: SECTION 02610.
3. Pressure Pipe: SECTION 02615.
4. Valves, Hydrants and Accessories: SECTION 02640.
5. Concrete: SECTION 03300.

C. See Details in the Standard Drawing Details.

1.02 REFERENCES

A. Applicable Standards:

1. American Water Works Association (AWWA):
 - a. C105 – Polyethylene Encasement for Ductile-Iron Pipe Systems
 - b. C600 - Installation of Ductile-Iron Water Mains and Their Appurtenances.
 - c. C605 – Underground Installation of Polyvinyl Chloride (PVC) and Molecularly Oriented Polyvinyl Chloride (PVCO) Pressure Pipe and Fittings.
2. American Standard Testing and Materials (ASTM):
 - a. C1244 - Standard Test Method for Concrete Sewer Manholes by the Negative Air

SECTION 02620 - PIPE INSTALLATION AND TESTING

Pressure, (Vacuum), Test Prior to Backfill.

- b. F1417 - Installation Acceptance of Plastic Non-pressure Sewer Lines Using Low Pressure Air.

1.03 DELIVERY, STORAGE AND HANDLING

- A. Handle in a manner to ensure installation in sound and undamaged condition.
 - 1. Do not drop or bump.
 - 2. Use slings, lifting lugs, hooks, and other devices designed to protect pipe, joint elements, linings and coatings.
- B. Ship, move, and store with provisions to prevent movement or shock contact with adjacent units.
- C. Handle with equipment capable of work with adequate factor of safety against overturning or other unsafe procedures.

PART 2 – PRODUCTS: Specified in respective Sections, except as included below.

2.01 TRACER WIRE

- A. General; All tracer wire shall have High Density Polyethylene, HDPE, insulation intended for direct bury and color coded per American Public Works Association, (APWA), standards for the utility being marked. See details in Standard Drawing Details.
- B. Tracer wire for open trench shall be a minimum 12 gauge, (AWG), insulated copper clad steel, (CCS), high strength, totally annealed 1055 steel, break load 452 lb. solid single strand conductive tracer wire. High Density Polyethylene, (HDPE), 30 mi minimum thickness jacket or coating shall be provided.
- C. Tracer wire for directional drilling/boring shall be a minimum 12 gauge, (AWG), insulated copper clad steel, (CCS), extra high strength, totally annealed 1055 steel, break load 1150 lb. solid single strand conductive tracer wire. High Density Polyethylene, (HDPE), 45 mi minimum thickness jacket or coating shall be provided.
- D. Tracer wire for pipe bursting shall be a minimum #2403" (AWG), insulated copper clad steel, (CCS), extra high strength, totally annealed 1055 steel, break load 4700 lb. tracer wire. High Density Polyethylene, (HDPE), 50 mi minimum thickness jacket or coating shall be provided.
- E. Grounding of tracer wire shall be achieved with a drive-in magnesium grounding anode rod, (Copperhead or approved equal), with a minimum of 20 feet of ground wire. Ground wire shall be #12 AVG insulated, (red), CCS solid single strand wire.
- F. All tracer wire installed with water service connections shall be accessible via water meter

SECTION 02620 - PIPE INSTALLATION AND TESTING

pits. No grounding anodes are required within water meter pits.

- G. Tracer wire shall be installed with all fire lines up to the exterior of the building. A grounding anode shall be placed at the building.
- H. Access boxes for tracer wire access points not corresponding to a valve or other structure shall be provided. Proper connectors such as Copperhead SnakeBite connectors or other moisture displacement connectors shall be used at all connections.

2.02 UNDERGROUND UTILITY MARKING TAPE

- A. Utility marking tape shall be 6" wide with appropriate wording and color-coded complying with American Public Works Association, (APWA), standards. Tape material shall be formulated from 100 percent virgin polyolefin resins. Resins shall be pigmental for chemical stability and resistance to sulfide staining (color fastness). Tape shall be constructed by the mechanical (non-adhesive) lamination of two plies of three layers blown film in such a manner as to produce a bi-axially oriented structure. The tape shall be able to provide a 700 percent elongation prior to rupture as per ASTM-D882.

PART 3 - EXECUTION

3.01 INSTALLATION – GENERAL

- A. Utilize equipment, methods, and materials ensuring installation to lines and grades indicated. Sewer mains shall be laid with uniform slope and straight alignment between manholes and alignment shall be checked by either a laser beam or lamping.
 - 1. Maintain within tolerances specified or acceptable laying schedule.
 - a. Alignment: ± 1 inch per 100 feet in open cut or tunnel.
 - b. Grade: ± 1 inch per 100 feet.
 - 2. Do not lay on blocks unless pipe is to receive total concrete encasement.
 - 3. Accomplish horizontal and vertical curve alignments with appropriate elbows and bends with adequate blocking. Alignment by deflection shall not be permitted.
 - 4. Obtain acceptance of method proposed for transfer of line and grade from control to the work.
- B. All water mains and sanitary sewer force mains shall have a minimum cover of 42" and a maximum cover of 60". Justification shall be provided where additional depth is required. Not less than 42" of cover shall be provided over top of gravity sanitary sewer mains in all areas unless otherwise approved by the Public Works Director. In areas where grading activities will take place, the water main shall not be installed until final grade has been achieved in the location of the proposed water main. The City shall not be responsible for

SECTION 02620 - PIPE INSTALLATION AND TESTING

required relocating or lowering of installed water mains due to insufficient pre-construction grading activities. No public water or gravity sewer main shall be constructed less than eight (8) inches in diameter.

- C. Sanitary sewer mains shall be constructed on the opposite sides of streets from water mains. Sanitary sewers mains and water mains shall be located within right-of-ways and easements to provide the least interference with the location of other utility lines unless topography dictates otherwise.
- D. There shall be no physical connection between a public or private potable water supply system and a sewer, or appurtenance thereto, which would permit the passage of any wastewater or polluted water into the potable water supply. No water main shall be located closer than 25 feet to any wastewater disposal facility, agricultural waste disposal facility, or landfill. Water mains shall be separated by a minimum of 25 feet from septic tanks and wastewater disposal areas such as cesspools, subsurface disposal fields, pit privies, land application fields, and seepage.
- E. Planting of trees within water and sanitary sewer main easements shall not be permitted.
- F. Open cutting of streets shall be permitted only where approved by the Public Works Director or appropriate Right-of-Way Manager. At locations where open cutting is not permitted, the street crossing shall be made by boring or tunneling. Crossings made by boring or tunneling shall require a casing pipe unless otherwise approved by the Public Works Director. The diameter and length of the casing pipe to be used shall be in accordance with details in the Standard Drawing Details.
- G. Install pipe of size, materials, strength class, and joint type with embedment indicated or specified for plan location. All PVC sewers over 10' deep shall be SDR-21, Class 200 pipe. SDR 35 may be used for depths less than 10 feet. Vitrified Clay sewer pipe is not permitted. Used pipes, fittings, and appurtenances are not permitted.
- H. Commence laying at downstream end of line and install pipe with bell ends in direction of laying. Obtain approval for deviations therefrom.
- I. Appropriate sewer main easements shall be extended to the property line for future potential extension. Manholes shall be placed at the ends of these mains with an invert formed for future connection. There shall also be a formed opening, gasket, 5' pipe stub and a pipe plug placed at the manhole invert for future connection.
- J. Clean interior of all pipe, fittings, and joints prior to installation. Exclude entrance of foreign matter during installation and at discontinuance of installation.
 - 1. Close open ends of pipe during any break in work, lunch, end of day, etc. Pipes shall be sealed with inflated rubber ball plugs.
 - 2. Do not let water control measures prove inadequate. The trench shall be kept free from water during pipe installation until the pipe has been installed, embedded and backfilled.

SECTION 02620 - PIPE INSTALLATION AND TESTING

3. Remove water, sand, mud and other undesirable materials from trench before removal of end seal.
- K. Brace or anchor as required to prevent displacement after establishing final position.
- L. Perform only when weather and trench conditions are suitable. Do not lay in water.
- M. Observe extra precaution when hazardous atmospheres might be encountered.
- N. Adequate support shall be provided at all joints in pipes utilized for aerial crossings. Only ductile-iron pipe with restrained joints shall be used unless otherwise approved by the Public Works Director.
- O. For stream crossings, construction methods that will minimize siltation and erosion shall be employed. Clean-up, grading, seeding, planting, or restoration of all work areas shall begin immediately. Exposed areas shall not remain unprotected for more than seven days.
- P. Cleanouts and lampholes are not permitted on sanitary sewer mains.
- Q. Construction of sidewalks longitudinally above sanitary sewers or water mains is not permitted. No sanitary sewer or water main shall be constructed under storm boxes.

3.02 STEEP SLOPE PROTECTION FOR SANITARY SEWER MAINS

- A. Steep slope protection. Sanitary sewers on twenty percent (20%) slope or greater shall be anchored securely with concrete slope anchors or equal, spaced as follows:
 1. Not over thirty-six feet (36') center-to center on grades twenty percent (20%) and up to thirty-five percent (35%);
 2. Not over twenty-four feet (24') center-to center on grades thirty-five percent (35%) and up to fifty percent (50%);
 3. Slopes shall not exceed fifty percent (50%).

3.03 JOINTING

- A. General Requirements:
 1. Locate joint to provide for differential movement at changes in type of pipe embedment, impervious trench checks and structures.
 2. Perform conforming to manufacturer's recommendations.
 3. Clean and lubricate all joint and gasket surfaces with lubricant recommended.
 4. Utilize methods and equipment capable of fully homing or making up joints without damage.

SECTION 02620 - PIPE INSTALLATION AND TESTING

5. Check joint opening and deflection for specification limits.
6. Mechanical joints shall be carefully assembled in accordance with the manufacturer's recommendations. If effective sealing is not obtained, the joint shall be disassembled, thoroughly cleaned, and reassembled. Over tightening of bolts to compensate for poor installation practice shall not be permitted.

B. Special Provisions for Jointing Ductile-Iron Pipe:

1. Conform to AWWA C600.
2. Visually examine while suspended and before lowering into trench.
 - a. Paint bell, spigot, or other suspected portions with turpentine and dust with cement to check for cracks invisible to the eye.
 - b. Remove turpentine and cement by washing when test is satisfactorily completed.

C. Polyethylene Encasement: All cast iron fittings, tapping sleeves, valves, or other cast iron accessories shall be provided with polyethylene tube or sheet protection installed in accordance with AWWA C105.

3.04 CUTTING

- A. Cut in neat manner without damage to pipe.
- B. Observe specifications regarding joint locations.
- C. Cut cast-iron, ductile-iron, and steel pipe with carborundum saw or other acceptable method per manufacturer's instructions.
 1. Smooth cut by power grinding to remove burrs and sharp edges.
 2. Repair lining as required and approved.
- D. Cut PVC pipe with a fine-toothed saw and mitre box or tube cutter. After cutting, the end of the pipe shall be dressed to remove all roughness and sharp corners and beveled in accordance with the manufacturer's instructions.

3.05 CLOSURE PIECES

- A. Connect two segments of pipeline or a pipeline segment and existing structures with short sections of pipe fabricated for the purpose.
- B. Observe Specifications regarding location of joints, type of joints, and pipe materials and strength classifications.

SECTION 02620 - PIPE INSTALLATION AND TESTING

- C. Field-fabricated closures, where required, shall be concrete encased between adjacent flexible joints.
- D. May be accomplished with solid sleeve.

3.06 TEMPORARY PLUGS

- A. Furnish and install temporary plugs at each end of work for removal by others when completed ahead of adjacent contract.
- B. Plugs:
 - 1. Test plugs as manufactured by pipe supplier.
 - 2. Fabricated by Contractor of substantial construction.
 - 3. Watertight against heads up to 20 feet of water, or 150% of test pressure, whichever is greater.
 - 4. Secured in place in a manner to facilitate removal when required to connect pipe.

3.07 SEWER SERVICE CONNECTIONS

- A. Install one sewer service connection, at locations indicated on the drawings, for future connection of building lateral to main sewer. Sewer service connections shall be provided for every lot and every structure and shall be centered in the lot frontage where feasible
- B. Sewer Service connections installed coincidentally with the main shall be gasketed "tees" or "wyes".
- C. Sewer Service connections installed sub-sequentially to the main shall be accomplished by saddle type fittings. The fitting shall be supported by flowable fill. The flowable fill shall completely encase the service fitting and main and extend to a minimum of one foot above the point of connection to the main. Granular pipe embedment shall be used for an additional one-foot lift.
- D. Install lateral to right-of-way, permanent easement or property line, reference details in the Standard Drawing Details. No split services (except for multi-family) or 90° turns are permitted. Service connections on the mains shall have a minimum of five (5) feet of separation and shall be located a minimum of five (5) feet from the exterior wall of a manhole.
- E. Clean outs shall be located not more than 100 feet apart measured from the upstream entrance of the cleanout. See the International Plumbing Code for services 8" in diameter and larger. No clean outs shall be located within public right-of-way except those required for the termination of the tracer wire.
- F. Provide a schedule 40 PVC cap at end of lateral line in accordance with details in Standard

SECTION 02620 - PIPE INSTALLATION AND TESTING

Drawing Details.

3.08 WATER SERVICE LINE

- A. Tapping sleeves and valves shall be used where required to connect to existing in-service water mains. Connections to existing water mains shall be made in such a manner as to provide the least amount of interruption to water service. In the event closing of valves to make a connection will affect a customer who cannot be without service, provision shall be made for a temporary service at the expense of the developer/applicant.
- B. All water meters shall be compound water meters. Turbine or 'turbo' meters are not permitted.
- C. All water services connecting to single setters are to be 3/4-inch diameter.
- D. All water meter boxes shall be a minimum of 24-inches in diameter.
- E. All water meters connecting to double setters are to be a minimum of 1-inch in diameter up to the U-Branch connection, and 3/4-inch in diameter from the U-branch to each meter loop.
- F. All water service connections 2-inches and larger shall include bypass lines and be installed in a 30-inch diameter meter pit and shall include a heavy-duty 2-piece aluminum lid.
- G. All water service connections 3-inches and larger shall be enclosed in concrete vaults with a heavy duty 2-piece aluminum lid with access panel door, and shall include a bypass line fitted with a 1-inch or larger bypass water meter.
- H. No meter pits shall be installed in traffic areas unless 4 or more steel bollards as a minimum are installed around the meter pit.
- I. SDR-9 PE 3408, ASTM-D2737, CTS-OD, 200 PSI roll tubing water service line shall be installed from the main line to the meter setter for each service connection. All service lines shall be bedded in conformance with Section 02222-3.02.
- J. For all new developments and all rehabilitations of existing water systems, SDR-9 PE 3408, ASTM-D2737, CTS-OD, 200 PSI roll tubing water service line shall be installed up to the meter and connected to the new or existing setter.
- K. Connect water service line to main line with brass saddle.
- L. Connect water line to saddle with corporation stop valve.
- M. Polypropylene lids are not permitted.
- N. Install meter box, lid and meter setter in accordance with details in the Standard Drawing Details.
- O. For both existing and new systems, each service connection shall be individually metered. Single family units, each unit of a townhome, duplex, triplex and four-plex shall normally be provided with separate water meters for each living unit unless otherwise approved by the City. Multi-family apartment units shall be provided with one water meter for the entire facility. Multi-unit apartment complexes shall be provided with one bulk meter for the entire complex. A separate commercial water meter shall be provided for each separate commercial unit.

SECTION 02620 - PIPE INSTALLATION AND TESTING

unless otherwise approved by the City. Irrigation systems may be provided with separate water meters.

- P. All water meter sizes shall be approved by the City prior to construction.
- Q. Per City of Ozark detail drawings, all water meters greater than a distance of 10 feet away from the mainline and all services which connect to water mains located under paved surfaces require a brass curb stop to be installed within the meter pit. In any situation where installation inside the meter pit is unfeasible, other means of surface access to the curb stop shall be required.
- R. All service saddles and corporation stops are to be installed on the main prior to pressure and leakage testing in conformance with Section 02620-3.14B.
- S. For all water meters requiring installation of a curb stop at the meter, the service connection shall be installed up to the curb stop prior to pressure and leakage testing. All connections are to be included in pressure testing in conformance with Section 02620-3.14B.

3.09 CONNECTIONS TO EXISTING STRUCTURES

- A. Connect pipe to existing structures and pipelines where indicated.
- B. Prepare structure by making an opening with at least 3 inches clearance all around fitting to be inserted or as indicated.
- C. Observe pertinent articles of Specifications pertaining to joint locations and closures.
- D. Repair wall opening with concrete or as indicated.
- E. Connections of new sanitary sewer pipe to existing manholes shall be made with a field cast A-Lok flexible connection.

3.010 TRACER WIRE

- A. A tracer wire shall be provided for all water and sewer mains and services. The tracer wire shall not be attached to the main or services but shall be placed in the bedding material under the pipe in the same orientation to all installed pipe. Tracer wire shall be installed in a manner that allows access for connection of the line tracing equipment, proper locating of wire without loss or deterioration of low frequency, (512Hz), signal for distances in excess of 500 linear feet and without distortion of signal caused by multiple wires being installed in close proximity to one another. The tracer wire shall be installed as a single continuous wire, except where using approved connectors. The tracer wire shall be extended to the surface at a maximum spacing of 500 feet. Access boxes for tracer wire access points shall be provided. Such an access box shall not be located within any driving or parking surface. Tracer wire shall be installed for all water service lines to the meter box and shall be connected to the water main's tracer wire. The tracer wire for the sewer service line shall be connected to the tracer wire at the sewer main and extended to a capped clean out. Proper connectors shall be used at all connections.

SECTION 02620 - PIPE INSTALLATION AND TESTING

Provide proper grounding at dead ends and at spacing not to exceed 500'. The grounding anode shall be buried at the same depth as the tracer wire. See details in Standard Drawing Details.

- B. Where existing tracer wire is encountered on an existing utility that is being extended or tied into, the new and existing tracer wire shall be connected using approved splice connectors, shall be properly grounded at the splice location as specified and be completely waterproof to prohibit corrosion and loss of conductivity.
- C. Any damage occurring during installation of the tracer wire must be immediately repaired in and approved waterproof method. Taping and/or spray coating shall not be allowed.
- D. The following products and methods shall not be allowed or acceptable:
 - 1. Uninsulated tracer wire.
 - 2. Tracer wire insulations other than HDPE.
 - 3. Twist-on wire connectors.
 - 4. Brass or copper ground rods.
 - 5. Wire connections utilizing taping or spray-on waterproofing.
 - 6. Looped wire or continuous wire installations, that has multiple wires laid side-by-side or in close proximity to one another.
 - 7. Brass fittings with tracer wire connection lugs.
 - 8. Wire terminations within the roadway, i.e. in valve boxes, cleanouts, manholes and etc.
 - 9. Connecting tracer wire to existing conductive utilities.

3.011 UNDERGROUND UTILITY MARKING TAPE

- A. Utility marking tape of appropriate color shall be provided 18" to 24" below finish grade at all water and sewer mains and services.
- B. At tees, tape ends, etc., the warning tape shall be tied together (spliced) with knot to create a continuous warning tape throughout the length of the pipeline and associated branch lines, appurtenances, etc.

3.012 CONCRETE ANCHOR AND THRUST BLOCKS

- A. Install at tees, elbows, bends, and dead ends where indicated. See details in Standard Drawing Details

SECTION 02620 - PIPE INSTALLATION AND TESTING

- B. Place against undisturbed earth or rock and install so that all joints are accessible for repair.
- C. Of design indicated or specified.
 - 1. Removable thrust blocks shall be constructed by utilizing a sheet of ¼-inch plywood to prevent concrete adherence to pipe, fittings or accessories.
 - 2. Apply two coats of coal tar coating to minimum 20 mils dry film thickness on anchor bars, straps and hardware.

3.013 SEPARATION OF WATER MAINS WITH SANITARY SEWERS

A. Horizontal Separation:

- 1. All sanitary sewers, storm sewers, or manholes shall be laid at least 10 feet, horizontally, from a water main. The distance shall be measured from edge to edge of pipes. In cases where it is not practical to maintain a ten-foot separation, deviation maybe allowed on a case-by-case basis, if supported by data from the design engineer. Such a deviation may allow installation of the sewer closer to a water main, provided that the water main is in a separate trench or on an undisturbed earth shelf located on one side of the sewer and at an elevation so the bottom of the water main is at least 18" above the top of the sewer. Where it is impossible to obtain separation as described, the sewer shall be constructed of slip-on or mechanical joint pipe or continuously encased and be pressure tested to 150 psi. to ensure water-tightness. A request for variance shall be submitted to the DNR Public Drinking Water Branch and the City for approval. This request shall include proposed alternate installation configuration.

B. Vertical Separation:

- 1. Water mains crossing sanitary sewers, house sewers, or storm sewers shall be constructed to provide a minimum clear distance of 18 inches between the outside of the water main and the outside of the sewer. This clearance is required whether the water main is above or below sewer pipes. At crossings, the full length of water pipe shall be located so that both joints will be as far from the sewer as possible but in no case less than 10 feet. Special structural support for the upper pipe may be required. In areas where the proper separation cannot be maintained as stipulated above, either the water main or sewer line must be constructed of mechanical joint pipe or cased in a continuous casing.

C. Special Conditions:

- 1. No waterline shall be located closer than 25 feet to any on-site disposal facility, agricultural waste facility or landfill.
- 2. Waterlines which cross surface waterways shall meet the requirements of Section 8.7 of MODNR "Design Guide for Community Water Systems". All appropriate construction parameters shall be included on the construction drawings.

SECTION 02620 - PIPE INSTALLATION AND TESTING

3.014 FIELD TESTING

A. Acceptance Tests for Gravity Sanitary Sewer:

1. General:

- a. All sewers shall be visually inspected, mandrelled and tested for infiltration and exfiltration.
- b. Exfiltration testing shall be achieved by a low-pressure air leakage test.
- c. The Contractor shall furnish all labor, equipment, tools and materials and shall perform all acceptance tests.
- d. All tests shall be witnessed and recorded by City Personnel. All testing after backfilling will be conducted by the contractor. The contractor shall provide a minimum of a 48-hour notice to the City prior to testing.
- e. In addition, the City may elect to camera test all sewer mains for defects, irregularities and compliance with design profile and specifications. The City may also elect to smoke test the entire sewer system.

2. Alignment:

- a. Sewer shall be inspected (lamped) by flashing a light between manholes or by physical passage where space permits. Each section of sewer line between manholes shall be straight and uniformly graded.
- b. Contractor shall clean pipe of excess mortar, joint sealant and other dirt and debris prior to inspection.
- c. Determine from Lamping or Physical Inspection:
 - (1) Presence of any misaligned, displaced, or broken pipe.
 - (2) Presence of visible infiltration or other defects.
- d. Correct defects as required prior to conducting leakage tests.

3. Leakage Tests: The leakage tests shall be performed on the full length of all sewer mains prior to acceptance.

- a. Air leakage testing. The Contractor shall perform low pressure air testing of the sewer mains for exfiltration testing. Air testing shall comply with ASTM F1417.
 - (1) The general testing procedure shall be as follows: Raise pressure to 4.0 psi in sections being tested, throttle the air supply to maintain between 4.0 and 3.5 psi for at

SECTION 02620 - PIPE INSTALLATION AND TESTING

least 2 minutes in order to allow equilibrium between air temperature and pipe walls to be obtained. After temperature has stabilized, allow the pressure to decrease to 3.5 psi. At 3.5 psi begin timing to determine the time required for pressure to drop to 2.5 psi. If the time for the air pressure to decrease from 3.5 to 2.5 psi is greater than that shown in the table below, the pipe shall be presumed free of defects.

Required Time for Length (min:sec)

Pipe Size (in.)	100 L.F.	200 L.F.	300 L.F.	400 L.F.
8	7:34	7:34	7:36	10:08
10	9:26	9:26	11:52	16:49
12	11:20	11:24	17:05	22:47
15	14:10	17:48	26:42	35:36
18	17:00	25:38	38:27	51:16
21	19:50	34:54	62:21	69:48

If air test fails to meet above requirements, repeat test as necessary after all leaks and defects have been repaired. In areas where ground water is known to exist, increase the test pressure by 0.43 psi for each foot of depth that the ground water is above the top of the pipe.

- b. **Manhole Testing:** The Contractor shall perform a vacuum exfiltration test on each manhole in accordance with ASTM C1244. Manholes shall be tested after completion of adjacent work to avoid disturbing the manhole. No manholes shall be raised after testing. Any manhole disturbed or raised shall be retesting. Vacuum testing equipment shall be as manufactured by Cherne Industries, P.A. Glazier, Inc. or approved equal. Vacuum testing shall be conducted following manhole construction, including connection to piping and setting of the lid and frame. No grout shall be placed in horizontal joints until manhole has passed the vacuum test. All lifting holes shall be grouted. Manholes which fail the test shall be reconstructed as required to adequately seal the manhole. Grouting of leak from the interior or exterior will not be acceptable. Plug all pipes entering manhole. Securely brace all plugs as required. Install testing lead in manhole frame and inflate seal in accordance with manufacturer's recommendation. A vacuum of 10 inches of mercury shall be drawn and the vacuum pump shut off. With all valves closed, measure the time required for the vacuum to drop to 9 inches of mercury. The manhole shall pass if the time is greater than 120 seconds for a 48-inch diameter manhole and 150 seconds for a 60-inch diameter manhole. If a manhole fails the test, perform necessary repairs and retest until an acceptable test meeting the above requirement is achieved.

4. Mandrel Testing:

- a. Mandrel testing shall not be conducted prior to 30 days after backfilling is complete.
- b. Each reach of PVC gravity sewer shall be checked for excessive deflection by pulling a mandrel through the pipe without a mechanical pulling device.

SECTION 02620 - PIPE INSTALLATION AND TESTING

- c. The mandrel should be rigid and have nine, (9) or more odd number of flutes or points.
 - d. Mandrel diameter shall not be less than 95 percent of the base inside diameter or average inside diameter of the pipe depending on which is specified in the ASTM specification, including the appendix, to which the pipe is manufactured.
 - e. Pipe with diametric deflection exceeding 5 percent shall be uncovered and the bedding and backfill replaced to prevent excessive deflection.
 - f. Repaired pipe shall be retested after repair.
 - g. Contractor shall submit all deflection test results to the City/Engineer.
5. All tracer wire installations shall be located using typical low frequency, (512Hz), line tracing equipment witnessed by the City prior to acceptance. Continuity testing in lieu of actual line tracing shall not be accepted.
6. After final grading, the City's representative will verify proper final grade at all manhole rims.

B. Acceptance Tests for Pressure Pipelines:

- 1. Perform hydrostatic pressure and leakage tests.
 - a. Conform to AWWA C600 procedures.
 - (1) As modified herein.
 - (2) Shall apply to all pipe materials specified.
 - b. Perform after backfilling.
- 2. Test separately in segments between sectionalizing valves, between a sectionalizing valve and a test plug, or between test plugs.
 - a. Select test segments such that adjustable seated valves are isolated for individual checking.
 - b. Contractor shall furnish and install test plugs.
 - (1) Including all anchors, braces, and other devices to withstand hydrostatic pressure on plugs. Bracing against structure walls isn't allowed.
 - (2) Be responsible for any damage to public or private property caused by failure of plugs.
- 3. Limit fill rate of line to available venting capacity. Fill rate shall be regulated to limit velocity

SECTION 02620 - PIPE INSTALLATION AND TESTING

in lines when flowing full to not more than 1 fps.

4. Contractor shall make arrangements with the City for water required for testing. There will be charges for flushing, sampling and testing.

5. Pressure and Leakage Test:

- a. Test pressure: The pipeline shall be subjected to not less than 150 psi of pressure for the duration of the test.
- b. Be at least 2-hour duration or longer if necessary for the City to inspect the pipeline. Maintain pressure throughout test ± 5 psi of test pressure.
- c. Leakage test shall be conducted concurrently with the pressure test.
- d. Acceptable when leakage does not exceed that determined by the following formula:

$Q = 0.0075 \text{ DLN}$ = maximum permissible leakage in gallons per Hour

L = length of pipe tested in thousand feet

D = nominal internal diameter of pipe being tested in inches

N = square root of the average test pressure in Psig

- e. When testing against closed metal-seated valves, an additional leakage per closed valve of 0.0078 gal/hr./in of nominal valve size shall be allowed.
- f. When hydrants are in the test section, the test shall be made against the closed hydrant.
- g. All fire lines shall be subjected to a test pressure of not less than 200 psi and maintain said pressure with ± 0 psi of deviation for a duration of 2 hours.
- h. All water service connection lines are to be installed up to the farthest corporation stop valve prior to pressure and leakage testing. Brass saddles and all other components of the water service up to the farthest corporation stop are to be included in pressure and leakage test. For water meters requiring a brass curb stop at the meter pit per Section 02620-3.8, all components up to the curb stop shall be included in pressure and leakage testing.
- i. Repeat test as necessary.
 - (1) After location of leaks and repair or replacement of defective joints, pipe, fittings, valves or hydrants. All visible leaks are to be repaired regardless of the amount of leakage.
 - (2) Until satisfactory performance of test.

SECTION 02620 - PIPE INSTALLATION AND TESTING

- j. The City Representative shall witness pressure and leakage test. The contractor shall provide a minimum of a 48-hour notice to the City prior to testing.

END OF SECTION 02620

SECTION 02640 - VALVES, HYDRANTS AND ACCESSORIES

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes all valves and accessories.
- B. Related Work Specified Elsewhere:
 - 1. Pipe Installation and Testing: SECTION 02620.
- C. See Details in the Standard Drawing Details.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Water Works Association (AWWA):
 - a. C111-Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
 - b. C502 - Dry Barrel Fire Hydrants.
 - c. C515 – Resilient Seated Gate Valves for Water Supply Service
 - d. C600 – Installation of Ductile Iron Water Mains and Their Appurtenances.
 - 2. American National Standards Institute.
 - a. B16 Standards for Pipes and Fittings.

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.
- B. Include, but not limited to, the following:
 - 1. Catalog data or illustrations showing principal dimensions, parts and materials.
 - 2. Spare parts list referenced to illustration of parts.
 - 3. Assembly and disassembly or repair instructions.
- C. Certificates and Affidavits: Furnish prior to shipment. Include the following:
 - 1. Test certificates.
 - 2. Affidavit of compliance with applicable AWWA Standard.

SECTION 02640 - VALVES, HYDRANTS AND ACCESSORIES

1.04 QUALITY ASSURANCE

- A. Manufacturers shall be experienced in the design and manufacture of specific valves and accessories for a minimum period of 5 years.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Ship all valves with suitable end covers to prevent entrance of foreign material into valve body.
- B. Protect valves from damage.

1.06 WRENCH NUTS

- A. Wrench nuts shall be provided on all buried valves.
- B. All wrench nuts shall comply with Section 3.16 of AWWA C500.
- C. Contractor shall provide two operating keys (T-bars) for operation of the wrench nuts.

1.07 ROTATION

- A. Direction of rotation of the wrench nut to open the valve shall be to the left (counterclockwise).
- B. Each valve body shall have cast thereon the word "OPEN" and an arrow indicating the direction to open.

1.08 ENDS

- A. All 3-inch or larger buried valves shall have mechanical joint ends unless otherwise specified.
- B. All 2-1/2 inch or smaller valves shall have threaded ends.
- C. Mechanical joints shall conform to AWWA C 111.

PART 2 - PRODUCTS

2.01 GATE VALVES

- A. Acceptable Manufacturers:
 - 1. Clow Corporation.
 - 2. Mueller.

SECTION 02640 - VALVES, HYDRANTS AND ACCESSORIES

- 3. Keystone Valve USA, Inc.
- B. All gate valves shall conform to AWWA C515.
- C. All gate valves shall be resilient seated wedge type.
- D. All gate valves shall be non-rising stem type with "O-ring seals.
- E. All gate valves shall be mounted in the vertical position.

2.02 CHECK VALVES

- A. Acceptable Manufacturers:
 - 1. American Valve and Hydrant.
 - 2. Dresser.
 - 3. Mueller.
- B. Check valves for sewage pump discharges 4-inch and larger shall be of the unobstructed waterway, quick closing, spring-loaded, external level arm, Horizontal swing type with iron body, flanged ends, and bronze trim.
- C. Hinge pins shall be stainless steel with both ends extending through bronze-bushed bearings and outside stuffing boxes with grease lubricated packing or O-ring seals.
- D. Flanges shall be flat-faced with ANSI B16.1, Class 125 diameter and drilling.

2.03 FIRE HYDRANTS

- A. Acceptable Model/Manufacturer:
 - 1. Clow Medallion.
 - 2. Kennedy iHydrant or Guardian
- B. Fire hydrants shall conform to AWWA C502, Standard for dry-barrel fire hydrants.
- C. Fire hydrant shall have a nominal 5-1/4 inch **I.D.** main valve with 6-inch mechanical joint inlet connection.
- D. Outlet nozzles shall be National (American) fire hose coupling screw threads and be as follows:
 - 1. Two - 2-1/2 inch hose nozzles.

SECTION 02640 - VALVES, HYDRANTS AND ACCESSORIES

2. One - 4-1/2 inch pumper nozzle.
- E. Main valve shall be equipped with "O"-ring seals and shall open to the left (counterclockwise).
- F. Fire hydrant shall be of the break-flange safety-top type.

2.04 VALVE BOXES

- A. Acceptable Manufacturers:
 1. Clay and Bailey Manufacturing Company.
 2. Clow Corporation.
 3. Dresser Industries, Inc.
 4. Mueller Company.
 5. Neenah Foundry Company.
 6. Tyler Company.
- B. Provide for all buried valves.
- C. Design:
 1. Boxes shall be cast-iron slide type with 5-1/4-inch shaft.
 2. Provide extension stem to bring operating nut within 3 feet of valve box top.
 3. Cover shall be marked "WATER".

2.05 SHOP PAINTING

- A. Prepare surfaces and paint or coat all valves, fire hydrants, valve boxes, corporation stops, and all related accessories standard of the manufacturer unless otherwise indicated or specified herein.
- B. Paint and coatings shall be suitable for the service intended.
- C. Submit type of paint or coating proposed with drawings and data prior to fabrication.

SECTION 02640 - VALVES, HYDRANTS AND ACCESSORIES

2.06 BACKFLOW PREVENTER

A. Acceptable Manufacturers

1. Watts Backflow Assembly or approved equal. Use only double check valve assemblies or reduced pressure principle assemblies included on the current Missouri Department of Natural Resources approved assemblies list. Backflow preventers and their installation shall conform to Missouri Department of Natural Resources Regulations 10 CSR 60-11.010.

PART 3 - EXECUTION

3.02 INSTALLATION

- A. Comply with provisions of AWWA C600 and as specified.
- B. Thoroughly clean and remove all shipping materials prior to setting. Operate all valves from fully opened to totally closed.
- C. Hydrants should be placed at or near each street intersection and at intermediate points when block lengths become long. Hydrants shall be provided within 50' of any lift station, but not within the fenced area. Under no circumstances shall the spacing of fire hydrants exceed five hundred (500) feet in residential areas nor three hundred (300) feet in commercial areas, (measured in street driving distance). Fire Hydrant installations shall conform to the Standard Drawing Details. As a rule, hydrants shall be oriented with the pumper outlet perpendicular to the curb which faces the street. Hydrants shall be protected if subject to mechanical damage. The means of protection shall be arranged in a manner that will not interfere with the connection to, or operation of, hydrants. In poor load-bearing soil, special construction such as support collars may be required. Thrust restraint shall be provided for throttling valve so that the hydrant may be removed without shutting down the supply main. Set fire hydrants with lowest nozzle 18 inches above finished grade and a minimum of 3' horizontal clearance beyond all nozzles. **Ductile iron risers shall be installed as necessary to ensure hydrant is within specified vertical clearance range. All riser installations are to be incidental to the installation of fire hydrant assemblies.** If at any time, the finish grade is adjusted or top soil/sod is added, then the fire hydrant height shall be readjusted to the new grade by the individual responsible for the change in grade. Check and fill stem bonnet lubricant reservoir.
- D. Extension stems shall be provided for buried valves when the operating nut is more than three feet below finished grade. Each extension stem for a buried valve shall extend to within three feet of the ground surface, shall be provided with spacers which will center the stem in the valve box, and shall be equipped with a wrench nut.
- E. Gate valves shall be used in all water mains. Sufficient isolation valves shall be provided on water mains to allow a system to be adequately flushed and so that inconvenience and sanitary hazards to customers will be minimized during repairs. The weight of the valve shall not be carried by the pipe. Valves shall be provided with proper support, such as crushed stone, concrete pads or a well compacted trench bottom. Where new water mains

SECTION 02640 - VALVES, HYDRANTS AND ACCESSORIES

connect to an existing main, a valve shall be installed on the new line. As a rule of thumb, no more than four valves should require closing to isolate a pipe. At a reducer, a valve shall be placed in the smaller pipe within 20 feet of the reducer. In long transmission mains with few branches, valves shall be installed at intervals of no greater than 1000-foot. In municipalities, valves shall be located at not more than 300-foot intervals in commercial areas and at not more than one block or 500-foot intervals in residential or other areas. Valves and valve boxes shall be set plumb with finish grade. If at any time, the finish grade is adjusted or top soil is added, then the valve box shall be readjusted to the new grade by the individual responsible for the change in grade. Each valve box shall be placed directly over the valve it serves, with the top of the box brought flush with the finished grade.

- F. Reinstalled Valves: Valves that are scheduled to be removed by the Contractor from existing work and reused as a part of the new work shall be reinstalled in accordance with the valve manufacturer's recommendations. New gaskets shall be provided between the existing valves and the new connecting pipe as required.

3.02 BACKFLOW PREVENTION DEVICES.

- A. An approved backflow prevention device shall be installed on each service line to a consumer's water system serving premises where, in the judgment of the Public Works Director, actual or potential hazards to the public potable water system exist. Backflow prevention devices for domestic water services shall be located on the consumer's side of the water meter. Backflow prevention devices for fire lines shall be located in an appropriate vault as close to the water main as is reasonably practical. In certain cases, the domestic water service may be supplied from the fire line with the approval of the Public Works Director. The fire line would remain the responsibility of the property owner. The City's Code book, section 720 shall be referenced for additional backflow prevention details.
- B. The following requirements shall be met for water loading stations.
 - 1. An appropriate backflow prevention arrangement shall be incorporated in the piping so there is no backflow to the public water supply. A filling device shall be used so the hose does not extend into the water vessel to prevent contaminants being transferred from a hauling vessel to others subsequently using the station. Hoses shall be short enough that they do not contact the ground or any constructed platform. Hanging brackets or rope and pulley hoist is acceptable.

3.03 FIELD TESTING

- A. Perform on piping and valves as specified in SECTION 02620.

END OF SECTION 02640

SECTION 02675 – DISINFECTION OF PIPING

PART 1 – GENERAL

1.01 SUMMARY

- A. This section covers disinfection of potable water piping with a strong chlorine solution.
- B. Disinfecting may be performed concurrently with pressure and leakage testing or after pressure and leakage testing at the Contractor's option.
- C. All necessary disinfection equipment and materials shall be provided by the Contractor.
- D. Related Work Specified Elsewhere:
 - 1. Pipe Installation and Testing – Section 02620.
- E. Disinfection work shall conform to the requirement of AWWA C651, Standard for Disinfecting Water Mains as modified herein.
- F. In all cases where it is necessary to interrupt service for testing purposes, permission by the City shall be obtained at least 48 hours before the service will be interrupted. The Contractor shall notify the City a minimum of 48 hours to allow City representatives to be present during cleaning and/or disinfection of the water line.

1.02 REFERENCES

- A. Applicable Standards
 - 1. American Water Works Association
 - a. B300-Hypochlorites.
 - b. B301-Liquid Chlorine.
 - c. C651 – Disinfecting Water Mains.
 - d. M12-Simplified Procedures for Water Examination.

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.
- B. Includes, but not limited to the following:
 - 1. Product data: Manufacturer's technical data, specification, safety precautions for chlorine products.
 - 2. Results of bacteriological testing on each section of pipe.

SECTION 02675 – DISINFECTION OF PIPING

- C. Disinfection Plan: Two weeks prior to starting any disinfection work, the Contractor shall submit to the City a detailed disinfection plan. The plan shall cover the method and procedure proposed, necessary coordination, equipment to be used, manner of filling and flushing the lines, chlorine injection points, sample points, testing schedule, potable water source, neutralization, and disposal of wasted water. Personnel performing the disinfection shall demonstrate a minimum of 5 years of experience in the chlorination and dechlorination of similar pipelines.

PART 2 - PRODUCTS

2.01 CHLORINE

- A. Calcium Hypochlorite - 70 percent available chlorine.
- B. Liquid chlorine - 99.5 percent available chlorine.

PART 3 - EXECUTION

3.01 FLUSHING

- A. All water mains shall be thoroughly flushed prior to disinfection at a velocity of not less than 3.0 feet per second. Booster pumps shall be used if required to obtain the necessary volume or velocity of water.
- B. Contractor shall verify that discharge points have adequate drainage to prevent flooding of surrounding area. Location of discharge point shall be approved by the City.
- C. Flushing shall continue until discharge stream is visibly clean (clear) or three pipe volumes have been replaced, whichever is greater.
- D. The City will charge for the cost of water used for flushing, as well as costs for sampling and testing accomplished by the City.

3.02 FEEDING

- A. Chlorine gas shall be used only as a solution. Introduction of chlorine gas into pipeline directly will not be permitted. Proper feeding operation shall utilize a chlorinator and booster pump with injector.
- B. Calcium hypochlorite shall be made into a solution and pumped into the pipeline with a suitable chemical feed pump.

3.03 APPLICATION

- A. Pipeline shall be disinfected by the continuous feed method.

SECTION 02675 – DISINFECTION OF PIPING

- B. Required chlorine to produce 50 milligrams per liter concentration in 100 feet of pipes – by diameter shall be as follows:

<u>Pipe Size (In.)</u>	<u>100 Percent Chlorine (lb.)</u>	<u>1 Percent Chlorine Solution (gal.)</u>
4	0.027	0.33
6	0.061	0.73
8	0.108	1.30
10	0.170	2.04
12	0.240	2.88

- C. Water from the existing distribution system shall be introduced at a constant measured rate into the newly-laid pipeline. The water shall receive a dose of chlorine which is fed at a constant measured rate.
1. The chlorine feed shall be proportioned to the rate of water flow into the pipeline so that the entering water contains at least 50 mg/l of available chlorine. Chlorine application shall be continuous until the entire pipeline is filled with the chlorine solution.
 2. To assure that this concentration is maintained, the chlorine residual should be measured at regular intervals in accordance with the procedures described in the latest edition of Standard Methods for the Examination of Water and Wastewater or AWWA Manual M12 or using appropriate chlorine test kits.
 3. Amount of chlorine required for each 100 feet of pipe of various diameters is indicated in paragraph 3.03 (B) above. Solutions of 1 percent chlorine shall be prepared with calcium hypochlorite by mixing one pound of calcium hypochlorite with 8 gallons of water.
 4. During the application of chlorine, valves shall be positioned to prevent chlorine solution from flowing back into the line supplying the water. The chlorinated water shall be retained in the pipeline for at least 24 hours during which time all valves and hydrants in the section treated shall be operated to ensure disinfection of the appurtenances. At the end of the 24-hour period, the treated water in all portions of the pipeline shall have a residual of not less than 25 mg/l free chlorine.
- D. Existing mains which could have been contaminated during work requiring connections to the new waterline, involving either tapping or cutting into operations, shall be flushed and disinfected in accordance with Section 10 of AWWA C651.

3.04 FINAL FLUSHING

- A. After the applicable retention period, heavily chlorinated water shall be flushed from the pipeline until chlorine residual is no higher than that generally prevailing in the system.
- B. Apply a chlorine reducing agent to the water to be wasted to neutralize the chlorine residual.

SECTION 02675 – DISINFECTION OF PIPING

- C. All chlorinated wastewater to be discharged shall be neutralized by chemical treatment and disposed of in accordance with AWWA C651. Schedule and coordinate rates of flow and locations of discharge of disinfection and flushing water with the City and cognizant of state and local regulatory agencies to ensure compliance with all applicable rules and regulations.

3.05 BACTERIOLOGICAL TEST

- A. After final flushing and before the water main is placed in service, samples shall be collected from the main, shall be tested for bacteriological quality in accordance with the Standard Methods for the Examination of Water and Wastewater and shall show the absence of coli form organisms.
 - 1. At least two (2) samples shall be taken from each sample point with 24 hours separation between sets of samples. Both sets of samples shall show the absence of coli form organisms.
 - 2. Samples points shall be as follows:
 - a. At 1200-foot intervals along the water main.
 - b. At the end of the water main.
 - c. At the end of each branch water main.
- B. No hose or fire hydrant shall be used in collection of samples. A suggested combination blow off and sampling tap consists of a standard corporation cock installed in the main with a copper-tube gooseneck assembly. After samples have been collected, the gooseneck assembly may be removed and retained for future use.

3.06 RE-DISINFECTION (REPETITION)

- A. If the initial disinfection fails to produce two successive satisfactory bacteriological samples, the water main shall be re-chlorinated by the continuous-feed method of chlorination until two successive satisfactory results of the bacteriological testing are obtained.

END OF SECTION 02675

SECTION 02720 – STORM DRAINAGE SYSTEM

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes storm drainage pipe and appurtenances.
- B. Related Work Specified Elsewhere:
 - 1. Site Preparation and Earthwork: SECTION 02200.
 - 2. Trenching and Backfilling for Utilities: SECTION 02222.
 - 3. Curbs, Gutters, Sidewalks, Driveway approaches and Paved Drainage: SECTION 02525.
 - 4. Concrete: SECTION 03300.

1.02 REFERENCES

- A. Applicable Standards.
 - 1. American Society for Testing and Materials (ASTM):
 - a. C76 - Reinforced Concrete Culvert, Storm Drain and Sewer Pipe.
 - b. C443 - Joints for Concrete Pipe and Manholes, Using Rubber Gaskets.
 - c. C478 – Circular Precast Reinforced Concrete Manhole Sections.
 - d. C506- Reinforced Concrete Arch Culvert, Storm Drain and Sewer Pipe.
 - e. C507-Reinforced Concrete Elliptical Culvert, Storm Drain and Sewer Pipe.
 - f. D2321-Underground Installation of Thermoplastic Pipe for Sewers and Other Gravity-Flow Applications.
 - 2. American Association of State Highway and Transportation Officials (AASHTO);
 - a. M294 – Corrugated Polyethylene Pipe 12 to 60” Diameter.
 - b. M252 – Corrugated Polyethylene Pipe 4 to 12” Diameter.
 - c. M274 – Steel Sheet, Aluminum-Coated for Corrugated Steel Pipe

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.

SECTION 02720 – STORM DRAINAGE SYSTEM

- B. Includes, but not limited to, the following:
 - 1. Pre-cast structures.
 - 2. Cast-in-place structures.
 - 3. Reinforced concrete pipe (certification only).
 - 4. Corrugated (metal or polyethylene) pipe (certification only).
 - 5. Joints and fittings (certification only).

PART 2 - PRODUCTS

2.01 GENERAL

- A. See Details in the Standard Drawing Details.
- B. The minimum allowable pipe size for storm sewers is dependent upon a diameter practical from a maintenance standpoint. For storm sewers in public right-of-way or public drainage easement less than fifty feet (50') in length, the minimum allowable diameter is fifteen (15) inches. All pipe over fifty feet (50') in length shall have a minimum diameter of eighteen (18) inches. The maximum allowable diameter is six feet (6') unless otherwise approved.

2.02 REINFORCED CONCRETE

- A. Conform to applicable requirements of SECTION 03300.
- B. Concrete shall be 4,000 psi concrete.

2.03 CORRUGATED METAL PIPE

- A. Pipe, both arch and round, flared end sections and coupling bands shall conform to AASHTO M274 and shall be aluminum-coated.
- B. Coupling bands shall be of the same base metal as the pipe.
- C. Flared end sections shall be provided with toe plates.

2.04 REINFORCED CONCRETE PIPE

- A. Design of circular pipe to conform to ASTM C76, Class III except as modified herein.
- B. Concrete arch culvert and elliptical culvert shall conform to C506 and C507.
- C. Furnish in lengths of not less than 4'-6", except fittings, closure pieces, and specials.

SECTION 02720 – STORM DRAINAGE SYSTEM

- D. Joints shall be rubber and concrete to conform to ASTM C443. Rubber gaskets shall be O-ring cross section.
- E. Select an independent testing laboratory acceptable to City to perform testing and inspection of all material except reinforcing steel.
- F. Storm sewers shall be designed for H-20 loadings.

2.05 CORRUGATED POLYETHYLENE PIPE

- A. Pipe and fittings shall conform to AASHTO M294 and M252 and shall have a circular cross section.
- B. End sections shall be polyethylene flared type with toe plates unless otherwise indicated.
- C. Joints shall be provided with neoprene or manufacturer's standard gaskets.

2.06 CORRUGATED POLYPROPYLENE PIPE

- A. Pipe and fittings shall conform to ASTM F-2881 and F-2764 and shall have a circular cross section.
- B. End sections shall be polyethylene flared type with toe plates unless otherwise indicated.
- C. Joints shall be provided with neoprene or manufacturer's standard gaskets.

PART 3 - EXECUTION

3.01 TRENCHING AND BACKFILLING

- A. Perform trenching and backfilling of trenches as specified in SECTION 02222.

3.02 PIPE LOCATION

- A. All storm sewer having trench walls within 2 feet of the back of curb shall be backfilled with compacted granular materials.
- B. The permitted locations for storm sewer within a street right-of-way are behind the curb. The outside edge of the pipe shall be located a minimum of 6" behind the back edge of curb. Except for crossings, storm sewers shall not be located under streets.
- C. Storm sewers located on private property shall be located within drainage easements and shall be aligned parallel with property lines unless otherwise approved. Where storm drains exit the street right-of-way between residential lots, the pipe shall be extended a minimum of forty feet (40') past the front yard setback line, or to the estimated location of the rear of the dwellings, whichever is more. The outside edge of the pipe shall be located a minimum of five feet (5') from the easement line.

SECTION 02720 – STORM DRAINAGE SYSTEM

- D. Reinforced concrete pipe or corrugated polypropylene pipe shall be used under paved areas.
- E. Corrugated polyethylene pipe and corrugated metal pipe are permitted within right-of-ways outside of traffic areas and other areas outside of the right-of-way.

3.03 PIPE INSTALLATION

- A. All pipes shall be carefully laid true to lines and grades indicated. The Contractor shall be responsible for establishing the horizontal and vertical alignment of all storm sewers. The contractor shall provide and maintain in good working order, on the site, at all times, a laser beam or other appropriate equipment to ensure proper alignment. Pipe laid in the trench shall not be covered until approved by the Public Works Director or his representative. Storm pipe alignment between manholes shall be straight except when approved by the Public Works Director. Curved alignments are not allowed. Storm sewer crossings shall be perpendicular to the street. Any pipe which is not in true alignment or which shows undue settlement after laying shall be taken-up and re-laid at the Contractor's expense.
- B. The recommended minimum slope for storm drain piping is 0.5% (five-tenths percent). Maximum recommended grade is 10% (ten percent). Proper anchorage may be required for grades above 10% (ten percent) and will be required for grades above 20% (twenty percent).
- C. Culverts shall be positioned to match both the vertical and horizontal alignment of the existing watercourse to the greatest degree practical.
- D. When changing pipe diameters, the inside tops of the pipes shall be set at the same elevation. Pipe size shall never be reduced downstream even though pipe slope and theoretical capacity may increase. A minimum vertical drop of 0.2' (two-tenths feet) shall always be provided across a junction structure, unless otherwise approved.
- E. Siphons or inverted siphons are not allowed in the storm sewer system.
- F. Under or within two feet (2') of streets or paved areas, the top of the pipe shall be located a minimum of twelve inches (12") below the pavement or curb subgrade, or greater if required to meet minimum cover and strength requirements for the type of pipe specified to withstand an AASHTO HS-20 loading. Outside of paved areas, the top of the pipe shall be located a minimum of twelve inches (12") below finished earth grade. Box culverts or other relatively wide and flat conveyance structures may be required to have additional cover if deemed necessary to support grass or other vegetative cover.
- G. Corrugated Metal Pipe:
 - 1. Install to conform to manufacturer's recommendations. All corrugated metal pipe shall be installed using Class B embedment as defined in section 02222.
 - 2. Lift or roll pipe to protect coating. Do not drag over gravel or rock. Avoid striking rocks or hard objects when lowering into trench. Pipe on which coatings have been damaged shall be rejected at the site of the work regardless of previous approvals.

SECTION 02720 – STORM DRAINAGE SYSTEM

3. Join pipe sections with firmly bolted coupling bands of the same materials as the pipe.

H. Reinforced Concrete Pipe:

1. Install to conform to manufacturer's recommendations and as follows:
2. Concrete Stormwater Piping shall be installed using Class B embedment as defined in section 02222.
3. Each length of pipe shall be laid on an even, firm bed, so that no uneven strain will exist to prevent the pipe from bearing on the sockets. Bell holes for bell and spigot pipe shall be dug at each joint as specified. Pipe laying shall commence at the low point of the project and progress upgrade, unless otherwise expressly permitted by the City/Engineer. The bell-end of the pipe shall be laid upgrade. The end of each joint of pipe shall be truly centered and fully positioned into the abutting pipe.
4. Pipe jointing material shall be Ram-nek or equal.
5. Clean joints thoroughly, and coat bell-and-spigot and gasket with recommended lubricant before jointing.
6. Check that rubber gasket is properly positioned prior to shoving pipe home.
7. Fill exterior pipe joint with a 1:2 cement mortar of pouring consistency and cover with a waterproof paper or cloth diaper wired in position. Rod mortar with a stiff wire curved to the radius of the pipe.
8. Fill interior of joint with stiff mix of 1:1 cement mortar troweled into place to provide a continuous smooth surface across joint (pipe 24 inches in diameter and larger).

I. Corrugated Polyethylene and Corrugated Polypropylene Pipe:

1. Installation to conform to ASTM D2321 with Class B embedment as defined in Section 02222.
2. Clean joints thoroughly, and coat bell, spigot and gasket with recommended lubricant before jointing.

3.04 STORM DRAINAGE STRUCTURES

A. Bends and Junctions:

1. A manhole or junction structure must be provided at each change in direction or grade of the piping, except that bends may be located at junction structures in order to provide a perpendicular connection. Bends must be provided at junction structures if the angle of entry is less than sixty (60) degrees. Pipes shall be aligned such that the direction of flow of

SECTION 02720 – STORM DRAINAGE SYSTEM

any incoming pipe is not less than perpendicular to the direction of flow of the outflow pipe (i.e. flow "against the grain" shall be avoided).

2. Access manholes or junction structures shall not be located within the pavement area of public streets. Access manholes or junction structures shall be located such that the outside edge is twelve inches (12") minimum behind the curb or from the edge of a retaining wall or other obstruction. Access manholes shall be provided at a maximum of five hundred feet (500') spacing along the pipe.
3. Precast circular manholes, square cast-in-place or precast junction boxes, or inlets may be used for junction structures.

B. Curb Inlet Boxes

1. Standard curb opening inlets as shown on details in the Standard Drawing Details shall be used for public streets with curb and gutter. In general, the use of grated inlets in streets, which require adjustment when streets are repaved, will not be permitted. Curb inlet boxes shall be placed to match the slope of the street centerline and adjacent curb line.

C. Storm Sewer Outlets

1. All storm sewer outlets into open channels shall be constructed with a **concrete** headwall and **concrete** wingwalls, **concrete culvert cap** or a **precast concrete** flared-end-section. Flared end sections and headwalls shall have a toewall extending a minimum of eighteen inches (18") below grade at their downstream end to prevent undercutting. Approved energy dissipation material shall be provided at all outlets as required.

D. Others

1. All other storm drainage structures shall be installed as per construction drawings.

E. Reinforced Portland cement Concrete:

1. All reinforced Portland cement concrete storm drainage structures shall have a paved invert and a smooth grade from pipe invert to pipe invert in structures having more than one pipe.
2. Cast-In-Place: Conform to all applicable requirements of SECTION 03300.
3. Precast: Structures shall be of precast construction where indicated or as approved by Engineer and The City. Precast structures shall have cast-in-place reinforced concrete base conforming to SECTION 03300.

END OF SECTION 02720

SECTION 02831 - CHAIN-LINK FENCES AND GATES

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes chain-link fabric fence, gates, and related components.
- B. Related Work Specified Elsewhere:
 - 1. Concrete: SECTION 03300.
- C. See Details in the Standard Drawing Details.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Society for Testing and Materials (ASTM):
 - a. A121 – Metallic-Coated Carbon Steel Barbed Wire.
 - b. A123 -Zinc (Hot-Galvanized) Coatings on Iron and Steel Products.
 - c. A153 - Zinc Coating (Hot-Dip) on Iron and Steel Hardware.
 - d. A392 - Zinc-Coated Steel Chain-Link Fence Fabric.
 - e. A1011 – Steel, Sheet and Strip, Hot-rolled, Carbon, Structural, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength.
 - f. F1083 - Pipe, Steel, Hot Dipped, and Zinc-Coated (Galvanized) Welded, for Fence Structures.

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.
- B. Includes, but not limited to, the following:
 - 1. Product data: Manufacturer's technical data, specifications, and installation instructions for fence and gate posts, fabric, gates, and accessories.
 - 2. Shop Drawings: Showing layout, location of fence, gates, posts, and including details illustrating fence height, sizes of posts, rails, braces, gates, hardware list, and accessories.
 - 3. Mill certification that materials meet specifications of member size, strength, wall thickness, and coatings.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

1.04 QUALITY ASSURANCE

- A. Provide chain-link fences and gates as complete units, including necessary erection accessories, fittings, and fastenings, from a single source or manufacturer.

PART 2 - PRODUCTS

2.01 ACCEPTABLE MANUFACTURERS

- A. Subject to compliance with requirements, provide products of one of the following:

- 1. Galvanized Steel Fencing and Fabric:
 - a. Allied Tube and Conduit Corp.
 - b. Anchor Fence, Inc.
 - c. Cyclone Fence, USK Corp.

2.02 GENERAL

- A. Fence height and gate width(s) shall be as indicated.
- B. Dimensions indicated for pipe, roll-formed, and H-sections are outside dimensions, exclusive of coatings.

2.03 FABRIC

- A. Steel Fabric:
 - 1. No. 9 gauge, 2-inch diamond-mesh steel, chain-link fabric. Furnish 1-piece fabric widths for fencing up to 12'-0" high.
 - 2. Galvanized: Conform to ASTM A392 with zinc coating, Class 2, 2.0 ounces minimum per square foot of wire surface.
 - 3. Top and bottom selvage knuckled for fabric 5'-0" and under.

2.04 FRAMING AND ACCESSORIES

- A. Steel Framework:
 - 1. General: Galvanized steel, ASTM F1083 or ASTM A123, with not less than 1.8-ounce zinc per square foot of surface, or steel conforming to ASTM A569 externally triple coated with hot-dip galvanizing at 1.0 ounce/square foot, chromatic conversion coating and clear acrylic polyurethane and coated internally with zinc-rich coating.
 - 2. Fittings and Accessories: Galvanized, ASTM A153, with zinc weights per Table I.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

2.05 STEEL POSTS, TOP RAIL AND BRACES

A. Minimum size and weight of steel components shall be as follows:

1. Posts for Fabric Height Over 6 Feet:

- a. End, Angle, Corner, or Pull Posts: 2.875 inches OD at 5.79 pounds per foot.
- b. Line Posts - 6-Foot to 8-Foot Fabric Height: 2.375 inches OD at 3.65 pounds per foot.
- c. Line Posts - Over 8-Foot Fabric Height: 2.875 inches OD pipe at 5.79 pounds per foot.
- d. In lieu of pipe specified above, steel pipe conforming to ASTM A1011 of greater strength but less wall thickness, will be acceptable.

2. Posts for Fabric Height 6 Feet or Less:

- a. End, Angle, Corner, or Pull Posts: 2.375 inches OD at 3.65 pounds per foot.
- b. Line Posts: 1.90 inches OD at 2.70 pounds per foot.
- c. In lieu of pipe specified above, steel pipe conforming to ASTM A1011 of greater strength but less wall thickness, will be acceptable.

3. Gate Posts:

- a. Furnish posts for supporting single-gate leaf, or one leaf of a double-gate installation, for nominal gate widths as follows:

<u>Leaf width</u>	<u>Gate Post</u>	<u>lbs/lf.</u>
Up to 6'	3.5" x 3.5" roll-formed Section or 2.1875" OD pipe	4.85 5.79
Over 6' to 13'	4.000" OD pipe	9.11

4. Top Rail:

- a. 1.660 inches OD at 2.27 pounds per foot.
- b. 18-foot minimum length of each section.
- c. Expansion-type couplings for each joint, approximately 6 inches long.

5. Post Bracing:

- a. Diagonal adjustable rods 3/8 inch in diameter equipped with adjustable tightener.
- b. Horizontal Braces: 1.660 inches OD at 2.27 pounds per foot.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

6. Post Tops:
 - a. Designed as a weather tight closure cap for tubular posts.
 - b. Furnish caps with openings to permit passage of top rail.
 - c. Malleable iron or pressed steel.
7. Stretcher Bars:
 - a. One piece, full height of fabric.
 - b. 3/16-inch x 3/4-inch, galvanized.
 - c. Bands of galvanized steel or malleable iron.
8. Barbed Wire:
 - a. Galvanized, ASTM A121, Class 2 or Aluminum coated.
 - b. Two 12-1/2 gauge steel wire with 4 point barbs.
 - c. Three strands of barbed wire located above top rail.
9. Bottom Tension Wire:
 - a. Galvanized or aluminum coated coil spring wire, 7 gauge.

2.06 GATES

- A. Manual-Swing:
 1. Framing:
 - a. Fabricate perimeter frames of gates from metal and finish to match fence framework.
 - b. Provide intermediate horizontal and vertical members for proper gate operation and for attachment of fabric, hardware, and accessories. Space so that frame members are not more than 8 feet apart unless otherwise indicated.
 - c. Frames assembled by welding or watertight galvanized steel rigid fittings.
 - d. Provide with same fabric as for fence. Install fabric with stretcher bars at vertical and top and bottom edges.
 - e. Diagonal cross bracing of 3/8-inch-diameter adjustable truss rods to ensure frame rigidity without sag or twist.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

- f. Where barbed wire is indicated or specified, extend gate end members 1 foot above top members to receive barbed wire.

2. Hardware:

- a. Hinges of pressed or forged steel, or malleable iron, nonlift-off type, offset to permit 180° gate opening, 1-1/2 pair per leaf.
- b. Latches and Gate Stops: Double-leaf.
 - (1) Plunger-bar type latch, full gate height, designed to engage gate stop of flush-plate type, with anchors.
 - (2) Locking device and padlock eyes an integral part of latch.
 - (3) Keeper to automatically engage gate leaf and secure free end of gate in open position.
- c. Latches: Single-leaf.
 - (1) Forked type to permit operation from either side of gate.
 - (2) Padlock eye as integral part of latch.

3. Coating: Galvanize conforming to A153.

B. Sliding Cantilevered:

- 1. Cantilevered gates may be either exposed rollers type or trolleys within a built-in channel type. Exposed rollers shall be provided with roller guards.
- 2. Framing:
 - a. Inverted channel track, roller ball-bearing truck assemblies, guides, stays, bracing, hardware, and accessories as required.
 - b. Intermediate horizontal and vertical members for proper gate operation and for attachment of fabric, hardware, and accessories. Space so that frame members are not more than 8 feet apart unless otherwise indicated.
 - c. Frames assembled by welding or watertight galvanized steel rigid fittings.
 - d. Diagonal cross bracing of 3/8-inch-diameter adjustable truss rods to provide frame rigidity.
 - e. Where barbed wire is indicated or specified, extend gate end members 1 foot above top members to receive barbed wire.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

2.07 CONCRETE As specified in Section 03300.

PART 3 - EXECUTION

3.01 PREPARATION

- A. Grading: Perform final grading prior to installation of fence.

3.02 INSTALLATION

- A. Fence:

1. Follow general contour of ground and properly alignment. Install as indicated.
2. Posts:
 - a. Set in concrete bases 3 feet below finish grade. Trowel-finish tops of footings and dome to direct water away from posts.
 - b. Temporarily brace until concrete in bases has set.
 - c. Install plumb and in straight alignment.
 - d. Space 10 feet center-to-center maximum.
 - e. Install pull posts every 300 feet if no corner posts are encountered in that distance.
 - f. Install corner posts at changes in direction of 30° or more.
 - g. Install pull posts at changes in direction of 10° to 30°.
 - h. Install pull posts at all abrupt changes in grade.
3. Post Bracing:
 - a. Install at each end, pull and gate post, and each side of each corner post.
 - b. Install after concrete in post bases has set.
 - c. Install so posts are plumb when diagonal rod is under tension.
4. Top Rails:
 - a. Run continuously through post caps or barbed wire supporting arms. (Bend to radius for curved runs.)
 - b. Install expansion couplings at each joint.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

5. Fabric:

- a. Run continuously through post caps or barbed wire supporting arms. (Bend to radius for curved runs.)
- b. Install fabric on security side of fence and anchor to framework so that fabric remains in tension after pulling force is released.
- c. Use U-shaped wire, conforming to diameter of pipe to which attached, clasping pipe and fabric firmly with ends twisted at least two full turns. Bend ends of wire to minimize hazard to persons or clothing.
- d. Fasten fabric to steel posts with wire ties spaced 12 inches OC maximum.
- e. Fasten fabric to top rail with wire ties spaced at 24 inches OC maximum.

6. Stretcher Bars:

- a. Thread through or clamp to fabric 4 inches oc.
- b. Secure to posts with metal bands spaced 15 inches OC maximum.
- c. Install at each gate, pull and end post, and each side of corner post.

7. Post Tops: Install on each post.

8. Barbed Wire: Mount strands on 45-degree extension arms.

9. Bottom Tension Wire:

- a. Install approximately 6 inches above grade.
- b. Attach wire to each post and securely anchor to terminal gate posts.

B. Manual-Swing and Cantilevered Sliding Gates:

1. Install plumb and level.
2. Install all hardware, tracks, framing, supports, and appurtenances as required for gate type.
3. Install keepers, ground-set items, and flush plate in concrete for anchorage.
4. Adjust and lubricate as necessary for smooth operation.

SECTION 02831 - CHAIN-LINK FENCES AND GATES

C. Repairing Damaged Coatings:

1. Repair any damaged coatings in the shop or field by recoating with compatible and similar coating.
2. Apply per manufacturer's recommendations.

END OF SECTION 02831

SECTION 02930 – SEEDING AND SODDING

PART 1 - GENERAL

1.01 SUMMARY

A. This Section includes the following areas of Work:

1. Preparation of areas for seeding and sodding.
2. Seeding.
3. Sodding.
4. Mulching.
5. Fertilizing seed and sod areas.
6. Maintenance.

B. Related Work Specified Elsewhere:

1. Site Preparation and Earthwork: SECTION 02200.

1.02 SUBMITTALS

A. Certificates:

1. Seed and fertilizer shall be accompanied by certificate from vendors certifying they meet requirements of these Specifications, stating botanical name, percentage by weight, percentage of purity, germination, and weed seed for each grass seed species.

PART 2 - PRODUCTS

2.01 TOPSOIL Specified in SECTION 02200.

2.02 GRASS SEED

- A. Provide fresh, clean, new crop seed complying with tolerance for purity and germination established by Official Seed Analysts of North America and as required below.
- B. Be labeled according to the U.S. Department of Agriculture Federal Seed Act and shall be furnished in containers with tags showing seed mixture, purity, germination, weed content, name of seller, and date on which seed was tested:
 1. Seed Mixture:
 - a. Meet the following minimum percentage requirements for purity and mix ratio:

SECTION 02930 – SEEDING AND SODDING

<u>Common and Botanical Name</u>	<u>Minimum Pure Live Seed (%)</u>	<u>Rate of Pure Live Seed (Pounds per Acre)</u>
Alta Fescue or Kentucky 31 Fescue (Festuca Elatior, variation Arundinacea)	75	100
Rye Grass (Lolium Perenne or L. Multiflorum)	80	25
Kentucky Blue Grass (Poa Pratensis)	75	15
Creeping Red Fescue (Festuca Rubra)	85	10
Total		150 pounds

2. Moldy seed or seed that has been damaged in storage shall not be used.

2.03 SOD

- A. Machine cut, strongly rooted, certified turf-grass sod, at least 2 years old, and be relatively free of weeds or other undesirable native grasses. Provide sod capable of vigorous growth and development when planted (viable, not dormant).
- B. Be composed principally of the following:
 - 1. Kentucky bluegrass.
- C. Moisten sod to depth at which it is to be cut when stripped during dry periods.
- D. Provide sod in uniform thickness of 5/8-inch, plus or minus 1/4-inch, measured at time of cutting and excluding top growth and thatch. Strips shall be of supplier's standard size of uniform length and width with maximum 5% allowable deviation in either length or width. Broken or torn pads or pads with uneven ends are not acceptable.
- E. Sod pads shall be capable of supporting their own weight and retaining size and shape when pad is suspended vertically from a firm grasp on upper 10% of pad.
- F. Handle sod with care to prevent loss of native soil from roots.

SECTION 02930 – SEEDING AND SODDING

2.04 LIMING MATERIAL

- A. Shall consist of agricultural liming materials conforming to the Missouri Agricultural Liming Materials Act of 1976.
- B. Material used for soil neutralization, unless otherwise specified, shall be agricultural lime with not less than 90% passing the No. 8 sieve and containing not less than 65% calcium carbonate equivalent.
- C. Manufacturer's certification shall include the minimum pounds of ENM (effective neutralizing material) per ton of the material to be supplied.

2.05 FERTILIZER

- A. Commercial fertilizer of neutral character, with some elements derived from organic sources, containing not less than 4% phosphoric acid, 2% potassium, and percentage of nitrogen required to provide not less than 1.0 lb. of actual nitrogen per 1,000 square feet of lawn area. Provide nitrogen in form that will be available to the lawn during initial period of growth.
- B. Deliver to site in labeled bags or containers.

2.06 MULCH

- A. Vegetative Anti-Erosion Mulch: Seed-free salt hay or threshed straw of wheat, rye, oats, barley, or other approved materials.
- B. Wood Cellulose Fiber:
 - 1. Not contain germination or growth-inhibiting ingredients.
 - 2. Dyed an appropriate color to aid in visual inspection.
 - 3. Be easily and evenly dispersed when agitated in water.
 - 4. Supply in packages of not more than 100-pound gross weight, and be marked by the manufacturer to show the air dry weight content.

2.07 JUTE NETTING

- A. Uniform, open, plain weave mesh of smolder-resistant, unbleached single-jute yarn:
 - 1. Yarn of loosely twisted construction and not vary in thickness by more than one-half its normal diameter.
- B. Furnish in rolled strips and as follows:
 - 1. Minimum width of 42 inches.

SECTION 02930 – SEEDING AND SODDING

2. 5.5 wrap yarns by 3.5 filling yarns per inch.

C. Staples of No. 11 gauge or heavier steel wire, U-shaped and not less than 6 inches in length.

PART 3 – EXECUTION

3.01 SOIL PREPARATION

- A. Dispose of any growth, rocks, or other obstructions which might interfere with tilling, seeding, sodding, or later maintenance operations. Remove stones over 1-1/2 inches in any dimension and sticks, roots, rubbish, and other extraneous matter.
- B. Thoroughly loosen and pulverize topsoil to a depth of at least 4 inches.
- C. Grade planting areas to a smooth, even surface with loose, uniformly fine texture. Roll and rake, remove ridges and fill depressions to meet finish grades. Limit fine grading to areas which can be planted within immediate future.
- D. Moisten prepared areas before planting if soil is dry. Water thoroughly and allow surface to dry off before planting. Do not create a muddy soil condition.
- E. Restore prepared areas to specified condition if eroded or otherwise disturbed after fine grading and prior to planting.
- F. Spread planting soil mixture to depth required to meet thickness, grades, and elevations indicated after light rolling and natural settlement.
- G. Allow for sod thickness in areas to be sodded.

3.02 LIMING AND FERTILIZING

- A. Lime and fertilizer shall be applied separately, but may be incorporated into the soil in one operation.
- B. Lime and fertilizer shall be applied not more than 48 hours before the seeding or sodding unless otherwise authorized by the City.
- C. Contractor shall take a minimum of three samples of the topsoil stockpile and through the services of an independent laboratory have test run to ascertain the rates of application of soil amendments required to provide at least the quantity of effective neutralizing material and fertilizers to nourish new growth.
- D. Apply lime and fertilizer at the rates recommended by soil analysis in pounds per acre to prepared seedbeds and sod beds.
- E. Incorporate fertilizer into the soil to a depth of at least 3 inches by disking, harrowing, or raking, except where applied hydraulically on slopes steeper than 2 horizontal to 1 vertical.

SECTION 02930 – SEEDING AND SODDING

3.03 SEEDING

- A. Do not use wet seed or seed that is moldy or otherwise damaged in transit or storage.
- B. Do not seed when wind velocity exceeds 5 miles per hour. Distribute seed evenly over entire area by sowing equal quantity in two directions at right angles to each other.
- C. Sow not less than rate of 100 pounds per acre.
- D. Rake seed lightly into top 1/8-inch of soil, roll lightly, and water with fine spray.
- E. Seasonal Limitations:
 - 1. Perform seeding only during the following seasons:
 - a. March 1 to June 15.
 - b. September 1 to October 30.
- F. Methods of Application:
 - 1. Dry Seeding: Spreader or seeding machine.
 - 2. Hydro seeding: Mix seed, fertilizer and pulverized mulch with water and constantly agitate. Do not add seed to water more than 4 hours before application:
 - a. On slopes of 3 horizontal to 1 vertical or flatter, apply seed separately from fertilizer. Cover seed with soil to an average depth of ½ inch by raking or other approved methods.
 - b. On slopes steeper than 3 horizontal to 1 vertical, a Type 3 Mulch, meeting the content and application requirements specified in Section 802 of the Missouri Standard Specifications for Highway Construction is required.

3.04 MULCHING

- A. Apply mulch covering to all seeded areas.
- B. Apply vegetative mulch to loose depth of 1-1/2 inches by means of a mechanical spreader or other approved methods.
- C. Apply wood-cellulose fiber mulch hydraulically at the rate of 1,000 pounds per acre:
 - 1. Mulch and seed may be applied in a single operation.
 - 2. Apply mulch to achieve a uniform coverage of the soil surface.

SECTION 02930 – SEEDING AND SODDING

- D. Immediately follow the application of the mulch, water the seeded area in one watering, in sufficient amount to penetrate the seedbed to a minimum of 2 inches. Perform so as not to cause erosion or damage to the seeded surface.
- E. Protect seeded areas against hot, dry weather or drying winds by applying mulch not more than 24 hours after completion of seeding operations.

3.05 SODDING NEW LAWNS

- A. Do not place sod during a drought or during the period from June 15 to September 1, except as authorized by the City.
- B. Lay sod within 24 hours from time of stripping. Do not lay dormant sod or if ground is frozen.
- C. Sod shall be moist at the time it is placed.
- D. Lay sod strips along contour lines, by hand, commencing at the base of the area to be sodded and working upward:
 - 1. Carefully lay sod to produce tight joints. Butt ends and sides of sod strips; do not overlap.
 - 2. Stagger transverse joints of sod strips.
 - 3. Work from boards to avoid damage to sub grade or sod.
 - 4. Tamp or roll lightly to ensure contact with sub grade. Work sifted soil into minor cracks between pieces of sod, removing excess to avoid smothering adjacent grass.
- E. On slopes of 3 horizontal to 1 vertical and steeper, anchor sod by wooden pegs. Pegs shall be ½" x 12", driven into the ground on about 2-foot centers. Top of peg after driving shall be not less than ½-inch but not more than 1 inch above top of sod.
- F. Water sod with fine spray immediately after planting. During first week, water daily or more frequently as necessary to maintain moist soil to depth of 4 inches.

3.06 RECONDITIONING EXISTING GRASS AREAS

- A. Recondition existing grass areas damaged by Contractor's operations, including storage of materials or equipment and movement of vehicles. Also recondition the areas where settlement or washouts occur or where minor regrading is required. Recondition other existing grass areas where indicated.
- B. Provide fertilizer, seed or sod, and soil amendments as specified for new grass and as required to provide satisfactorily reconditioned grass growth. Provide new planting soil as required to fill low spots and meet new finish grades.
- C. Cultivate bare and compacted areas thoroughly to provide good, deep planting bed.

SECTION 02930 – SEEDING AND SODDING

- D. Remove diseased or unsatisfactory grass areas; do not bury into soil. Remove topsoil containing foreign materials resulting from Contractor's operations including oil drippings, stone, gravel, and other construction materials. Replace with new topsoil.
- E. Where substantial grass remains (but is thin), mow, rake, aerate if compacted, fill low spots, remove humps and cultivate soil, fertilize, and seed. Remove weeds before seeding or, if extensive, apply selective chemical weed killers as required. Apply seedbed mulch, if required, to maintain moist condition.
- F. Water newly planted areas and keep moist until new grass is established.

3.07 PROTECTION

- A. Erect barricades and warning signs as required to protect newly planted areas from traffic. Maintain barricades throughout maintenance period until lawn is established.

3.08 MAINTENANCE

- A. Mow grass to a height of 2 inches as soon as there is enough top growth to cut with mower. Remove no more than 40% of grass leaf growth in initial or subsequent mowing. Do not delay mowing until grass blades bend over and become matted.
- B. Remove weeds by pulling or chemical treatment.
- C. Perform maintenance as indicated in the previous paragraphs A and B until the date of final acceptance by City.
- D. Seeded Areas:
 - 1. Water as required by good practice and as necessary to obtain a flourishing cover.
 - 2. Repair any portion of the seeded surface which becomes gullied or otherwise damaged or the seeding becomes damaged or destroyed.
- E. Sodded Areas:
 - 1. Thoroughly water daily for a period of 15 days after placing.
 - 2. Maintain sod in good live condition. Replace any sod not in good growing condition with fresh live sod.
 - 3. Water thoroughly whenever sod evidences excessive drying.
- F. Apply second fertilizer application after first mowing and when grass is dry. Use fertilizer which will provide not less than 1.0 pound of actual nitrogen per 1,000 square feet of lawn area.

SECTION 02930 – SEEDING AND SODDING

3.09 ACCEPTANCE OF LAWNS

- A. When lawn work is substantially complete, including maintenance, the City will, upon request, make an inspection to determine acceptability:
 - 1. Lawn work may be inspected for acceptance in parts agreeable to the City, provided work offered for inspection is complete, including maintenance.
- B. Replant rejected work and continue specified maintenance until re-inspected by the City and found to be acceptable.
- C. Seeded lawns will be acceptable provided requirements, including maintenance, have been complied with and healthy, uniform, close stand of specified grass is established free of weeds, bare spots, and surface irregularities.
- D. Sodded lawns will be acceptable provided requirements, including maintenance, have been complied with and healthy, well-rooted, even-colored, viable lawn is established free of weeds, open joints, bare areas, and surface irregularities.

3.010 CLEANUP

- A. Promptly remove soil and debris created by lawn Work from paved areas. Clean wheels of vehicles prior to leaving site to avoid tracking soil onto surfacing of roads, walks, or other paved areas.

END OF SECTION 02930

SECTION 03200 – CONCRETE REINFORCEMENT

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes steel reinforcement bars, ties, welded wire fabric, bolsters, chair supports, and accessories.
- B. Related Work Specified Elsewhere:
 - 1. Concrete: SECTION 03300.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American Society for Testing and Materials (ASTM):
 - a. A615 - Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
 - b. A1064 –Carbon - Steel Wire, Plain and Welded Wire Reinforcement, Plain and Deformed, for Concrete.
 - 2. American Concrete Institute (ACI):
 - a. 301 - Specifications for Structural Concrete.
 - b. SP-66 - Detailing Manual.
 - c. 318 - Building Code Requirements for Structural Concrete.
 - 3. Concrete Reinforcing Steel Institute (CRSI):
 - a. Manual of Standard Practice.

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.
- B. Include, but not limited to, the following:
 - 1. Complete bar schedule, bar details, and erection drawings to conform to ACI SP-66.
 - 2. Drawing with each type of bent bar marked with identification mark. Straight bars shall have mark number or be identified by size and length.
 - 3. Erection drawings shall be clear, easily legible, and to a minimum scale of:

SECTION 03200 – CONCRETE REINFORCEMENT

- a. $\frac{1}{4}$ inch = 1 foot.
- b. $\frac{1}{8}$ inch = 1 foot if bars in each face are shown in separate views.
- 4. Size and location of all openings.
- 5. Concrete protective cover.
- 6. Grade of steel.
- 7. Lap splice lengths.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Store steel reinforcement blocked-up off the ground and in orderly stacks.
- B. Store only bars with the same identifying label in the same stack.

1.05 TESTING

- A. Perform at the mill for each heat.
- B. Submit certified test results for acceptance upon request.

PART 2 - PRODUCTS

2.01 REINFORCEMENT BARS, TIES, AND STIRRUPS

- A. Materials:
 - 1. Conform to ASTM A615, Grade 60, except as otherwise specified.
 - 2. Cold-drawn wire for spiral column ties shall conform to ASTM A1064.
- B. Fabrication of Bars:
 - 1. Fabricate with cold bends conforming to the recommended dimensions shown in ACI 318.
 - 2. Fabricate bars according to the tolerances given in ACI 301, Chapter 5.
 - 3. Field fabrication will be allowed only if Contractor has equipment to properly fabricate steel.
 - 4. Attach metal or plastic tags with identifying mark or length corresponding to mark number or length on Drawing. Bent bars shall have mark number.

SECTION 03200 – CONCRETE REINFORCEMENT

5. Contractor may, at his option, continue steel reinforcement through openings in walls and slabs, then field-cut the opening so that there will be the required concrete cover between ends of bars and edge of opening.

2.02 WELDED WIRE FABRIC

- A. Conform to ASTM A1064 using bright basic wire.
- B. Wire size W 1.4 and smaller shall be galvanized.
- C. Mats only.

2.03 BOLSTERS, CHAIRS, AND ACCESSORIES

- A. Conform to ACI SP-66 and the CRSI Manual of Standard Practice.
- B. Provide all spacers, bolsters, chairs, ties, and other devices necessary to properly space, place, support, and fasten steel reinforcement in place during the concrete placement.
- C. Metal accessories shall be plastic-coated where legs will be exposed in finished concrete surfaces.
- D. Do not use rocks, broken bricks, wood blocks, reinforcement driven into the ground, concrete fragments or any other unauthorized materials for support of reinforcement.

2.04 PRECAST CONCRETE BLOCK BAR SUPPORTS

- A. May be used only for bar supports in slabs on ground.
- B. Blocks shall be made with a minimum of nine sacks of cement per cubic yard and have a minimum compressive strength of 6,000 psi in 28 days.
- C. Each block shall have a minimum of 9 square inches of bearing area. Space as required by the particular condition of weight, bearing surface, and rigidity of the steel reinforcement.

PART 3 - EXECUTION

3.01 PLACEMENT OF CONCRETE REINFORCEMENT

- A. Place in accordance with Chapter 5 of ACI 301, Chapters 7 and 12 of ACI 318, and the CRSI Manual of Standard Practice.
- B. Tie securely with 16-gauge or larger annealed iron wire.
- C. Place to maintain concrete cover to conform to Chapter 5 of ACI 301 and Chapter 7 of ACI 318, unless otherwise indicated.

SECTION 03200 – CONCRETE REINFORCEMENT

- D. All protruding reinforcement, onto which construction personnel could fall, shall be guarded to eliminate the hazard of impalement.
- E. Splice steel to conform to Chapter 12 of ACI 318.
 - 1. Unless otherwise indicated, lap splices shall be Class B as defined by ACI 318.
- F. Lap welded wire fabric in accordance with Section 12.19 of ACI 318, but not less than the length of one mesh plus 2 inches.

END OF SECTION 03200

SECTION 03300 – CONCRETE

PART 1 - GENERAL

1.01 SUMMARY

- A. This Section includes concrete and related items.
- B. Related Work Specified Elsewhere:
 - 1. Concrete Reinforcement: SECTION 03200.

1.02 REFERENCES

- A. Comply with the provisions of the following codes, specifications, and standards, except as otherwise indicated.
- B. Applicable Standards Where Referenced Herein:
 - 1. American Society for Testing and Materials (ASTM):
 - a. C31 - Making and Curing Concrete Test Specimens in the Field.
 - b. C33 - Concrete Aggregates.
 - c. C39 - Compressive Strength of Cylindrical Concrete Specimens.
 - d. C40 - Organic Impurities in Fine Aggregates for Concrete.
 - e. C88 - Soundness of Aggregates by Use of Sodium Sulfate or Magnesium Sulfate.
 - f. C94 - Ready-Mixed Concrete
 - g. C143 - Slump of Hydraulic-Cement Concrete.
 - h. C150 - Portland Cement.
 - i. C172 - Sampling Freshly Mixed Concrete.
 - j. C192 - Making and Curing Concrete Test Specimens in the Laboratory.
 - k. C231 - Air Content of Freshly Mixed Concrete by the Pressure Method.
 - l. C233 – Air-Entraining Admixtures for Concrete.
 - m. C260 - Air-Entraining Admixtures for Concrete.
 - n. C289 – Potential Alkali-Silica Reactivity of Aggregates, (Chemical Method).

SECTION 03300 – CONCRETE

- o. C295 - Petrographic Examination of Aggregates for Concrete.
 - p. C309 - Liquid Membrane-Forming Compounds for Curing Concrete.
 - q. C494 - Chemical Admixtures for Concrete.
 - r. C566 - Total Evaporable Moisture Content of Aggregate by Drying.
 - s. C1193 - Use of Joint Sealants.
 - t. D1751 - Preformed Expansion Joint Fillers for Concrete Paving and Structural Construction. (Non-extruding and Resilient Bituminous Types).
 - u. D1752 - Preformed Sponge Rubber Cork and Recycled PVC Expansion Joint Fillers for Concrete Paving and Structural Construction.
2. American Concrete Institute (ACI):
- a. 211.1 - Practice for Selecting Proportions for Normal, Heavyweight and Mass Concrete.
 - b. 304 - Practice for Measuring, Mixing, Transporting, and Placing Concrete.
 - c. 305 - Hot-Weather Concreting.
 - d. 306 – Standard Specification for Cold-Weather Concreting.
 - e. 308 – Standard Specification for Curing Concrete.
 - f. 309 - Guide for Consolidation of Concrete.
 - g. 318 – Building Code Requirements for Structural Concrete.
3. Concrete Plant Mixer Standards of the Plant Mixer Manufacturers Bureau.
4. Concrete Plant Standards of the Concrete Plant Manufacturers Bureau.
5. Corps of Engineers Specification for Non-Shrink Grout, CRD-C621.
6. National Bureau of Standards (NBS) Specifications for Scales.
7. National Ready-Mix Concrete Association, "Truck Mixer, and Agitator Standards of the Truck Mixer Manufacturers Bureau."

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.

SECTION 03300 – CONCRETE

B. Include, but not limited to, product data and Shop Drawings of the following:

1. Non-shrink grouts.
2. Admixtures.
3. Bonding agents.
4. Curing agents.
5. Expansion joint materials.
6. Expansion joint sealants.
7. Water stops.

C. Mill Certificates:

1. Submit a minimum of one copy for each cement shipment.

D. Concrete Mix Design Proportions:

1. Submit as specified in PART 2 - Mix Proportions, this Section.
2. Submit for each mix design.
3. Resubmit for any change in each mix design.

E. Production Test Reports: Submit as specified in accordance with the submittal section.

1.04 QUALITY ASSURANCE

A. Field Testing:

1. Tests of concrete shall be performed by an ACI concrete Field Testing Technician Grade 1.
2. Submit two certified copies of the qualification records as evidence of qualification prior to placing concrete.

B. Finishing:

1. Finishing of concrete shall be supervised by an ACI Concrete Flatwork Technician/Finisher.
2. Submit two certified copies of qualification records as evidence of qualification prior to placing concrete.

SECTION 03300 – CONCRETE

PART 2 - PRODUCTS

2.01 CONCRETE

A. Materials:

1. Portland cements Type II. Type II shall conform to ASTM C150 except the tricalcium aluminate content shall not exceed 5%.
2. Fine Aggregate:
 - a. Conform to ASTM C33.
 - b. Approved service record of 3 years with a history indicating that the fine aggregate is not chemically reactive.
 - c. For a new fine aggregate source, or when 3 years' approved service records are not available, or when the service records are unacceptable; the aggregate shall be evaluated for potential reactivity. Aggregate must be considered innocuous in accordance with petrographic examination by ASTM C295 and tests conforming to ASTM C289.
 - d. Fine aggregate considered deleterious or potentially deleterious shall not be used without approval.
 - e. Maintain fine aggregate free of ice and frozen lumps.
3. Coarse Aggregate:
 - a. Conform to ASTM C33.
 - (1) Limits for deleterious substances and physical property requirements shall conform to Table 3 and applicable class designation 5S, 5M, or 1N.
 - b. Approved service record of 3 years with a history indicating that the coarse aggregate is not chemically reactive.
 - c. For a new coarse aggregate source, when 3 years' approved service records are not available, or when the service records are unacceptable; the aggregate shall be evaluated for potential reactivity. Aggregate must be considered innocuous in accordance with petrographic examination by ASTM C289.
 - d. Coarse aggregate considered deleterious or potentially deleterious shall not be used without approval.
 - e. Blast furnace slag shall not be permitted.

SECTION 03300 – CONCRETE

f. Maintain coarse aggregate free of ice and frozen lumps.

g. Grading Requirements:

(1) From 1 inch to No. 4 for all concrete unless otherwise specified.

4. Mixing Water:

a. Only potable water will be acceptable without testing. The Contractor shall pay expense of testing water.

b. Non-potable water may be used if it produces concrete with at least 95% of the strength of similar specimens of the same mix design made with potable water, subject to approval of qualitative analysis.

5. Admixtures:

a. Water-Reducing Type:

(1) Conform to ASTM C494, Type A.

(2) Conform to manufacturer's recommendations for use.

(3) Technical assistance of the manufacturer's field representative shall be furnished upon request.

b. Air-Entraining Type:

(1) Conform to ASTM C260.

(2) Conform to manufacturer's recommendations for use.

(3) Technical assistance of the manufacturer's field representative shall be furnished upon request.

(4) Testing of air-entraining admixtures shall conform to ASTM C233.

c. Other Admixtures: Used only with Engineer's written concurrence.

(1) Water-Reducing, Retarding Type: Conform to ASTM C494, Type D, and shall not contain any chloride ions added during manufacture.

d. Storage:

(1) Admixtures shall be stored in such a manner as to avoid contamination, evaporation, freezing, temperature changes, settling, or any damage which would adversely affect their characteristics.

SECTION 03300 – CONCRETE

B. Laboratory Testing of Materials for Use in Concrete:

1. An approved independent testing laboratory shall be selected and paid by the Contractor to perform all required laboratory tests of materials proposed for use in the production of concrete and to determine mix proportions when laboratory trial batches are required.
2. Contractor shall deliver representative Samples of all proposed concrete materials to the laboratory for the following testing:
 - a. Fine Aggregate:
 - (1) ASTM C33.
 - (2) ASTM C40.
 - (3) ASTM C88.
 - b. Coarse Aggregate:
 - (1) ASTM C33.
 - (2) ASTM C88.
 - c. Mixing water, if other than potable water is proposed for use and in the opinion of the Engineer there is reason to suspect its acceptability:
 - (1) With the design mix the laboratory shall make two Concrete test cylinders using proposed water and two concrete test cylinders using potable water conforming to ASTM C192.
 - (2) All cylinders shall be tested conforming to ASTM C39. Age of cylinders at test shall be 28 days unless an earlier age is authorized by the Engineer.
3. The laboratory test results shall be part of the design mix as specified in this PART 2 Mix Proportions, this Section.

C. Concrete Qualities Required:

1. Compressive Strength:
 - a. Minimum 28-day compressive strength = 4,000 psi for all construction unless otherwise indicated or specified.
 - b. Minimum 28-day compressive strength = 3,000 psi for fill concrete and seal coats.
 - c. Compressive strength determinations shall be made from 6" diameter x 12" long concrete cylinders tested in accordance with ASTM C39.

SECTION 03300 – CONCRETE

2. Slump of concrete shall be 3 inches, ± 1 inch as tested in accordance with ASTM C143.
3. Air Content: 5% to 7% as tested in accordance with ASTM C231.
4. Minimum Cement Content: 564 pounds per cubic yard of concrete.
5. Water-Cement Ratio:
 - a. In addition to the aforementioned requirements, the water-cement ratio shall not exceed 0.45.

D. Mix Proportions:

1. Concrete shall be proportioned to conform to ACI 211.1.
2. Mix proportions for all concrete, unless otherwise specified, shall be selected preferably on the basis of field experience; but in the case where sufficient or suitable strength test data is not available; concrete shall be proportioned on the basis of laboratory trial mix design.

E. Measurement of Materials:

1. General Requirements:
 - a. Conform to ACI 304.
 - b. Beam or spring-less dial-type scale conforming to NBS "Specifications for Scales".
 - c. Volumetric measurement of water shall be performed with an approved automatic valve.
2. Concrete Plant Scale Accuracy and Calibration Frequency:
 - a. The concrete plant scales shall be accurate to $+0.4\%$ of the capacity of the scale.
 - b. The scales shall be calibrated at intervals as specified in PART 3 - Testing, this Section.
3. Individual Batch Accuracy:
 - a. Cement: $\pm 1.0\%$.
 - b. Water: $\pm 1.0\%$ by volume or weight.
 - c. Aggregates: $\pm 2.0\%$.
 - d. Admixtures: $\pm 3.0\%$ by volume or weight.
 - e. Mixing and Delivery:
 - (1) Conform to ACI 304.

SECTION 03300 – CONCRETE

- (2) Cement temperature, when added to mix, shall not exceed 170°F.
- (3) Adjust the amount of mix water to compensate for the moisture content of the aggregates.
- (4) Concrete Plant:
 - (a) Conform to “Concrete Plant Mixer Standards of the Plant Mixer Manufacturers Division Concrete Plant Manufacturers Bureau” and “Concrete Plant Standards of the Concrete Plant Manufacturers Bureau”.
 - (b) Charge with 5% to 10% of the mixing water both in advance and after the addition of aggregates and cement.
 - (c) Charge with remaining water uniformly with the other materials.
 - (d) Avoid charging in excess of manufacturer’s rating.
 - (e) Discharge mixed concrete completely prior to recharging.
 - (f) Mixing Time:
 - i. Start immediately when all ingredients, except the last of the water, are in the mixer.
 - ii. Minimum mixing time shall conform to mixer manufacturer’s instructions, but not be less than the following:

<u>Capacity of Mixer Cubic Yards</u>	<u>Minimum Time of Mixing</u>
1 or less	1 minute
2	1 minute, 15 seconds
3	1 minute, 30 seconds
4	1 minute, 45 seconds
5	2 minutes
6	2 minutes, 15 seconds

Add 15 seconds’ mixing time for each additional cubic yard of concrete

- (5) Mixing of Concrete at Plant off Jobsite:
 - (a) Mix concrete in central mixer or truck mixer. Transport in truck mixer turning at agitation speeds only.

SECTION 03300 – CONCRETE

- (b) Water added to concrete having a slump below the specified minimum shall be at Contractor's risk. If the water added produces a slump greater than the specified maximum, the concrete will be rejected. If water is added, the concrete shall be remixed for a minimum of 25 revolutions.
- (c) Water shall not be added after the truck has begun to discharge.
- (d) Truck mixer shall conform to "Truck Mixer and Agitator Standards of the Truck Mixer Manufacturers Bureau" of the National Ready-Mix Concrete Association.
- (e) Ready-mixed concrete shall be produced and delivered conforming to ASTM C94 as applicable.
- (f) Contractor shall furnish City/Engineer with a concrete delivery ticket for each load of concrete. The ticket shall have the following information recorded:
 - i. Name of ready-mixed concrete batch plant.
 - ii. Serial number of ticket.
 - iii. Date and truck number.
 - iv. Name of contractor.
 - v. Specific designation of the job (name and location).
 - vi. Mix number.
 - vii. Amount of concrete delivered (cu yd).
 - viii. Time mixer was loaded.
 - ix. Time of arrival at site.
 - x. Time discharge started.
 - xi. Time completed delivery.
 - xii. Amount of water added by Contractor and his initials.
 - xiii. Signature of ready-mix concrete representative.
 - xiv. Type, name and volume of admixture.
 - xv. Type and brand of cement.
 - xvi. Maximum size of aggregate.
 - xvii. Free water on the aggregate.
 - xviii. Indication that all materials are as previously certified or approved.
 - xix. The delivery ticket shall be supplemented by a computerized printout for each batch (from an automatic printing unit incorporated in the batching system) containing actual weights of all materials delivered including cement, water, and coarse and fine aggregate.

- (6) Plant and truck mixer uniformity shall be tested according to ASTM C94. Frequency of tests shall be as specified in PART 3, this Section.

2.02 GROUT

A. Grout for Dry Packing:

- 1. Volume: 1 part Portland cement to 2 parts sand.

SECTION 03300 – CONCRETE

2. Keep water to a minimum as required for placing by the dry packing method.
3. Place after the mixed grout has been allowed to stand for 2 hours.
4. The sand and cement shall be as specified for concrete.

B. Flowable Non-Shrinking Grout:

1. Use unless otherwise indicated or specified.
2. Required for setting equipment recommended by the manufacturer to be set with non-shrinking grout and in other places indicated.
3. Grout shall conform to Corps of Engineers specification for Non-Shrink Grout, CRD-C621.
4. Grout shall be nonmetallic, as manufactured by one of the following:
 - a. L and M Construction Chemicals, Inc. - Crystex.
 - b. U. S. Grout Corporation - Five Star Grout.
 - c. Master Builder's Company - Masterflow 713 Grout.
 - d. Sauereisen Cements Company - Sauereisen F-100.
 - e. Cormix Construction Chemicals - Supreme Grout.
5. Prepare and place conforming to manufacturer's printed instructions.
6. For equipment bases, the concrete surfaces shall be sandblasted or roughened with a chipping hammer prior to grouting. The foundation plates shall be cleaned of any grease, oil, paint, primers, or epoxy coatings.

C. Grout for Bonding:

1. Proportion (by weight): 1-part cement to 1-1/2 parts sand.
2. Keep water to a minimum.

2.03 BONDING AGENT

- A. Provide moisture-insensitive, epoxy-resin bonding agent as manufactured by one of the following:
 1. A. C. Horn, Inc. - Epoxitite.
 2. Euclid Chemical Company - Euco Epoxy.

SECTION 03300 – CONCRETE

3. Sika Chemical Company - Sikadur 32, Hi-Mod.
4. L&M Construction Chemicals, Inc. - Epobond.

2.04 CONCRETE ACCESSORIES

A. Water stops:

1. Serrated virgin polyvinyl chloride equal to one of the following:
 - a. Tamma Industries - Horn/Durajoint Type 3.
 - b. Vulcan Metal Products Company - Vulco 8013.
2. Plastic Water stop: Preformed plastic water stop as manufactured by SYNKO-FLEX Products Co., Houston, Texas.

B. Expansion Joints:

1. Expansion Joint Filler: Pre-molded cork of thickness indicated and conforming to ASTM D1752, Type III, self-expanding cork. Use at all locations unless indicated to be asphalt-impregnated fiber.
2. Expansion Joint Filler: Preformed asphalt-impregnated fiber of thickness indicated and conforming to ASTM D1751.
3. Bond Breaker: Polyethylene tape or other plastic tape as recommended by the sealant manufacturer for preventing sealant from adhering to joint filler materials or joint surfaces at the bottom of joint where such adhesion would result in sealant failure.
4. Sealant Backer Rod (closed cell, compatible with sealant):
 - a. Bostick Construction Products Division.
 - b. Chem-Calk - Backer Rod.
 - c. Dow Chemical Company - Ethafoam.
 - d. Hercules Foam Backer Rod.
 - e. Sonneborn Building Products - Sonofoam.
 - f. W. R. Meadows - Sealtight Backer Rod.

SECTION 03300 – CONCRETE

5. Joint Sealant:

a. Two-component polysulfide system as manufactured by one of the following:

(1) A. C. Horn, Inc. - Hornflex L.

(2) Pecora, Inc. - Synthacalk GC-2.

2.05 CURING AGENT

- A. Liquid membrane-forming compound conforming to ASTM C309, Type 1. Curing agent shall be VOC compliant with a maximum of 3.5 lbs/gal (425 g/l) or less where area regulations are more stringent. ASTM C309, Type 2 shall be used as specified in PART 3 - Hot Weather Concreting, this Section.

PART 3 - EXECUTION

3.01 PREPARATION FOR CONCRETE PLACEMENT

- A. Openings Through Concrete: Provide openings through concrete as indicated and for the proper installation of all equipment, piping, wiring, ductwork and similar items installed included in the Work.
- B. Installation of Embedded Items:
1. Provide for accurate installation of embedded items included in the Work.
 2. During cold weather, protect embedded items from moisture which may freeze, expand, and crack the concrete structure.
 3. Grease or tape anchor bolt threads to protect from concrete splatter.
- C. Installation of Joints:
1. Construction Joints:
 - a. Location:

(1) Joints shall be located as shown on the plans or standard drawings.
 - b. Preparation and Installation:
 - (1) Clean and break laitance or other foreign material from bonding surface.
 - (2) Tighten forms remaining in place (where applicable) to prevent seepage between forms and hardened concrete.

SECTION 03300 – CONCRETE

(3) Provide water stops and shear keys as indicated or specified and as required in any new construction joint requested by Contractor.

c. Water stops:

(1) Install conforming to manufacturer's standard installation instructions.

(2) All joints and splices of PVC water stop shall be 100% fused.

2. Expansion Joints:

- a. Install filler, backer rod and sealant in strict conformance with manufacturer's written instructions.
- b. Reinforcing shall not extend through expansion joints unless indicated otherwise.
- c. Attach rigid joint filler to the face of the joint prior to placing adjacent concrete. The filler shall occupy the entire width of the joint.
- d. Install sealant backer rod for sealant except where indicated to be omitted. Install bond breaker where indicated.
- e. Clean joint surfaces immediately before application of sealant.
- f. Install joint sealants to conform to ASTM C1193. Tool sealant to provide smooth, uniform bead with a slightly concave surface, eliminate air pockets, and insure sealant contact and adhesion with sides of joint.
- g. Protect joints from moisture and ice during freezing.

3. Contraction Joints: As specified in this PART 3 - Finishing, this Section.

3.02 PLACING OF CONCRETE

A. Conventional Placing:

1. General Requirements:

- a. Conform to ACI 304.
- b. Bonding surfaces, including reinforcement, shall be clean, free of laitance and foreign materials.
- c. Face horizontal bonding surfaces with 1-inch-thick coat of fresh "grout for bonding". Wet all other surfaces.

SECTION 03300 – CONCRETE

- d. Place concrete on properly prepared and unfrozen sub grade and only in dewatered excavation and forms.
- e. Use forms for all concrete except where otherwise indicated or specified.
- f. Do not place concrete that has partially hardened or has been contaminated by foreign materials.
- g. Prevent mud or foreign materials from entering the concrete or forms during placement operations.
- 2. Conveying:
 - a. Convey concrete from the mixer and deposit in place by methods which will prevent the segregation or loss of materials.
 - b. Equipment for chuting, pumping, and pneumatically conveying concrete shall be of such size and design as to provide a practically continuous flow of concrete at the delivery end.
 - c. Aluminum conveying equipment shall not be used.
- 3. Depositing:
 - a. Place concrete in continuous horizontal lifts not to exceed 2 feet, and place concrete against bulkheads and keyways at vertical joints.
 - b. Maximum free drop of concrete and grout for bonding shall be 5 feet, in walls 10 inches or less in thickness, with 1-foot additional drop allowed for each inch of wall thickness over 10 inches, with a maximum drop of 10 feet.
 - c. When moisture barrier is used, keep lapped joints closed and take precautions to avoid puncturing the barrier.
- 4. Consolidation of Concrete:
 - a. Consolidate concrete in conformance with ACI 309. Characteristics and application of concrete vibrators shall be as set forth in Table 5.1.4.
 - b. Provide an adequate number of vibrators of sufficient capacity to keep up with the maximum rate of concrete placement. Keep on hand adequate standby equipment in good operating condition.
 - c. Vibrate concrete only until the concrete is thoroughly consolidated and the voids filled, as evidenced by the leveled appearance of the concrete at the exposed surface and the embedment of the surface aggregate.

SECTION 03300 – CONCRETE

- d. Insert internal vibrators vertically to the full depth of the layer being placed and into the previous layer. Do not drag vibrators through the concrete. Insert and withdraw vibrator slowly with the vibrator running continuously so that no hole will be left in the concrete. Do not flow concrete from one location to another by use of a vibrator.
- e. Consolidate concrete layer to full depth when using a surface vibrator. Use thinner layers or a more powerful vibrator if necessary to achieve complete consolidation.
- f. Use form vibrators only where sections are too thin or where sections are inaccessible for internal vibrators.

5. Time Requirements:

- a. Place concrete at a sufficient rate to assure that lifts below have not taken initial set before fresh concrete is deposited.
- b. Place concrete within 45 minutes after mixing. This period may be extended to 1 hour and 30 minutes provided that the combined air temperature, relative humidity, and wind velocity are such that the plasticity of the fresh concrete is satisfactory for placement and consolidation, and that the specified mixing water is not exceeded. Concrete which has partially set shall not be re-tempered but shall be discarded.

6. Placing Concrete at Joints:

- a. Bed horizontal joints with 1 inch of grout for bonding.
- b. Take precautions to ensure tight, well-bonded construction joints with no air pockets or voids.
- c. Take special precautions to avoid bending or displacing water stop while placing concrete around it.
- d. Delay construction at a joint a minimum of 16 hours where placement is continued past joint, except where otherwise indicated.

3.03 FINISHING

A. Unformed Surfaces:

1. Screed Finish:

- a. Use as first stage for all concrete finishes.
- b. Use as final finish on surfaces that will be covered by additional concrete, grout placement, or mortar setting bed except as otherwise specified.

SECTION 03300 – CONCRETE

- c. Immediately after screening, use a wood float, darby, or bull float to eliminate high and low spots and to embed large aggregate. This shall be done in a manner to produce even, uniform surfaces so that surface irregularities do not exceed 3/8 inch in 10 feet when used as final finish.

2. Floated Finish:

- a. Use as second stage of broomed, troweled, or magnesium-troweled finish.
- b. Float with mechanical float. Hand floating will be permitted only in areas inaccessible to mechanical float.
- c. On surfaces not to receive troweled or magnesium-troweled finish, finish with wood or cork float after mechanical floating to a true uniform surface so that surface irregularities do not exceed 1/8 inch in 10 feet, except at floor drains.

3. Broomed Finish:

- a. Use as final finish on all outdoor slabs including pavements and sidewalks.
- b. After floated finish, draw a stiff bristle broom across the surface making uniform corrugations, perpendicular to the direction of traffic, not more than 1/16 inch deep.

4. Troweled Finish:

- a. Use as final finish on all other unformed surfaces not otherwise indicated or specified.
- b. Trowel with steel trowel, mechanical or hand, to obtain a smooth, dense finish. The final troweling shall be done after the concrete has become hard enough so that no mortar adheres to the edge of trowel and a ringing sound is produced as the trowel passes over the surface.
- c. Do not trowel before surface water has evaporated or has been removed with a squeegee.
- d. Finish to a true uniform surface so that surface irregularities do not exceed 1/8 inch in 10 feet, except at floor drains.
- e. Do not add sand or cement to the floor surface.

5. Magnesium-Troweled Finish:

- a. Perform as specified in PART 3 - Troweled Finish, this Section, except use a magnesium trowel by hand instead of a steel trowel to obtain a dense, but not slick, finish.
- b. Use where floor will receive protective coating after curing.

SECTION 03300 – CONCRETE

6. Contraction Joints:

- a. Locate as indicated.
- b. Maintain true alignment with straightedge.
- c. Joints shall be grooved except where sawed joints or preformed joints are indicated.
- d. Grooved Joints:
 - (1) Perform during the finishing process.
 - (2) Width of groove shall not exceed $\frac{1}{4}$ inch.
 - (3) Depth of groove shall be at least 1 inch or $\frac{1}{4}$ of slab thickness.
- e. Sawed Joints:
 - (1) Cut joints with power blade as soon as concrete surface is firm enough to resist tearing or damage by the blade and before random shrinkage cracks can occur. (Usually required 4 to 12 hours after finishing.)
 - (2) Make joints approximately 1/8-inch-wide with depth as indicated.
 - (3) Seal with the same type sealant specified for expansion joint sealant.

B. Formed Surfaces:

1. Repair surface defects as specified in PART 3 -Repair of Defective Surfaces, this Section.

C. Repair of Defective Surfaces:

1. Defined as any concrete surface showing misalignment, rock pockets, poor joints, holes from ties, voids, honeycomb, or any other defective area.
2. Repairing:
 - a. Repair as soon as forms have been removed.
 - b. Chip surface back to minimum depth of $\frac{1}{2}$ inch, chip edges perpendicular to surface, pre-wet depression and brush with neat cement immediately before patching.
 - c. Patch surfaces using stiff mortar with same sand-cement ratio as original concrete and with minimum water for placing. Blend with white cement to match concrete color.
 - d. Compact mortar into depressions so that after curing, hole is filled and mortar is flush with surface. Use hammer and ramming rod for compacting the holes.

SECTION 03300 – CONCRETE

- e. Moist-cure for 3 days or use curing compound.
- f. City/Engineer shall be notified of areas containing defects or where reinforcing Steel is exposed, prior to determination of repair method.

3.04 CURING

- A. Cure all concrete by one of the following methods in accordance with ACI 308:
 - 1. Leaving in forms for a minimum of 7 days. Keep formwork wet to prevent drying of concrete surfaces.
 - 2. Use of saturated bats, soaker hoses, or sprinkler for a minimum of 7 days. Keep concrete continuously wet.
 - 3. Using one coat of a liquid membrane forming compound conforming to ASTM C309, Type 1. Apply immediately after removal of forms (which have been continuously wet); or in case of a slab, after the concrete has been finished and is hardened sufficiently to walk-on.
 - 4. Using polyethylene sheets applied in full contact with surfaces.
 - 5. Curing of concrete during hot or cold weather shall conform to PART 3 - Hot Weather Concreting and Cold Weather Concreting, this Section.

3.05 HOT WEATHER CONCRETING

- A. Follow the recommendations of ACI 305 if any of the following conditions occur:
 - 1. When the temperature is 90°F or above.
 - 2. When the temperature is likely to rise above 90°F within the 24-hour period after concrete placement.
 - 3. When there is any combination of high air temperature, low relative humidity, and wind velocity, which would impair either concrete strength or quality.
- B. Concrete shall have a maximum temperature of 85°F during placement.
- C. Dampen sub grade and forms with cool water immediately prior to placement of concrete.
- D. Protect freshly placed concrete immediately after placement so that the rate of evaporation as determined by ACI 305 (Figure 2.1.5) does not exceed 0.2 pound per square foot per hour.
- E. Protect concrete with suitable insulation if rapidly decreasing nighttime temperatures occur, which would cause thermal shock to concrete placed during warm daytime temperatures.
- F. Protect the concrete with temporary wet covering during any appreciable delay between placement and finishing.

SECTION 03300 – CONCRETE

- G. Begin curing unformed surfaces immediately after finishing and continue for 24 hours. Curing shall consist of application and maintenance of water-saturated material to all exposed surfaces; horizontal, vertical, and otherwise. After the 24-hour interval, continue curing using one of the following methods:
1. Moist curing for 6 days.
 2. Application of one coat of curing compound conforming to ASTM C309, Type 2.
 3. Application and maintenance of curing paper or heat-reflecting plastic sheets for 6 more days.
- H. Begin curing formed concrete immediately after placing. Curing shall consist of keeping forms continuously wet for 24 hours. Thereafter, continue curing using one of the following methods:
1. Loosen forms and position soaker hose so that water runs down along concrete surfaces. Continue for 6 days.
 2. Strip forms and apply curing compound conforming to ASTM C309, Type 2. Do not allow concrete surfaces to dry prior to application of curing compound.

3.06 COLD WEATHER CONCRETING

- A. When the temperature is 40°F or is likely to fall below 40°F during the 24-hour period after concrete placement, follow the recommendations of ACI 306 to prevent loss of concrete strength or quality.
- B. Minimum temperature for concrete as mixed shall be as indicated on lines 2, 3, and 4 of Table 1.4.1 of ACI 306. Maximum temperature for concrete as mixed shall be 10°F greater than the corresponding minimum temperature.
- C. Place and maintain concrete so that its temperature is never less than the temperature indicated on line 1 of Table 1.4.1 of ACI 306. Maintain the required temperature for the time duration indicated on Table 1.4.2 of ACI 306.
- D. Monitor temperature of concrete in place at corners or edges of formwork as applicable.
- E. Air Heaters:
1. Do not expose concrete to carbon monoxide or carbon dioxide fumes from heaters or engines.
 2. Oil-or coke-burning salamanders will not be permitted.
 3. Heaters shall be ultramatic portable heaters made by the Union Chill Mat Company or City/Engineer approved equal.

SECTION 03300 – CONCRETE

- 4. Personnel shall be present at all times to maintain safe, continuous operation of heating system.
- F. Control temperature and humidity of protected concrete so that excessive drying of concrete surfaces does not occur.
- G. Calcium chloride will not be permitted as a concrete accelerator or to thaw frozen sub grade prior to concrete placement.
- H. The maximum allowable temperature drop during the first 24-hour period after protection is discontinued shall be as indicated on line 5 of Table 1.4.1 of ACI 306.
- I. Cure the concrete in accordance with Chapter 5 of ACI 306.

3.07 LOW-STRENGTH CONCRETE

A. Low-Strength Concrete:

- 1. Defined as either:
 - a. Concrete whose average, of any sets of three consecutive 28-day strength tests, is below the required 28-day strength.
 - b. Concrete whose individual 28-day strength test (average of two cylinders) is more than 500 psi below the required 28-day strength.
- 2. Should concrete meet either definition of low-strength concrete as a minimum, the Contractor shall take the following steps:
 - a. Increase the cement content. The increase shall be based on a statistical evaluation of the strength data, the design water-cement ratio, compressive strength curve, and acceptable mix-design literature as follows:
 - (1) If sufficient concrete has been furnished to accumulate 30 tests, these should be used to establish a new target average strength in accordance with ACI 318, Section 4.3.1.
 - (2) If less than 30 tests have been made, the new target average strength should be at least as great as the average strength used in the initial selection of the mix proportions. Increase the target average strength based on a statistical evaluation of the available strength data, the design water-cement ratio, compressive-strength curve, and acceptable mix-design literature. If the statistical average equals or exceeds the initial mix-design level, a further increase in the average level is required.

SECTION 03300 – CONCRETE

- b. Remove and replace with acceptable concrete when the quality and location of the concrete is such that City/Engineer considers the strength or durability of the structure is impaired and so orders.

B. Potentially Low-Strength Concrete: Defined as concrete whose 7-day test (average of two cylinders) is less than 70% of the specified minimum 28-day compressive strength.

3.08 MISCELLANEOUS CONCRETE ITEMS

A. Concrete Seal Coat:

1. Apply to the ground surface immediately beneath all "on-grade" slabs and footings where indicated or specified.
2. Seal coat shall consist of a concrete slab of the thickness indicated but not less than 2 inches.
3. Accurately screed so that the top of the seal coat will not be higher than the bottom elevation of structural slabs or footings to be placed thereon.
4. Do not place seal coat until after all excavating in the area have been completed and all drain lines, conduits, and other items under the area are completed and properly backfilled and compacted.

B. Equipment Bases:

1. Construct equipment bases, pads, and foundations as indicated or, when not indicated, conforming to equipment manufacturer's requirements.
2. Reinforce conforming to typical detail unless otherwise indicated.
3. Equipment bases shall include concrete, reinforcing steel, form work as required, and anchor bolts. Place grout for equipment included in the Work.
4. Finish top area of bases between anchor bolts and forms with a troweled finish.

3.09 TESTING

A. Field Testing of Concrete Plant and Mixing Trucks:

1. The concrete plant shall be inspected and tested to ensure conformance with ACI 304 and the "Concrete Plant Standards of the Concrete Plant Manufacturers Bureau". The scales shall be calibrated at the initial setup and at 3-month intervals thereafter.
2. Mixing trucks shall be inspected and tested to ensure conformance with ACI 304 and "Truck Mixer and Agitator Standards of the Truck Mixer Manufacturers Bureau" of the National

SECTION 03300 – CONCRETE

Ready-Mix Concrete Association. Tests shall be done at initial setup and every three months thereafter.

3. Submit test reports when requested.

B. Field Testing of Concrete and Making of Concrete Test Cylinders:

1. Contractor shall furnish on request test equipment, test cylinder molds, and certified personnel to perform all required field tests, make the required concrete test cylinders, and deliver test cylinders to the testing laboratory. The prescribed tests shall be made in the presence of or with the concurrence of the City.
2. Field testing personnel shall be on-site throughout placement of concrete.
3. Concrete sampling for tests and cylinder making shall be done conforming to ASTM C172 except samples for slump, air and temperature tests shall be taken from the first portion of the batch discharge. Samples shall be taken at random and at the point of truck discharge.
 - a. Moisture content, ASTM C566. Perform this test a minimum of twice a day and adjust the amount of mix water to compensate for the moisture content of the aggregates.
 - b. Prepare test cylinders conforming to ASTM C31, with not less than one set of cylinders (four cylinders) from each day's placement for each 100 cubic yards or fraction thereof.
 - c. Slump test conforming to ASTM C143. Perform tests on the first batch produced each day, for every 50 cubic yards or fraction thereafter, and with every set of test cylinders. Additional tests shall be run when directed by Engineer.
 - d. Air content test conforming to ASTM C231. Perform for first batch of day and with each set of test cylinders.
 - e. The batch of concrete being tested for slump or air content shall not be placed until acceptable results are obtained.
 - f. Discard concrete used for slump and air tests.
 - g. Perform concrete and air temperature tests for first batch of day and with each set of test cylinders. Additional readings shall be taken when directed by City/Engineer.
 - h. Any batch of concrete with slump or air content not in conformance with Specifications shall be rejected.
 - i. Furnish slump, air content, and temperature test results to the testing laboratory for inclusion in the cylinder test reports.

SECTION 03300 – CONCRETE

C. Laboratory Testing of Aggregates and Concrete During Construction:

1. An independent testing laboratory will be selected and paid by the Developer/Owner to perform the required laboratory tests and statistical evaluations of aggregates and concrete being used in the Work.
2. Laboratory will cure and test concrete cylinders conforming to ASTM C192 and C39, testing two cylinders at 7 days of age and two at 28 days of age.
3. Contractor shall have the right to observe all phases of concrete cylinder curing and testing. Should Contractor observe any deviations from the prescribed testing procedures that he considers detrimental to concrete strength test results, he shall immediately notify Developer/Owner in writing.
4. Contractor shall assist laboratory in obtaining Samples of fine and coarse aggregate for testing.
5. The Contractor shall make arrangements with the testing laboratory to receive copies of test reports. The cost of providing a maximum of two copies of each report to the Contractor will be paid by the Developer/Owner.
6. Should the test results indicate low strength concrete as defined in PART 3 – Low Strength Concrete, this Section, Contractor shall take immediate corrective action.
7. Should the statistical data indicate an excessive margin of safety, the concrete mix may be modified subject to City/Engineer's approval.
8. Should the material tests taken during construction indicate nonconformance with the Specifications, the Contractor shall take immediately corrective action.

END OF SECTION 03300

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

PART 1 – GENERAL

1.01 SUMMARY

- A. This section covers furnishing and installing submersible wastewater pumping stations and related components for lift stations with a capacity less than one million gallons per day (1 MGD) or less than a size deemed appropriate by the City for a particular application. Future discharge to the proposed lift station shall be taken into account during design and shall be considered when determining the ultimate capacity of the proposed lift station.
- B. Pumping stations shall be:
 - 1. Capable of pumping raw wastewater and be of the duplex type.
 - 2. Furnished complete and include pump casings, shafts, bearings, seals, lubrication, floor mounted discharge bases, piping assemblies, guide rails, anchor bolts, stainless steel bolts, submersible motors, controls, power cables, access hatch cover and all other parts and accessories indicated, specified or required for proper installation, operation and maintenance.
- C. Related Work Specified Elsewhere:
 - 1. Site Preparation and Earthwork: Section 02200.
 - 2. Manholes and Wet wells: Section 02605.
 - 3. Pipe Installation and Testing: Section 02620.
 - 4. Valves, Hydrants and Accessories: Section 02640.
 - 5. Chain-Link Fences and Gates: Section 02831.
 - 6. Concrete: SECTION 03300.
- D. See details in the Standard Drawing Details.

1.02 REFERENCES

- A. Applicable Standards:
 - 1. American National Standards Institute (ANSI).
 - a. B16.1 - Cast Iron Pipe Flanges and Flanged Fittings.
 - b. 316 – Stainless Steel Round Bar.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

2. American Society for Testing and Materials, (ASTM).
 - a. A-48 – Gray Iron Castings.
3. National Electrical Manufacturer's Association (NEMA).
 - a. NEMA Type 4 Enclosures.
 - b. NEMA Type 1 Enclosures.
 - c. MG-1 Motors and Generators.
 - d. Class H Insulation
4. Institute of Electrical and Electronics Engineers (IEEE).
5. Underwriters Laboratories.
 - a. UL-508 – Industrial Control Equipment.
 - b. UL-1008 – Transfer Switch Equipment.
6. National Electrical Code.
7. International Organization for Standardization.
8. National Fire Protection Association.
9. International Electrotechnical Commission.

B. Regulations

1. Missouri Department of Natural Resources
 - a. 10 CSR 60-11.010(3)(A) – Backflow Prevention Methods
 - b. 10 CSR 60-11.010(4) – Backflow Prevention Methods

1.03 SUBMITTALS

- A. Submit as specified in accordance with the submittal section.
- B. Submittals shall include, but not be limited to, the following:
 1. Equipment submittals as specified in accordance with the submittal section.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

2. Standard performance curves for each pump model furnished. Curves shall cover range from shutoff to 150% of design flow rate at the conditions specified, and shall be submitted for the following parameters as a function of pump capacity:
 - a. Total developed head.
 - b. Required brake horsepower.
 - c. Pump efficiency.
 - d. Required wire-to-water horsepower.
 - e. Minimum nameplate horsepower with 1.15 derating factor (excluding motor S.F.).
 - f. Required NPSH.
 - g. Minimum recommended submergence.
3. Shop drawings shall be submitted showing materials and assembly of all elements of the pumping station. In addition to pump and motor data to be submitted descriptive literature shall clearly indicate all information necessary to evaluate conformance with specification requirements for all features of the pump station including valves. Complete data for all electrical items, switches, enclosures, relays, motor starters and controls, and a drawing of the control panel layout and a schematic diagram of the control panel circuitry shall be included.
4. Provide two (2) sets of operation and maintenance manuals covering the generator, switchgear, and auxiliary components. Include final as-built wiring interconnect diagrams and recommended preventative maintenance schedules.

1.04 QUALITY ASSURANCE:

A. Factory Tests and Reports:

1. Perform tests on each pump in accordance with Hydraulic Institute Standards except as otherwise specified.
2. Statically balance pump impellers and dynamically balance all pump/motor units such that equipment vibration displaced (peak-to-peak) as measured at any point on the machine shall not exceed 5.0 mils for 1200 r.p.m. and 4.0 mils for 1800 r.p.m.
3. Submit results of factory tests.
4. Perform standard tests on all motors in accordance with IEEE.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

1.05 FACTORY ASSEMBLY:

- A. Pump/motor units shall be completely shop assembled and aligned prior to shipping.
- B. After completion of the specified factory tests, pumps shall be prepared for shipment with the minimum amount of disassembly, and such that no field disassembly, cleaning, or flushing is required.
- C. Any components removed for shipping shall be match-marked prior to removal and shipment.
- D. Prepare all cast iron surfaces and provide manufacturer's standard paint system.

1.06 GENERAL

- A. Contractor shall furnish all labor, materials, equipment and incidentals required providing _____ Non-clog submersible centrifugal sewage pump(s) as specified herein.
- B. The contractor shall supply a control panel which contains all necessary components for proper starting and operation of the pump. This panel shall provide a circuit that monitors the seal sensors, and heat sensors in the pump.

1.07 OPERATING CONDITIONS

- A. Each pump shall be rated ___ H.P., ___ volts, 3 phase, 60 hertz, 1750 R.P.M. The unit shall produce ___ G. P. M. at ___ ft TDH, with a minimum pump efficiency of ___ and maximum input KW of ___ KW. The pump shall be non-overloading throughout the entire range of operation without employing service factor. The pump shall reserve a minimum service factor of 1.15. The performance curve submitted for approval shall state in addition to head and capacity performance, the pump efficiency, solid handling capacity, and reflect motor service factor.

1.08 CONSTRUCTION

- A. The pump shall be a centrifugal, non-clog, solids handling, submersible, wastewater type; model ___ as manufactured by Hydromatic, Meyers or Barnes. The pump volute, motor and seal housing shall be high quality gray cast iron, ASTM A-48, Class 30. The pump discharge shall be fitted with a 4" standard ASA 125-lb. flange, faced and drilled. All external mating parts shall be machined and Buna N Rubber O-ring sealed on a beveled edge. Gaskets shall not be acceptable. All fasteners exposed to the pumped liquids shall be 300 series stainless steel.

1.09 ELECTRICAL POWER CORD

- A. Electrical power cord shall be STW-A, water resistant 600 V, 60°C, UL and CSA listed and applied dependent on amp draw for size.
- B. The pump shall be triple protected with a compression fitting and two epoxy potted areas at the power cord entry to the pump. A separation between the junction box area of the pump and the motor by a stator lead sealing gland or terminal board shall not be acceptable.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

- C. The power cable entry into the cord cap assembly shall first be made with a compression fitting. Each individual lead shall be stripped down to bare wire at staggered intervals, and each strand shall be individually separated. This area of the cord cap shall then be filled with an epoxy compound potting which will prevent water contamination to gain entry even in the event of wicking or capillary attraction.
- D. The power cord leads shall then be connected to the motor leads with extra heavy connectors having brass inserts with a screwed wire to wire connection, rather than a terminal board that allows for possible leaks.
- E. The connection box wiring shall be separated from the motor housing wiring by stripping each lead down to bare wire, at staggered intervals, and separating each strand. This area shall be filled with an epoxy compound potting. Fiberglass terminal boards which are subject to heat fatigue and cracking, and which may lead to possible leaks shall not be acceptable.
- F. The cord cap assembly where bolted to the connection box assembly and the connection box assembly where bolted to the motor housing shall each be sealed with a Buna N Rubber O-ring on a beveled edge to assure proper sealing.
- G. All cables shall be of sufficient length to terminate in a junction box outside the wet well as indicated on the drawings, with a minimum of 10 feet of slack which will be coiled in the wet well.

1.010 MOTOR

- A. The stator, rotor and bearings shall be mounted in a sealed submersible type housing. The stator windings shall have Class H insulation, (180°C or 356°F), rated for continuous duty and variable frequency drive operation, and a dielectric oil filled motor, NEMA B design. Further protection shall be provided by motor winding thermal sensors. Because air-filled motors do not dissipate heat as efficiently as oil-filled motors, they shall not be acceptable.
- B. The pump and motor shall be specifically designed so that they may be operated partially or completely submerged in the liquid being pumped. The pump shall not require cooling water jackets. Dependence upon, or use of, water jackets for supplemental cooling shall not be acceptable.
- C. Stators shall be securely held in place with a removable end ring and threaded fasteners so they may be easily removed in the field without the use of heat or a press. Stators held by a heat shrink fit shall not be acceptable. Stators must be capable of being repaired or rewound by local motor service station. Units, which require service only by the factory, shall not be acceptable. No special tools shall be required for pump and motor disassembly.
- D. Pump shall be equipped with heat sensors. The heat sensors (two on three phase) shall be a low resistance; bi-metal disc that is temperature sensitive. It shall be mounted directly on the stator windings and sized to open at 120°C and automatically reset at 30-35°C differential. The sensors shall be connected in series with motor starter coil so that the pump ceases operation when an over-temperature condition is sensed. The starter shall be equipped with 3 leg

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

overload relay with heaters sized for the pump's full load amps. The pump shall cease operation when the overload is tripped. The overload shall be manually reset.

1.011 BEARINGS AND SHAFT

- A. An upper radial bearing and a lower thrust bearing shall be required. These shall be heavy-duty single row ball bearings which are permanently lubricated by the dielectric oil which fills the motor housing. Double row, sealed grease packed bearings shall not be acceptable. Bearings that require lubrication according to a prescribed schedule shall not be acceptable. The upper radial bearing shall have a minimum B-10 life at the specified condition of 40,000 hours and the lower thrust bearing shall have a minimum B-10 life at the specified condition of 40,000 hours. Bearings shall be locally available.
- B. The shaft shall be machined from a solid 400 series stainless steel forging and is a large diameter design with minimum overhang to reduce shaft deflection and prolong bearing life.

1.012 SEALS

- A. The pump shall have two mechanical seals, mounted in tandem, with an oil chamber between the seals. John Crane Type 21, BD1D1, seals shall be used with the rotating seal faces being tungsten/carbide and the stationary seal faces to be tungsten/carbide. The lower seal shall be replaceable without disassembly of the seal chamber and without the use of special tools. Pump-out vanes shall be present on the backside of the impeller to keep contaminants out of the seal area. Units that require the use of foreign manufactured seals shall not be acceptable. Seals shall be locally available.
- B. The pump shall be equipped with a seal leak detection probe and warning system. This shall be designed to alert maintenance personnel of lower seal failure without having to take the unit out of service for inspection or requiring access for checking seal chamber oil level and consistency.
- C. There shall be an electric probe or seal failure sensor installed in the seal chamber between the two tandem mechanical seals. If the lower seal fails, contaminants which enter the seal chamber shall be detected by the sensor and send a signal to operate the specified warning device.
- D. Units equipped with opposed mechanical seals shall not be acceptable.

1.013 IMPELLER

- A. Impeller shall be of the two-vane, enclosed non-clogging design and have pump-out vanes on the front and backside of the impeller to prevent grit and other materials from collecting in the seal area. Single vane design impellers which cannot be easily trimmed and which do not maintain balance with wear causing shaft deflections and reducing seal and bearing life are not acceptable. Impeller shall not require coating. Because most impeller coatings do not remain beyond the very early life of the impeller, efficiency and other performance data submitted shall be based on performance with an uncoated impeller. Attempts to improve efficiency by coating

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

impeller shall not be acceptable. The impeller shall be manufactured from ASTM A-48, Class 30 material.

- B. Impellers shall be statically and dynamically balanced. The tolerance values shall be listed below according to the International Standard Organization grade 6.3 for rotors in rigid frames. The tolerance is to be split equally between the two balance planes, which are the two impeller shrouds.

RPM	Tolerance
1750	0.02 in. - oz./lb. of impeller weight

- C. The impeller shall be slip fit to a tapered shaft and key driven. A 300 series stainless steel washer and impeller bolt shall be used to fasten the impeller to the shaft. Straight end shafts for attachment of the impeller shall not be acceptable.
- D. Castings shall not have been repaired by plugging, welding, or other means.

1.014 CASING

- A. The casing shall be of the end suction volute type having sufficient strength and thickness to withstand all stress and strain from service at full operating pressure and load. The casing shall be of the horizontal flanged type. A rail system to allow easy installation and removal of the pump shall be available. The design shall be such that the pumps will be automatically connected to the discharge piping when lowered into position with the guide rails. The casing shall be accurately machined and bored for register fits with the suction and casing covers.
- B. A volute case-wearing ring shall be provided to minimize impeller wear. The wear ring shall be bronze ASTM # B584-932 and held by 300 series stainless steel fasteners. The wear ring shall be easily replaceable in the field. Wear rings of any other material shall not be acceptable.

1.015 PAINTING

- A. The pump shall be primed and painted after assembly, and testing, with a dark green water reducible air dry enamel. The paint shall be applied in one coat covering all exterior surfaces. The pump shall be air dried after testing and before painting.

1.016 SERVICEABILITY

- A. The complete rotating assembly shall be capable of being removed from the volute without disturbing discharge piping or volute. The motor housing, seal housing with seal plate and impeller still attached to the shaft shall be capable of being lifted out of the volute case from the top as one assembly.

1.017 SUPPORT

- A. Though the pump may not require feet to support the unit while installed, the pump volute

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

must have feet to support the unit when removed for service. Units which do not have feet upon which the unit can be supported when removed for service shall not be acceptable.

1.018 TESTING

- A. Commercial testing shall be required and include the following:
 - 1. The pump shall be visually inspected to confirm that it is built in accordance with the specification as to HP, voltage, phase and hertz.
 - 2. The stator motor leads shall be tested for integrity using a meg-ohm meter at the highest setting.
 - 3. Pump shall be allowed to run dry to check for proper rotation.
 - 4. Discharge piping shall be attached; the pump submerged in water and amp readings shall be taken in each leg to check for an unbalanced stator winding. If there is a significant difference in readings, the stator windings shall be checked with a bridge to determine if an unbalanced resistance exists. If so, the stator shall be replaced,
 - 5. The pump shall be removed from the water, meg-ohm meter tested again, dried and the motor housing filled with dielectric oil.
- B. (OPTIONAL) In addition to the above commercial testing, a special meg-ohm meter test shall be performed and include the following:
 - 1. The pump shall be submerged in water and allowed to run at maximum load for 30 minutes.
 - 2. A written report on the above shall be prepared by the test engineer, certified and submitted to the engineer.
- C. (OPTIONAL) A hydrostatic test shall also be performed on the pump. The hydrostatic test shall require that the volute and impeller be removed and a fixture installed to hold the spring and lower mechanical seal in place. A double plate, gasket and through bolt shall be installed on the pump. A discharge mating flange, gasket and pressure fitting shall be installed. The inlet port, volute and discharge nozzle shall then be pressurized with water to 150% of the maximum pump shut off pressure. This hydrostatic pressure shall be maintained for at least 5 minutes and the housing checked for leaks and/or loss of pressure.
- D. (OPTIONAL) A non-witnessed Hydraulic Institute performance test shall be performed. This shall include the following.
 - 1. The pump shall be tested at the design point as well as at least 4 other points to develop a curve. Data shall be collected to plot the head capacity curve as well as a KW input and amperage curve.
 - 2. In making these tests, no minus tolerance or margin shall be allowed with respect to capacity, total head or efficiency at the specified design condition. Pump shall be held within

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

a tolerance of 10% of rated capacity or at rated capacity with a tolerance of 5% of rated head. The pump shall be tested at shutoff, but not be plotted, and only used as a reference point when plotting the performance curve.

3. Complete records shall be kept of all information relevant to the test, as well as the manufacturer's serial number, type and size of pump, as well as any impeller modifications made to meet the design conditions,
4. A written test report shall be prepared, signed and dated by the test engineer incorporating 3 curves (head-capacity, KW input, and amperage) along with the pump serial number, test number, date, speed, volts, phase, impeller diameter, and certification number. This report shall then be submitted to the engineer.

PART 2 - PRODUCTS

2.01 ACCEPTABLE MANUFACTURERS

- A. Hydromatic, Meyers, Barnes or equal.

2.02 GENERAL REQUIREMENTS:

- A. Provide totally sealed submersible electrically operated pumps capable of pumping raw unscreened sewage.
- B. Pump controls shall be as indicated and as specified in this section.
- C. Pump shall operate at or near maximum efficiency at operating conditions.
- D. Pump head-capacity curve shall be continuously falling from shutoff head.
- E. Pump discharge connection elbow and discharge piping shall be installed such that pump will automatically connect and seal to discharge connection elbow when lowered into place.
- F. Pump shall be easily removable for inspection or service.
- G. Provide guide rail system and pump rail guide bracket to raise or lower pump unit by lifting chain.
- H. Guide entire weight of pump unit with a minimum of two stainless steel guide bars.
- I. Seal interface of the pump and discharge elbow by O-ring, gaskets, or metal to metal contact.
- J. Pumps shall be capable of pumping 3-inch diameter non-compressible solids.
- K. Pumps shall be provided with runtime meters.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

- L. All equipment to be installed inside the wet well shall be explosion-proof rated for use in Class I, Division 2, Group C and D areas.
- M. Pumping station equipment shall be installed in a concrete wet well.

2.03 DESIGN REQUIREMENTS Design requirements will be determined by Engineer. The following requirement at a minimum shall be established for each pump and provided to the City for review and approval prior to ordering of any equipment. The City shall review all information submitted in a timely manner.

- A. Number of Pumps (2 min.)
- B. Design Capacity
- C. Design Heads: Minimum, ft.
 Rated, ft. (at Design Capacity)
 Shutoff, ft. (minimum)
- D. Maximum Motor Speed, rpm (not to exceed 1800 rpm)
- E. Minimum Efficiency at rating Point, %
- F. Brake horsepower
- G. Wire to Water Horsepower
- H. Minimum Nameplate Motor Horsepower: Nameplate horsepower, regardless of service factor, shall be at least 115 percent of the maximum load imposed by the driven equipment.
- I. Maximum Depth of Water in Wet well, ft.
- J. Minimum Depth of Water in Wet well, ft.
- K. Minimum Discharge Elbow Outlet Size, In.

2.04 SEQUENCE OF OPERATION

- A. The pump control system shall be designed to operate with five normally open float switches. The “off” (second lowest) float will close to arm the control circuit. When the wet well level rises and closes the “off” float no pumps are started. As the wet well level rises, the “lead” float switch will close and the controller will start the lead pump. The lead pump will continue to operate, even after the level drops and the “lead” float switch opens, until the “off” float opens and the controller stops the lead pump.
- B. When the “off” and “lead” floats are closed and the lead pump is operating, if the wet well level continues to rise and the “lag” float closes, the controller will start the lag pump. Should a pump fail to start, the auto-dialer will call with an alarm condition. The lead and lag pumps will

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

continue to operate, even after the level drops and the “lead” and “lag” floats open, until the “off” float opens and the controller stops the lead and lag pumps.

- C. The controller shall automatically alternate the “lead” from pump to pump after each pump operation cycle.
- D. If the lead and lag pumps are operating and the wet well level continues to rise and closes the “high level” float, the high water alarm light will illuminate, flashing on/off, the alarm horn will sound and the auto-dialer will call with an alarm condition. The alarm light and horn will remain in operation until the level drops and the “high level” float opens. The alarm horn may be silenced by depressing the “Push to Silence” switch.
- E. The “redundant off” (lowest) float shall be normally tipped up closing the switch. Should the “Off” float fail to open upon “pump down” and stop the lead and/or lag pump, the level will continue to fall until the “redundant off” float opens and the controller stops the lead and/or lag pumps.
- F. A time delay shall be programmed into the controller to prevent both the lead and lag pump from starting at the same time. Should a power failure occur and the “off”, “lead” and “lag” floats are closed, when the power is restored, the lag pump will start approximately 10 seconds later. This delay will occur anytime both pumps receive a start signal simultaneously.

2.05 CONTROL PANEL CONSTRUCTION

- A. The controls for the pump shall be contained in a steel enclosure meeting NEMA 4X requirements with a hinged door and neoprene gasket.
- B. The enclosure shall have provisions for padlocking. A nameplate shall be permanently affixed to the panel and include the model number, voltage, phase, hertz, ampere rating and horsepower rating. A warning label against electric shock shall be permanently affixed to the outer door.
- C. A steel back panel with electroplated bright zinc and clear chromate finish shall be provided. A painted steel back panel will not be acceptable.
- D. Run lights and hand-off-auto switches shall be provided. Run light and hand-off-auto switch shall be mounted on electro-plated bright zinc with clear chromate finish steel bracket. The run light and hand-off-auto switch shall be properly labeled as to function. The hand-off-auto switch shall be rocker type with an electrical life of 50,000 operations. The run light shall match the hand-off-auto switch in appearance and have an electrical life of 5,000 hours. Run light shall be red.
- E. The incoming power shall be 208/460 volts, 3 phase, 60 hertz service. Terminal blocks with box type lugs shall be supplied to terminate all wiring for floats and heat and seal sensors for the pump. The pump leads shall be terminated at the overload relay or at box type terminal blocks. The terminal blocks for the float connections shall be on the pump controller.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

- F. A circuit breaker shall be used to protect from line faults and to disconnect the pump from the incoming power. Circuit breaker shall be thermal magnetic and sized to meet NEC requirements for motor controls.
- G. The magnetic starters shall include a contactor with a minimum mechanical life of 3,000,000 operations and a minimum contact life of 1,000,000 operations. A definite purpose contactor shall not be acceptable. The magnetic starter shall include an overload relay which is ambient temperature compensated and bimetallic with adjustable trip settings based on the motor full load amps. The overload relay shall have test and reset buttons. The overload relay shall be capable of being set in either manual or automatic reset mode. In the manual mode, reset shall be accomplished only by the operator. At 6 times full load amps the overload relay shall trip within 10 seconds or Class 10 rated overload relays shall be required. Motor contactor and overload relay shall be Cutler Hammer.
- H. Control voltage shall be 120 VAC and may be accomplished by the means of a transformer or available line voltage. A control fuse and on/off switch shall protect and isolate the control voltage from the line.
- I. Wire ties shall be used to maintain panel wiring in neat bundles for maintenance and to prevent interference with operating devices. All wiring shall be color coded to facilitate maintenance and repair of the control panel. Where a color is repeated, number coding shall be added. A schematic shall be permanently attached to the inside surface of the front door.
- J. All ground connections shall be made with ring tongue terminals and star washers to assure proper ground.
- K. A duplex pump controller as manufactured by Hydromatic, Meyers or Barnes shall be provided for control logic. Pump controller shall be solid state utilizing a printed circuit board to avoid conventional wiring. The printed circuit board of the pump controller shall be made of U.L. listed materials.
- L. The pump controller shall indicate float circuit operations utilizing red amber LED indicator lights. LED indicator lights shall provide adequate information so that they can be used for diagnosis in troubleshooting problems located in the float circuits. Each LED shall be permanently labeled on the pump controller as to function, "Off float", "On float", "Pump 1 Call", "Pump 2 Call". The pump controller shall have provisions for connecting float level controls and heat sensor monitors, to box type lug connectors.
- M. Box type lug connectors shall be made of polyamide thermoplastic to exclude aging due to heat influences. Phenolic type terminal blocks on the pump controller shall not be acceptable. Each terminal block shall be property and permanently labeled on the pump controller as to its purpose.
- N. Wiring of hand-off-auto switch, run light, contactor, and overload to the pump controller shall be accomplished by means of plug connectors. The pump controller shall have male header assemblies from the corresponding devices as labeled on the pump controller for that male header assembly. Header assemblies shall be constructed of a corrosion-resistant

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

thermoplastic material having a temperature range of -55 °C to 105 °C and copper alloy, bright acid tin over nickel plating contacts.

- O. When reduced voltage starters are used, they shall be Cutler-Hammer, IT Series reduced voltage solid-state starters or equivalent.

2.06 REQUIRED OPTIONS

- A. Panel shall be equipped with the following additional features:

1. U.L. 508, intrinsically safe circuit extensions for floats.
2. A High level alarm flashing, red light mounted on top of the enclosure.
3. A High-level alarm horn, rated 95 dB at 2 feet with local push to silence switch. Dry contacts for telemetry of alarm conditions, Power Failure, High Water Alarm, Pump Failure.
4. Redundant off float switch.
5. Each pump shall have a non-resettable, Nema 4 rated, elapsed run time meter mounted on the outside of the enclosure's outer door.
6. Seal failure to be monitored for each pump and upon seal fail detection, the "Seal Fail" orange/yellow light on the panel exterior will illuminate. Pump will continue to operate while the light is on.
7. Anti-condensate heater (50 watt) with thermostat.
8. Heat sensor.
9. Phase failure protection.
10. Lightning suppresser.
11. Lag pump on time delay.
12. GFCI 110-volt, duplex receptacle installed on side of enclosure with a weatherproof cover.
13. Swing dead front inner door with all operating switches accessible through the inner door to prevent possible electrical hazard to the operator. Service entrance rated main power non-fused, disconnect switch with through the door operator handle on inner door.
14. Power transformer, 3 KVA, mounted on outside of enclosure. The transformer shall have a primary power disconnect switch and fuse protection. Circuit breakers shall be provided to distribute the transformer secondary power for:
 - a. Pump controller power

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

- b. Generator heater
 - c. Generator battery charger
 - d. Duplex receptacle for auto-dialer power
 - e. GFCI duplex receptacle
15. Alarm Agent WRTU auto-dialer, monitor pump run times and programmed to alarm AC power loss, High water alarm, Seal failure and Pump failure.
16. Sized to house motor starters, relays, alternator, etc.
17. Mount on unistrut rack that is sized adequately to hold the two disconnect switches and the common control panel.
18. Watertight termination fittings for all pipes and conduits entering the enclosure.
19. Interior of box shall be insulated with 1-inch thick noncombustible Styrofoam board insulation with foil facing.
20. Furnished by Pump Manufacturer.

2.07 FLOAT SWITCHES AND WET WELL CONDUIT

- A. The level control float switches shall be the internally weighted, normally opened type by Anchor Scientific, Type S, Roto-Float.
- B. A complete set of seals, O-Rings, and gaskets, and one spare set of mechanical seals consisting of an upper and a lower seal, shall be furnished for each pump.
- C. Spare parts shall be suitably packaged with labels indicating the contents of each package. Spare parts shall be delivered to the City as directed.
- D. The stainless steel float bracket for five (5) floats shall be wall mounted and have cord grips as manufactured by Hubbell, model F2 for each float.
- E. Separate 2" PVC conduit pipes for a total of five (5) shall be run between the wet well and the control panel enclosure for each of the following wires and one extra conduit for future use:
 - 1. Float wires 2" conduit
 - 2. Pump 1 wires 2" conduit
 - 3. Pump 2 wires 2" conduit
 - 4. Extra 2" conduit

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

2.08 SPARE PARTS

A. The following spare parts, meeting the same specifications as listed above, shall be supplied and properly labeled for easy identification.

1. Magnetic starter
2. Thermal overload relay

2.09 ACCESSORIES

A. Pump Discharge Base:

1. Base shall be sufficiently rigid to firmly support the guide rails, discharge piping and pumping unit under all operating conditions.
2. Base shall be provided with integral support legs suitable for bolting to the floor of the wet well with stainless steel anchor bolts.
3. Designed to automatically connect to the pump discharge without bolts.
4. Constructed of cast or ductile iron.
5. Diameter and drilling of the elbow outlet flange shall conform to ANSI B16.1, Class 125.

B. Rail Guides:

1. Fasten stainless-steel guide supports to pump so that no lifting loads are applied to pump or motor housing.

C. Lifting:

1. Provide one stainless steel lifting chain for each pump.
2. Design to raise and lower pump with additional safety factor for overcoming force of pump hang-ups.
3. Provide stainless steel hooks for chain when not in use.
4. Provide one portable hoist assembly for removal of pumps:
 - a. Hoist shall be manually operated.
 - b. Hoist shall have mounting plate/socket cast into top of concrete slab.

D. Guide Rails:

1. Stainless-steel pipe.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

2. All ANSI 316 stainless steel, including rails, brackets, and anchor bolts.
3. Size shall be 2-inch minimum.
4. Shall not support any portion of the pump weight.
5. Provide a minimum of two guide rails.
6. Shall extend to the top of the wet well at the access hatch cover.

E. Cable Holder:

1. Provide stainless steel or rust-proof grip holders for pump and control cables.
2. Cables shall be easily adjusted to pumping level without splices.
3. Provide continuous cables from control panel to pumps and level controls.

F. Access Hatch Cover:

1. Fabricated aluminum hatches suitable for a live load of 300 pounds per square foot with stainless steel accessories.
2. Automatic latching mechanism shall prevent the hatch from closing unintentionally.
3. Double leaf type construction of structural shapes and reinforced diamond pattern checkered plate.
4. Structural shapes and plates shall have a minimum thickness of ¼ inch.
5. The hatch shall be spring loaded to minimize opening effort.
6. Hatch cover shall be set in concrete top.
7. All hatches shall be provided with OSHA approved fall protection.

2.010 ELECTRICAL EQUIPMENT

A. Conform to NEC, NEMA and IEEE on all electrical equipment and controls.

B. Controls:

1. Wet well level and alarm controls shall be 120 volts and shall be provided by sealed float type mercury switches. The mercury tube switches shall be sealed in a solid polyethylene float for corrosion and shock resistance.
2. The support wire for each float switch shall have a cord lock to secure float to bracket.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

3. Each float switch shall hang in the wet well supported only by the individual cord connected thereto.
4. The number of floats required shall be as indicated in Section 2.07 within this specification section.

2.011 EMERGENCY OPERATION

- A. All pump stations shall provide overflow protection by means of a riser from the force main with quick connect coupling and appropriate valving to hook up portable pumps.
 1. The diameter of the quick connect coupling shall be designated by the City.
 2. Riser assembly shall be housed in a concrete vault. Riser assembly shall include a plug type shutoff valve.
 3. Access to the assembly shall be through an aluminum hatch cover cast into the top slab. Hatch cover shall be provided by the pump manufacturer and meet requirements covered in Section 2.08(F).
 4. All valves, piping and fittings shall be field painted. Field painting shall consist of a minimum of two coats of epoxy enamel paint. Color to be selected by the City.
- B. Pumping stations designated by the City as temporary shall be provided with a quick couple connection for a portable generator. Quick couple connection type shall be compatible with existing City equipment.
- C. Pump stations not designated temporary by the City shall provide overflow protection by a quick connect coupling and one of the following methods:
 1. Connection to two independent public utility sources, or;
 2. Provide power generating equipment.
 - a. Provide low fuel alarm relay to telephone dialer.
 - b. Provide automatic transfer switch.
 - c. Provide automatic day/time selection timer to exercise the generator at user's selectable time.
 - d. Type of fuel to be determined by the City.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

2.012 REFERENCES AND STANDARDS

A. References and Standards

1. The generator covered by these specifications shall be designed, tested, rated, assembled and installed in strict accordance with all applicable standards of ANSI, NEC, ISO, UL508, IEEE and NEMA.

B. Work Included

C. Installation

1. The work includes supplying and installing a complete integrated generator system.
2. The system consists of a natural gas/propane generator set with related component accessories and automatic transfer switches specified under a separate section.

D. Fuel System

1. The CONTRACTOR shall provide fuel connections for the completion of all testing.

E. System Test

1. A complete system load test shall be performed after all equipment is installed.

F. Requirements, Codes and Regulations

- G. The equipment supplied and installed shall meet the requirements of the NEC and all applicable local codes and regulations. All equipment shall be of new and current production by a manufacturer who has 50 years of experience building this type of equipment. Manufacturer shall be ISO9001 certified.

2.013 SYSTEM RESPONSIBILITY

A. Generator Set Distributor

1. The completed engine generator set shall be supplied by the Manufacturer's authorized distributor only.

B. Requirements, Codes and Regulations

1. The equipment supplied and installed shall meet the requirements of NEC and all applicable local codes and regulations. All equipment shall be new, of current production. There shall be one source responsibility for warranty; parts and service through a local representative with factory trained service personnel.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

C. Automatic Transfer Switch

1. The automatic transfer switch specified in another section shall be supplied by the generator set manufacturer in order to establish and maintain a single source of system responsibility and coordination.

2.014 WARRANTY

- A. The manufacturer's warranty shall in no event be for a period of less than five (5) years from date of shipment of the system.
- B. The warranty shall include repair parts, labor, and reasonable travel expense necessary for repairs at the job site, and expendables (lubricating oil, filters, antifreeze, and other service items made unusable by the defect) used during the course of repair.
- C. The following parts will be replaced within the five (5) years of date of shipment upon payment of the applicable percentage of the list price of each part in effect at the time of the replacement.

<u>Item</u>	<u>Months After Shipment</u>			
	<u>0-18</u>	<u>19-31</u>	<u>32-45</u>	<u>46-60</u>
Mechanical Seal	0%	25%	50%	75%
Impeller	0%	30%	50%	80%
Pump Housing	0%	30%	50%	80%
Wear Ring	0%	50%	80%	100%
Ball Bearings	0%	50%	80%	100%
Rotor and Stator	0%	40%	80%	100%

- D. In order to ensure warranty coverage and timely service, all pumps shall be supplied by the manufacturer's representative for this area.
- E. Submittals received without written warranties as specified will be rejected in their entirety.

2.015 PARTS AND SERVICE QUALIFICATIONS

A. Service Facility

1. The engine-generator supplier shall maintain 24-hour parts and service capability.
2. The distributor shall stock parts as needed to support the generator set package for this specific project. The proximity from the distributor's facility to the City shall be 25 miles or less.

2.016 SERVICE PERSONNEL

- A. The dealer shall maintain qualified factory trained service personnel.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

2.017 GENSET REQUIREMENTS

- A. The generator set shall be sized to start all loads with a maximum voltage dip of 25% or less, if controls allow the pumps to be staged then the sizing may be determined by the maximum voltage dip when the last pump starts while all others are running.

2.018 MATERIALS AND PARTS

- A. All materials and parts comprising the unit shall be new and unused.

2.019 ENGINE

- A. The engine shall be spark ignition type Natural gas fueled, four (4) cycle, water-cooled, vertical in-line or vee-type, operating with nominal speed not exceeding 1800 RPM.
- B. LPG (Propane) or diesel fuel may be considered with prior approval from the City.

2.020 GENERATOR

- A. Generator Specifications
 - 1. The synchronous generator shall be a single bearing, self-ventilated, drip-proof design in accordance with NEMA MG 1 and directly connected to the engine flywheel housing with a flex coupling.
- B. Insulation
 - 1. The insulation material shall meet NEMA standards for Class H insulation and be impregnated in a polyester varnish or vacuum impregnated with epoxy varnish to be fungus resistant. The excitation system shall be of brushless construction.
- C. Automatic Voltage Regulator
 - 1. The automatic voltage regulator (AVR) shall maintain generator output voltage within +/- 0.5% for any constant load between no load and full load. The regulator shall be a totally solid-state design, which includes electronic voltage buildup, volts per Hertz regulation, over excitation protection, shall limit voltage overshoot on startup, and shall be environmentally sealed.

2.021 CIRCUIT BREAKER

- A. Circuit Breaker Specifications
 - 1. Provide a generator mounted circuit breaker, molded case or insulated case construction 3 pole. Breaker shall utilize a thermal magnetic trip. Breaker shall be housed in a steel NEMA 1 enclosure mounted on a separate support stand vibration isolated from the engine / generator arrangement. Bus bars, sized for the cable type shown on drawing, shall be

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

supplied on the load side of breaker.

2.022 CONTROL PANEL

A. Generator Mounted Control Panel

1. Provide a generator set mounted control panel for complete control and monitoring of the engine and generator set functions. Panel shall include automatic start/stop operation, cycle cranking, AC metering with phase selector switch, shutdown sensors and alarms with horn and reset, adjustable cool down timer and emergency stop push-button. Critical components shall be environmentally sealed to protect against failure from moisture and dirt. Components shall be housed in a NEMA 1/IP22 enclosure with hinged door. The panel itself shall be mounted on a separate support stand isolated from the engine / generator arrangement. Panel / breaker arrangements mounted on the generator set in such a way that access to the AC Generator terminal box is restricted in any way whatsoever are not acceptable.

B. Readouts

1. Provide the following readouts:
 - a. Engine oil pressure
 - b. Coolant temperature
 - c. Engine RPM
 - d. System DC Volts
 - e. Engine running hours
 - f. Generator AC Volts
 - g. Generator frequency
 - h. Generator AC Amps

C. Alarm

1. Provide the following indications for protection and diagnostics:
 - a. Low oil pressure
 - b. High water temperature
 - c. Low coolant level

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

- d. Over speed
- e. Over crank
- f. Emergency stop depressed

D. Control Functions / Interfaces

- 1. Provide the following control functions
 - a. Terminals located inside the control panel for REMOTE EMERGENCY STOP.
 - b. ON / OFF / AUTO control switch

2.023 COOLING SYSTEM

- A. The generator set shall be equipped with a rail-mounted, engine-driven radiator with blower fan and all accessories. The cooling system shall be sized to operate at full load conditions and 110 F ambient air entering the room or enclosure (If an enclosure is specified). The generator set supplier is responsible for providing a properly sized cooling system based on the enclosure static pressure restriction.

2.024 FUEL SYSTEM

- A. Fuel Piping
 - 1. All gas piping shall be flexible fuel hose rated for this service.
- B. Fuel Line Rating
 - 1. Flexible fuel lines rated 300 degrees F and 100 PSI.
- C. Engine Governing
 - 1. Fuel supply to the engine shall be via a venturi mixer type throttle body with integral electronic governor. Speed control shall be isochronous with 0.25% steady state regulation.

2.025 STARTING SYSTEM

- A. Starting Motor
 - 1. A DC electric starting system with positive engagement shall be furnished. The motor voltage shall be as recommended by the engine manufacturer.
- B. Jacket Water Heater
 - 1. A unit mounted thermal circulation type water heater. The heater Watt rating shall be

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

sized by the manufacturer to maintain jacket water temperature at 90 degrees F, and shall be a 120 Volt, single phase, 60 hertz.

C. Batteries

1. Batteries - A lead-acid storage battery set of the heavy-duty diesel starting type shall be provided.
2. Battery voltage shall be compatible with the starting system. The battery set shall be rated no less than 75-ampere hours. Necessary cables and clamps shall be provided.

D. Battery Charger

1. Battery Charger - A current limiting battery charger shall be furnished to automatically recharge batteries. Output voltage regulation shall not exceed 1% the charger shall include temperature compensation. It shall also include overload protection, silicon diode full wave rectifiers, voltage surge AC input voltage shall be 120 volts, single phase. On outdoor units the battery charger shall be mounted inside the genset enclosure.

2.026 ENCLOSURE

A. Standard Weather Protective Enclosure

1. A weather resistant enclosure complying with NEMA Type 4X finished steel with electrostatically applied powder coated baked polyester paint. It shall consist of a roof, side walls, and end walls. Fasteners shall be either zinc plated or stainless steel.
2. Number of doors on enclosure shall be as required so that all normal maintenance operations, such as lube oil change, filter change, belt adjustment and replacements, hose replacements, access to the control panels, etc., may be accomplished without disassembly of any enclosure components. Access doors shall be fabricated of the same material as the enclosure walls and shall be reinforced for rigidity. Handles shall be key lockable, all doors keyed alike, and hinges shall be zinc die cast or stainless steel. Fasteners shall be zinc plated or stainless steel. Doors shall be of a lift off design allowing one person to remove door if necessary.
3. Air handling will be sized and designed by the manufacturer for 0.5" static pressure drop through enclosure. Intake openings shall be screened to prevent the entrance of rodents.
4. Lube oil and coolant drains shall be extended to the exterior of the enclosure and terminated with drain valves. Radiator access shall be through a hinged, lockable cover on enclosure. Cooling fan and charging alternator shall be fully guarded to prevent injury.
5. A critical type silencer, companion flanges, and flexible stainless steel exhaust fitting properly sized shall be furnished. Enclosure manufacturer shall internally mount the exhaust silencer and maintain the weather resistant integrity and aesthetic appearance of the system. Externally mounted silencers will not be permitted for safety reasons.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

6. Lifting points shall be provided on base frame suitable for lifting combined weight of base tank, generator set and enclosure.

2.027 AUTOMATIC TRANSFER SWITCH

- A. An automatic transfer switch, (ATS), shall be furnished as specified herein.

2.028 GENERAL

- A. The transfer switch shall be rated for the voltage and amperage as shown on the plans and shall have 600-volt insulation on all parts in accordance with NEMA standards.
- B. The current rating shall be a continuous rating when the switch is installed in an unventilated enclosure, and shall conform to NEMA temperature rise standards. Designs which require cabinet ventilation are unacceptable and do not meet this specification.
- C. The unit shall be rated based on all classes of loads, i.e., resistive, tungsten, ballast and inductive loads. Switches rated 400 amperes or less shall be UL listed for 100% tungsten lamp load.
- D. As a precondition for approval, all transfer switches complete with accessories shall be listed by Underwriters Laboratories, under Standard UL 1008 (automatic transfer switches) and approved for use on emergency systems.
- E. The withstand current capacity of the main contacts shall not be less than 20 times the continuous duty rating when coordinated with any molded case circuit breaker established by certified test data. Refer to required withstand and close ratings as detailed in this specification.
- F. Temperature rise tests in accordance with UL 1008 shall have been conducted after the overload and endurance tests to confirm the ability of the units to carry their rated currents within the allowable temperature limits.
- G. Transfer switches shall comply with the applicable standards of UL, CSA, ANSI, NFPA, IEEE, NEMA and IEC.
- H. The transfer switches shall be supplied with a microprocessor based control panel as detailed further in these specifications.

2.029 SEQUENCE OF OPERATION

- A. The ATS shall incorporate adjustable three phase under-voltage sensing of the normal source.
- B. When the voltage of any phase of the normal source is reduced to 80% of nominal voltage, for a period of 0-10 seconds (programmable) a pilot contact shall close to initiate starting of the engine generator.
- C. The ATS shall incorporate adjustable single phase under-voltage sensing of the emergency

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

source.

- D. When the emergency source has reached a voltage value within 10% of nominal voltage and achieved frequency within 5% of the rated value, the load shall be transferred to the emergency source after a programmable time delay.
- E. When the normal source has been restored to not less than 90% of rated voltage on all phases, the load shall be re-transferred to the normal source after a time delay of 0 to 30 minutes (programmable). The generator shall run unloaded for 5 minutes (programmable) and then automatically shut down. The generator shall be ready for automatic operation upon the next failure of the normal source.
- F. If the engine generator should fail while carrying the load, retransfer to the normal source shall be made instantaneously upon restoration of proper voltage (90%) on the normal source.
- G. Site inspection and operational tests shall be conducted by the factory trained generator service technician in the presence of the engineer, to indicate that the switch satisfies the specifications.
- H. The transfer switch shall be equipped with a microprocessor based control panel. The control panel shall perform the operational and display functions of the transfer switch. The display functions of the control panel shall include ATS position and source availability.
- I. The front panel display shall include indicators for timing functions, capability to bypass the TD on transfer or retransfer, an ATS test switch and afford on-board diagnostic capability.
- J. The control panel shall be provided with calibrated pots (accessible only by first opening the lockable cabinet door) to set time delays, voltage and frequency sensors. Designs which make use of DIP switches to render such adjustments are not acceptable. The ATS shall be capable of being adjusted while the controls are energized and the unit in automatic mode. Designs which force a "programming mode" or require the controls be de-energized during adjustment are unacceptable.
- K. The control panel shall be opto-isolated from its inputs to reduce susceptibility to electrical noise and provided with the following inherent control functions and capabilities:
 - 1. An LED display for continuous monitoring of the ATS functions.
 - 2. Built-in diagnostic display.
 - 3. Capability to support external communication and network interface through an optional RS 485 serial port.
 - 4. Touch pad test switch to simulate a normal source failure.
 - 5. Time delay to override momentary normal source failure prior to engine start. Field programmable 0-10 seconds (continuously adjustable via a calibrated potentiometer factory

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

set at 3 seconds.

6. Time delay on retransfer to normal source, continuously adjustable 0-30 minutes, factory set at 30 minutes. If the emergency source fails during the retransfer time delay, the transfer switch controls shall automatically bypass the time delay and immediately retransfer to the normal position.
7. Time delay on transfer to emergency, continuously adjustable 0-15 seconds, factory set at 1 second.
8. An in-phase monitor shall be provided. The monitor shall compare the phase angle difference between the normal and emergency sources and be programmed to anticipate the zero crossing point to minimize switching transients.
9. An interval-type automatic clock exerciser shall be incorporated within the microprocessor.
10. Provide a momentary pushbutton to bypass the time delays on transfer and retransfer.

2.030 CONSTRUCTION AND PERFORMANCE

- A. The automatic transfer switch shall be of double throw construction operated by a reliable electrical mechanism momentarily energized. There shall be a direct mechanical coupling to facilitate transfer in 6 cycles or less.
- B. The normal and emergency contacts shall be mechanically interlocked such that failure of any coil or disarrangement of any part shall not permit a neutral position.
- C. For switches installed in systems having ground fault protective devices, and/or wired so as to be designated a separately derived system by the NEC, a 4th pole shall be provided. This additional pole shall isolate the normal and emergency neutrals. The neutral pole shall have the same withstand and operational ratings as the other poles and shall be arranged to break last and make first to minimize neutral switching transients. Add-on or accessory poles that are not of identical construction and withstand capability are not acceptable.
- D. The contact structure shall consist of a main current carrying contact, which is a silver alloy with a minimum of 50% silver content. The current carrying contacts shall be protected by silver tungsten arcing contacts on all sizes above 400 Amps.
- E. The transfer switch manufacturer shall submit test data for each size switch, showing it can withstand fault currents of the magnitude and the duration necessary to maintain the system integrity. Minimum UL listed withstand and close into fault ratings shall be as follows:

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

Any Molded Case Breaker*:

<u>Size (Amps)</u>	<u>(RMS Symmetrical)</u>
Up to 200	10,000
201 - 260	35,000
261 - 400	35,000
401 - 1200	50,000
1201 - 4000	100,000

Specific Coordinated Breaker*:

<u>Size (Amps)</u>	<u>(RMS Symmetrical)</u>
Up to 150	30,000
151 - 260	42,000
261 - 400	50,000
401 - 800	65,000
801 - 1200	85,000
1201 - 4000	100,000

Current Limiting Fuse*:

<u>Size (Amps)</u>	<u>(RMS Symmetrical)</u>
Up to 4000	200,000

*All values 480 volt, RMS symmetrical, less than 20% power factor.

- F. A dielectric test at the conclusion of the withstand and closing tests shall be performed.
- G. The automatic transfer switch manufacturer shall certify sufficient arc interrupting capabilities for 50 cycles of operation between a normal and emergency source that are 120 degrees out of phase at 480 volts, 600% of rated current at .50 power factor. This certification is to ensure that there will be no current flow between the two isolated sources during switching.
- H. All relays shall be continuous duty industrial type with wiping contacts. Customer interface contacts shall be rated 10 amperes minimum. Coils, relays, timers and accessories shall be readily front accessible. The control panel and power section shall be interconnected with a harness and keyed disconnect plugs for maintenance.
- I. Main and arcing contacts shall be visible without major disassembly to facilitate inspection and maintenance.
- J. A manual handle shall be provided for maintenance purposes with the switch de-energized. An operator disconnect switch shall be provided to defeat automatic operation during maintenance, inspection or manual operation.
- K. The switch shall be mounted in a NEMA 1 enclosure unless otherwise indicated on the plans.
- L. Switches composed of molded case breakers, contactors or components thereof not specifically designed as an automatic transfer switch will not be acceptable.
- M. The automatic transfer switch shall be warranted against defects in material or workmanship for

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

a period of two years from the date of shipment.

- N. To afford the advantage of a single source of supply to the owner, the automatic transfer switch shall be supplied by the manufacturer of the engine generator set and covered under the same warranty program. The ATS shall be the Caterpillar CTG Series.

PART 3 – EXECUTION

3.01 INSTALLATION

- A. Make all electrical and control connections.
- B. Provide all necessary lubrication for initial start-up, testing and as required for final acceptance.
- C. Provide a complete unit with all materials, components and adjustments as required for successful operation.
- D. Installation, start-up and setting of all equipment and associated construction shall conform to manufacturer's recommendations.
- E. Do not place grout for pump discharge bases until pumps are completely aligned.
- F. Install pipe and pipe appurtenance supports to minimize stresses being placed on pump nozzles.
- G. Electrical junction boxes not permitted inside wet well.

3.02 START-UP AND TESTING

- A. Coordinate all start-up and testing activities with the Engineer and Owner.
- B. After installation is complete and normal power is available, the manufacturer's local dealer shall perform the following:
 - 1. Verify that the equipment is installed properly.
 - 2. Check all auxiliary devices for proper operation, including battery charger, jacket water heater(s), generator space heater etc.
 - 3. Test all alarms and safety shutdown devices for proper operation and annunciation.
 - 4. Check all fluid levels.
 - 5. Start engine and check for exhaust, oil, fuel leaks, vibrations, etc.
 - 6. Verify proper voltage and phase rotation at the transfer switch before connecting to the load.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

7. Connect the generator to building load and verify that the generator will start and run all designated loads.
8. The system shall be tested under full load and monitor the following readings:

Oil pressure
Coolant temperature
Battery charge rate
AC volts
AC Amperes- all phases
Frequency
Kilowatts
Ambient Temperature

3.03 TRAINING

- A. Provide one day of on-site training to instruct the city's personnel in the proper operation and maintenance of the equipment. Review operation and maintenance manuals, parts manuals, and emergency service procedures.

3.04 VENTILATION

- A. Pump station wet well shall be provided with adequate ventilation.
- B. Ventilation piping shall be provided with ¼-inch screen mesh.

3.05 STATION GROUNDS

- A. Fencing:
 1. A chain-link fence shall be provided around the pump station.
 2. The fence shall have a fabric height of six feet and be provided with three barbed wire strands above the top of the fabric.
 3. The fence shall be provided with a 12-foot wide double-leaf gate with locking system.
- B. Valve Vault:
 1. A suitable valve vault shall be provided to house a plug valve and check valve from the discharge of each pump. Check valve shall be located between the plug valve and the pump. Valves shall be placed only in horizontal pipe runs. Valves shall not be located in the wet well.
 2. Check valves shall be as specified in other sections of the specification.
 3. Plug valves shall be as specified in other sections of this specification.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

4. Valve vault shall be constructed of concrete and be provided with an aluminum access hatch cover of similar design and manufacture of the hatch cover provided for the wet well. Access hatch cover shall be of single leaf.
5. Provide drain connecting vault to wet well. Provide trap to seal drain pipe at wet well.
6. All valves, piping and fittings shall be field painted. Field painting shall consist of a minimum of two coats of epoxy enamel paint. Color to be selected by the City.

C. Gravel Surfacing:

1. Crushed rock: Gradation of ¾-inch to 1-inch sizes.
2. The area inside the fence shall be provided with a minimum of 4 inches of gravel surfacing on 6 mil polyethylene sheeting placed over entire enclosed area. Polyethylene sheeting shall be provided with 3 -one inch holes per square yard.
3. Treat soil with soil sterilant prior to sheeting application.

D. Outside Lighting:

1. An outside weatherproof pole mounted light shall be provided.
2. Light shall be of the high-pressure sodium type with electric eye (photo cell) for dusk to dawn operation.

E. Access Road:

1. Pump station shall be provided with an asphalt or concrete access road.
2. The access road shall be a minimum of 12 feet in width and extend from the pump station gate to the adjacent street pavement.
3. Access road shall be constructed with a minimum of 4" thick base rock, 7" minimum thickness of black base and 1-1/2" of asphalt surface, (or concrete equivalent).
4. Access road shall have a turn-around provided at the pumping station.

F. Water Supply:

1. Provide metered water supply to pumping station with a ¾" freeze proof yard hydrant within perimeter fence. Provide an appropriate backflow preventer as per Paragraph 2.06.A.1, Page 02640-5 in this document.

SECTION 11151 – SUBMERSIBLE WASTEWATER PUMPING STATION

3.06 PERFORMANCE TESTS

- A. Conduct in the presence of Contractor, City, and Engineer.
- B. Equipment Tests:
 - 1. Check performance of all components as a functioning unit.
 - 2. Check alignment of each unit.
- C. Operational Tests:
 - 1. Conduct such operational tests as necessary to determine that the performance of equipment and controls is as specified.
 - 2. Tests will generally consist of placing equipment in operation under varying conditions and observing performance.
- D. Make all necessary equipment adjustments and corrective work indicated by tests.
- E. Submit a written test report to Contractor with one copy to the City in a letter form stating operations performed and results obtained for each unit.
- F. Wet well hydrostatic tests as specified for Manhole Water Testing in the Pipe Installation and Testing Section.

3.07 PAINTING

- A. Prepare surfaces of damaged and uncoated areas and touch-up as required for complete protection.

END OF SECTION 11151

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

PART 1 – GENERAL REQUIREMENTS

1.01 SUMMARY OF WORK

A. Work Covered by These Specifications:

1. The work covered by these specifications shall consist of any and all utility work performed or to be performed in, under, or through rights-of-way, streets, or alleys, including but not limited to water supply, sanitary sewer, storm sewer, telephone, fiber optic cable, gas pipelines, electrical conduit or conductors, cable television lines, and telecommunication facilities. It is to include, but not be limited to; repair of street cuts, required final grading, clean up, disposal of surplus materials and seeding or sodding. No street cut shall be accomplished without approval from the Right of Way Manager. An approved right-of-way permit shall be obtained from the City of Ozark prior to beginning any work within any City right-of-way by any person wishing to perform said work. No street cut shall be accomplished without approved by the Director of Public Works or their designee.

B. Work Sequence:

1. The permit holder or his contractor shall schedule his work to allow emergency vehicle access to public and private property at all times. Private drives and public streets and alleys shall be opened for use at the end of each workday. Cables shall be buried and covered as soon as reasonable and possible, but not to exceed a two-week period. No exposed cable shall be laid across any street or traffic way. Permanent patching of street cuts shall also be accomplished as soon as reasonable and possible.

C. PERMIT HOLDER Use of Premises:

1. The permit holder shall confine construction equipment, storage of materials and equipment, and operations or workers to areas within the public right-of-way and easements of record as indicated on the drawings or as directed by the Right of Way Manager. If permit holder proposes to use any private property for his use, he shall be solely responsible for making arrangements for such use with the property owner. The City shall not be liable for any damages caused by permit holder's use of such property.

D. Coordination with Work by Others:

1. The permit holder shall cooperate with City employees or others who may be working in the area of this Work. He shall strive to coordinate his Work to not interfere with the work of others unnecessarily. He will not be required to interrupt the progress of his operations materially to assure such coordination.

1.02 REFERENCES

A. Applicable Standards;

1. American Society for Testing and Materials (ASTM);

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

- a. D698 – Laboratory Compaction Characteristics of Soil Using Standard Effort.
 - b. D1556 – Density and Unit Weight of Soil in Place by Sand-Cone Method.
 - c. D2167 - Density and Unit Weight of Soil in Place by the Rubber Balloon Method.
 - d. D6938 – Density and Water Content of Soil and Soil-aggregate in by Nuclear Methods, (Shallow Depth).
2. Department of Transportation, Public Service Commission;
 - a. Part 192 – Transportation of natural and Other Gas by Pipeline.
 3. Missouri Standard Specifications for Highway Construction;

1.03 EXISTING ABOVE GROUND AND UNDERGROUND INSTALLATION AND STRUCTURES

A. General:

1. Utility poles, pipe lines and other existing above ground and underground installations and structures in the vicinity of the Work are to be indicated on the plans according to the best information available to the permit holder and City.
2. Permit holder shall make every effort to protect such installations and structures. He shall contact the owners of such installations and structures and prospect in advance of trench excavation. Any delays or extra cost to the permit holder caused by such installations and structures, whether shown on the plans or not, or found on locations different than those indicted, shall not constitute a claim against the City for extra work, additional payment or damages.
3. Damage to existing above ground and underground installation or structures caused by the permit holder shall be repaired by the permit holder as directed by the owner of such installation or structure. The owner of such installation or structure shall be notified immediately of any such damage and repairs made as soon as possible to keep the interruption of service to a minimum. The permit holder shall bear any costs assessed because of such repairs and shall hold the City and the Engineer harmless.

1.04 TRAFFIC CONTROL AND SAFETY

A. Maintenance of Traffic:

1. The permit holder shall conduct his work as to interfere as little as possible with public travel, whether vehicular or pedestrian. Whenever it is necessary to cross, obstruct, or close roads, driveways or walks, whether public or private, the permit holder shall at his own expense provide and maintain suitable and safe bridges, detours or other temporary expedients for the accommodations of public and private travel, and shall give reasonable notice to the owners of private drives before interfering with them. Prior to interfering with

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

the public travel in any way, the permit holder shall notify the Public Works Department with information as to the extent of the interference and the length of time of such interference to permit review and approval by the Public Works Department.

B. Barricades and Lights:

1. All streets, roads, highways and other public thoroughfares, which are closed to traffic, shall be protected by means of effective barricades on which shall be placed acceptable warning signs. Barricades shall be located at the nearest intersecting public highway or street on each side of the blocked sections.
2. All open trenches and other excavations shall be provided with suitable barriers, signs and lights to the extent that adequate protection is provided to the public. Obstructions, such as material piles and equipment, shall be provided with similar warning signs and lights. All barricades and obstructions shall be illuminated by means of warning lights at night. All lights used for this purpose shall be kept illuminated from sunset to sunrise. Materials stored upon or alongside public streets shall be so placed, and the work at all times shall be so conducted, as to cause the minimum obstructions and inconvenience to the traveling public.
3. All barricades, signs, lights and other protective devices shall be installed and maintained in conformity with the latest edition of the Manual of Uniform Traffic Control Devices and applicable statutory requirements, and where within rights-of-way, as required by the authority having jurisdiction there over.

- C. Existing traffic and street name signs which will interfere with construction shall be removed by the Contractor and stored in a safe place. These signs shall not be removed until the Right of Way Manager has so directed and until the necessary measures have been taken to safeguard traffic after the signs have been removed. Preservation and maintenance of the signs shall be the sole responsibility of the Contractor. Upon completion of the project, the Contractor shall reset all such signs.

1.05 SHOP DRAWINGS

- A. Shop drawings or manufacturer's literature shall be required for water distribution systems for the following items: Pipe and fittings, valves, and fire hydrant assemblies. Material certification may be required on all other materials used in the installation of Work in the City rights-of-way.

1.06 BACKFILL

- A. There is no ordinary backfill in work performed in the City right-of-way. All backfill will be 90% or 95% compacted as required by the specifications. See details in the Standard Drawing Details

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

PART 2 – EXCAVATION, TRENCHING, AND BACKFILL

2.01 GENERAL

- A. This specification covers excavation and trenching and backfilling work and shall include the necessary clearing, grubbing and preparation of the site, removal of improvements; removal and disposal of all debris; excavation and trenching as required; the handling, storage, transportation and disposal of all excavated material; all necessary sheeting, shoring, and protection work; preparation of sub grades; pumping and dewatering as necessary or required; protection of adjacent property; backfilling; pipe embedment; surfacing and grading; and other appurtenant work.
- B. Excavation, trenching and backfilling work shall be performed in a safe and proper manner, with suitable precautions being taken against hazards of every kind. Excavation shall provide adequate working space and clearance for the work to be performed therein.
- C. No backfill, fill or embankment materials shall be installed on frozen surfaces, nor shall frozen materials, snow or ice be placed in any backfill, fill, or embankments.

2.02 CLASSIFICATION OF EXCAVATED MATERIALS

- A. No classification of excavated materials will be made. Excavation and trenching work shall include the removal and subsequent handling of all materials excavated or otherwise removed in performance of the contract work, regardless of the type, character, composition, or condition thereof.

2.03 REMOVAL OF WATER

- A. The permit holder shall provide and maintain adequate dewatering equipment to remove and dispose of all surface and ground water entering excavations, trenches, or other parts of the work. Each excavation shall be kept dry during sub grade preparation and continually thereafter until the pipeline to be installed therein is completed to the extent that no damage from hydrostatic pressure, flotation, or other causes will result.
- B. Surface water shall be diverted or otherwise prevented from entering excavated areas or trenches, to the greatest extent practicable without causing damage to adjacent property.

2.04 SHEETING AND SHORING

- A. Except where banks are cut back on a stable slope, excavation for structures and trenches shall be properly and substantially sheet braced, and shored, as necessary, to prevent caving or sliding, to provide protection for workmen and the Work, and to provide protection for existing structures and facilities. Sheeting, bracing, and shoring shall be designed and built to withstand all loads that might be caused by earth movement or pressure, and shall be rigid, maintaining its shape and position under all circumstances.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

2.05 STABILIZATION

- A. Trench bottoms shall be firm, dense, and thoroughly compacted and consolidated; shall be free from mud and muck; and shall be sufficiently stable to remain firm and intact under the feet of the workmen.
- B. Trench bottoms, which are otherwise solid, shall be reinforced with one or more layers of crushed stone embedded therein. No more than ½ inch depth of mud or muck shall be allowed to remain on stabilized trench bottoms when the pipe bedding material is placed thereon.
- C. All stabilization work hereunder shall be performed by and at the expense of the permit holder.

2.06 TRENCH EXCAVATION

- A. Except where knifing, boring or tunneling is shown on the plans, is specified, or is permitted by the City, all trench excavation shall be open cut from the surface.
- B. The permit holder shall not open more trench in advance of pipe laying than is necessary to expedite the Work. In the event that pipe laying is stopped for any cause, 100 feet shall be the maximum length of open trench permitted on any line under construction.

2.07 ALIGNMENT AND GRADE

- A. Alignment and Grade-Water Mains:
 - 1. The alignment and grade or elevation of each pipe line at street and railroad crossing and other critical points shall be fixed as determined by means of offset stakes to be set by the permit holder. At other locations, lines stakes will be furnished and set by permit holder. Pipe shall be laid with 42" minimum cover and 60" maximum cover unless otherwise approved. Straight sections shall be laid in a straight alignment. Vertical and horizontal alignment of pipes shall be accomplished with appropriate elbows and bends with adequate blocking. Alignment by deflection shall not be permitted.
- B. Alignment and Grade-Sewer:
 - 1. Pipe shall be laid true to line and grade as shown on drawings prepared by a licensed engineer. Each section of pipe shall rest upon the pipe bed for the full-length of the barrel with recesses excavated to accommodate bell joints. Any pipe that has its grade alignment or joint disturbed after laying shall be taken up and re-laid. Under no circumstances shall pipe be laid in water or when weather or trench conditions are unsuitable for such work in the opinion of the City.
 - 2. Sewer mains shall be laid on a uniform grade, and at a uniform (straight) alignment between manholes. All changes in grade, and or alignment, shall be made only at a manhole.
 - 3. Sewer service laterals shall be laid at uniform grade and alignment. Clean-outs on the service laterals shall be provided at any change in grade or alignment of over 45° angle.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

C. Alignment and Grade-Natural Gas Pipelines:

1. Natural gas pipelines laid in the City rights-of-way shall be laid in a straight alignment parallel or perpendicular to the street centerline to the greatest extent possible. Natural gas transmission lines shall be placed at depths specified by DOT/MPSC Part 192.
2. Non-metallic lines shall be buried with metallic locator wires or tape, which will permit accurate location of said lines from the surface with normal magnetic locator devices.
3. Any line passing under a City street shall be buried at a minimum of 36" below the street surface and 24" below flow line of storm drains.

D. Alignment and Grade-Telecommunications Lines:

1. Telecommunication lines buried in the City right-of way shall be laid in a straight alignment parallel to, or perpendicular to, the street centerline to the greatest extent possible. Local service lines shall be buried a minimum of 24". Trunk lines and fiber optic lines shall be buried at a minimum depth of 36". Any line passing under a City street shall be buried at a minimum of 36" below the street surface. Placement must be a minimum of 24" below flow line of storm water structure and natural flow line.

E. Alignment and Grade-Underground Electric Transmission Lines:

1. Electric transmission lines buried in the City rights-of-way shall be laid in a straight alignment parallel to, or perpendicular to, the street centerline to the extent possible. Electric transmission lines shall be buried at a minimum depth of 36".

2.08 TRENCH WIDTHS AND PIPE CLEARANCES

- A. Trenches shall be excavated to a width, which will provide adequate working space and pipe clearances for proper pipe installation, jointing and embedment.
- B. Minimum trench widths for water and sewer mains shall be as per embedment detail in the Standard Drawing Details. Minimum trench width for natural gas pipelines, conduit for electrical and telecommunication cables, and fiber optic lines shall be as specified by the Engineer of record for the utility installing such facilities.
- C. The stipulated minimum clearances are not minimum average clearances, but are minimum clear distances which will be permitted between the pipe as laid and any part, projection or point of rock, shale, stone or boulder.
- D. Where, for any reason, the width of the lower portion of the trench as excavated at any point exceeds the maximum permitted, either pipe of adequate strength, special pipe embedment, as required by loading conditions and as determined by the Engineer, shall be furnished and installed by and at the expense of the permit holder.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

2.09 MECHANICAL EXCAVATION

- A. Mechanical equipment used for trench excavation shall be of a type, design, and construction, and shall be so operated, that the rough trench excavation bottom elevation can be controlled, that uniform trench widths and vertical side walls are obtained at least from an elevation one foot above the top of the installed pipe to the bottom of the trench, and that the trench alignment is such that the pipe when accurately laid to specified alignment will be centered in the trench with adequate clearance between the pipe and side walls of the trench. Undercutting of the trench sidewall to obtain clearance will not be permitted.

2.010 SUBGRADE PREPARATION

- A. Except where otherwise required, pipe trenches shall be excavated below pipe sub grade elevations, as required, to provide for the installation of granular fill pipe foundation material.
- B. Whenever required by soft foundations, the permit holder shall excavate to such depth below grade as necessary and the trench bottom shall be brought to grade with granular fill.
- C. Bell Holes shall provide adequate clearance for the tools and methods used in installing the pipe. No part of any bell or coupling shall be in contact with the trench bottom, trench walls or granular fill when the pipe is jointed.

2.011 PIPE EMBEDMENT

- A. See Section 02222 in this document and details in the Standard Drawing Details. Natural gas lines may be directly bedded, without granular fill, if so directed by the Engineer of record for installing natural gas utility. Granular fill material shall be placed in a manner as to provide uniform and continuous support and shall not disturb alignment of the pipe during placement.
- B. Succeeding layers of backfill above those described shall be placed as described in the following paragraphs.

2.012 BACKFILL

- A. Ordinary Backfill:
 - 1. There shall be no ordinary backfill in this Work.
- B. Compacted Backfill in unimproved areas:
 - 1. 90% compaction will be required where the line passes under lawns, pasture, and within open areas. The average density of the trench backfill shall be 90% of maximum density. Material shall be placed in lifts as required for adequate compaction with variations in lift thickness depending on soil and on method of compaction. Completed backfill shall have no less than 90% density, excluding the top few inches to be used as seedbed or for bedding sod.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

2. Compaction may be by hand tamping, tamping machine, or other methods approved by the City. Permit holder will prepare test pits for sampling and testing and evaluation of compaction procedures.

C. Compacted Backfill in improved areas:

1. 95% compaction will typically be required under streets, driveways, and walkways. Flowable fill may be used instead of compacted backfill.
2. Placement of material and compaction for 95% compacted backfill shall be as described above for 90% compacted backfill except a minimum of 95% of maximum density must be maintained throughout the backfill. Material shall be placed in 6" maximum lifts.

D. Standard Compaction and Field Density Tests:

1. Wherever the terms "% of Maximum Density" or "Optimum Moisture" are used, Maximum Density and Optimum Moisture shall be determined by the Standard Compaction Test as defined by ASTM D698.
2. Field Density Test: Field density shall be obtained using the sand cone method (ASTM D1556), by the balloon method (ASTM D2167), or nuclear density gauge (ASTM D6938). The calculated density obtained in this test is divided by the Maximum Density as determined by the Standard Compaction Test to determine the percent compaction obtained.
3. Developer/owner will, through services of an independent laboratory, test all backfill at intervals as required to verify conformance with specified density relationships. A copy of all test results shall be provided to the City.

E. Responsibility of permit holder for Backfill Settlement:

1. Where either 90% or 95% compaction is called for, the permit holder shall be responsible financially, and otherwise, for a period of one year after completion of work, for;
 - a. all settlement of trench and other backfill which may occur from time of original backfilling,
 - b. the refilling and repair of all backfill settlement and the repair or replacement to the original or a better condition of all pavement, top surfacing, driveways, walks, surface structures, utilities, drainage facilities, and sod which have been damaged as a result of backfill settlement or which have been removed or destroyed in connection with backfill replacement operations, and
 - c. all damage claims or court actions against the City for any damage directly or indirectly caused by backfill settlement.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

2. The permit holder shall make, or cause to be made, all necessary backfill replacements, and repairs or replacements appurtenant thereto, within thirty days after notification by the Engineer or City.

2.013 DRAINAGE MAINTENANCE

- A. Trenches across roadways or driveways adjacent to drainage ditches of water courses shall not be backfilled prior to the completion of backfilling of the trench on the upstream side of the roadway to prevent the impounding of water after the pipe has been laid. Bridges and other temporary structures required to maintain traffic across such unfilled trenches shall be constructed and maintained by the permit holder. Backfilling shall be done so that water will not accumulate in unfilled or partially filled trenches. All material deposited in roadway ditches or other water courses crossed by the line of trench shall be removed immediately after backfilling is completed and the section grades and contours of ditches or water courses shall be restored to their original condition. Surface drainage shall not be obstructed longer than necessary.

2.014 DISPOSAL OF EXCESS EXCAVATED MATERIAL

- A. All excess excavated materials shall be disposed of away from the site of the Work. The permit holder shall be responsible for locating areas for disposal of such materials.
- B. Excavated rock in excess of the amount permitted to be and actually installed in trench backfill, junk, and debris encountered in excavation work, and other similar waste material shall be disposed of away from the site of the Work.

PART 3 – RESTORATION OF SURFACE

3.01 GENERAL

- A. The permit holder shall restore all surfaces equal to or better than its original condition unless otherwise specified. Restoration includes pavement, sidewalks, curb/gutter, lawns, etc.

3.02 SEEDING, FERTILIZING AND MULCHING

- A. Seeding and fertilizing is required where any utility excavation crosses established lawns, pastureland or right-of-way of the City or in other areas regularly grassed and mowed. The permit holder, at his option and at no additional cost to the City, may provide sod as specified herein in lieu of seeding in any or all areas required to be seeded. See Section 02930 for details of requirements.

3.03 STREET, DRIVEWAY, ALLEY AND SIDEWALK REPAIRS

- A. Base Aggregate:
 1. Six inches of compacted stone base meeting Missouri Standard Specifications for Highway Construction, Section 1007, Type 1 Aggregate, shall be placed under the pavement for the cut portion of street or alley.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

B. Concrete, Asphalted Concrete and Other Asphalted Surfaces:

1. All materials used shall conform to the City's Constructions Specifications and the latest edition of MoDOT's Standard Specifications for Highway Construction.
 - a. Black Base Course shall comply with Section 401 Plant Mix Bituminous Base or Section 403 Asphaltic Concrete Pavement, Type SP190 or Type SP250.
 - b. Surface Course shall comply with Section 401, Type BP-2 or Section 403, Type SP125.
 - c. Tack Coats shall comply with Section 407.
 - d. Any Prime Coat required shall comply with Section 408
2. All pavements are to be saw-cut prior to removal. Repairs to streets, driveways, and alleys disturbed by work in City right-of-way are to be made as follows:
3. New pavement shall have a width of at least 12" greater than the trench width. Each repair area in concrete or asphalt streets shall be cut on all sides for the full depth of the pavement with a concrete saw. The material shall be removed so that no damage occurs to the surrounding pavement. If any damage occurs to the surrounding pavement, then the damaged areas will also be removed and replaced.
4. For concrete pavements, see Section 03300 in this document and details in the Standard Drawing Details. Concrete shall meet Missouri Standard Specifications for Highway Construction for Pavement Concrete Section 501, and shall have a maximum slump of 4 inches and a minimum compressive strength of 4000 psi at 28 days.
5. For asphalted concrete pavements, the asphalt thickness of the repair shall be at least 11" or equal to thickness of adjacent existing pavement, (whichever is greater), over a minimum of 6" of compacted base rock. The stone base (MoDOT Type I), shall be compacted to 95% of Maximum Dry Density. Replace the pavement with hot-mix asphalt and compact thoroughly in lifts not to exceed 2" each. See Section 02512 in this document and details in the Standard Drawing Details.
6. The top of all pavement repairs shall be flush with the existing pavement.
7. Curbs and gutters to be replaced as required to match existing shape and material. Curbs and gutters are to be constructed as per Section 02525 in this document.
8. Sidewalks shall be replaced over the entire width and to the nearest joints. The concrete thickness shall be at least 4" placed over a 4" thick rolled stone base or to existing if thicker. Concrete used for sidewalk repair shall be equivalent to MoDOT Class B-1 concrete, 4000 psi and shall have a maximum slump of 4". Sidewalk construction shall be as per Section 02525 in this document.

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

PART 4 - SEPARATION OF WATER MAINS, SANITARY SEWERS AND STORM SEWERS

4.01 PARALLEL INSTALLATION

A. Horizontal Separation:

1. All sanitary sewer, storm sewer, or manhole shall be laid at least 10 feet, horizontally, from a water main. The distance shall be measured from edge to edge of pipes or to outer wall of manhole. When local conditions prevent a lateral separation of 10 feet, a request for variance shall be submitted to the DNR Public Drinking Water Branch for approval. This request shall include proposed alternate installation configuration.

B. Vertical Separation:

1. Water mains crossing sanitary sewers, house sewers, or storm sewers shall be constructed to provide a minimum clear distance of 18 inches between the outside of the water main and the outside of the sewer. This clearance is required whether the water main is above or below sewer pipes. At crossings, the full length of water pipe shall be located so that both joints will be as far from the sewer as possible but in no case less than 10 feet. Special structural support for the upper pipe may be required. In areas where the proper separation cannot be maintained as stipulated above, either the water main or sewer line must be constructed of mechanical joint pipe or cased in a continuous casing.

4.02 EXCEPTION

- A. The MoDNR must specifically approve any variance from the requirements of Section 4.01 A and/or B, when it is impossible to obtain the specified separation distances. The Design Engineer shall request any such variance after all other remedies have been evaluated.

4.03 SEWER MANHOLES

- A. No waterline shall be located closer than 10 feet to any part of a sewer manhole.

PART 5 - INSURANCE REQUIREMENTS, BONDS AND PENALTIES:

5.01 INSURANCE REQUIRED.

- A. Any person applying for a permit shall furnish to the director a certificate of insurance naming the city as an additional insured and evidencing the permittee's general liability insurance, with owner's protective coverage, automobile liability insurance and worker's compensation insurance in such amounts of coverage and with such endorsements as determined by the director. Said limits of liability shall not be less than the current year sovereign immunity limits for Missouri public entities calculated by the Missouri Department of Insurance as of January 1 each calendar year and published annually in the Missouri register pursuant to Section 537.610 RSMo. Current, valid insurance policies meeting the requirements herein identified shall be maintained during the duration of the named project. Renewal certificates or cancellation notices shall be sent to the city 30 days prior to any expiration date. It shall be the responsibility

SECTION 12000 – RIGHT-OF-WAY TECHNICAL SPECIFICATIONS

of the contractor to ensure that all subcontractors comply with the same insurance requirements.

5.02 INDEMNIFICATION AND HOLD HARMLESS.

- A. Any person who is issued a permit under the provisions of this Section shall, as a condition of the granting of such permit, indemnify and hold the city harmless for any claims and damages because of bodily injury, including death, and from claims for damages to property which may arise out of and during excavation operations, whether such operations are by the permittee or by any contractor and/or subcontractor or other person directly or indirectly employed by permittee.

5.03 CASH DEPOSIT OR SURETY BOND REQUIRED.

- A. Any person wishing to make an excavation in the right-of-way pursuant to this Section shall, prior to receiving a permit, file with the director either a cash deposit or surety bond with a corporate surety approved by the city, sufficient in amount to ensure payment to the city for the proper repair and restoration of the right of way or other public improvement upon which excavation is to be made.
- B. Such cash deposit or surety bond shall be released within sixty (60) days after the excavation has been properly backfilled and repaired and payment made thereof, and to his knowledge no damage to any person or property has occurred by reason of such excavation prior to acceptance by the city and after a street inspector shall have reported the excavation to have been properly repaired.

5.04 PENALTIES

- A. Failure of the permittee to comply with the provisions of this Section shall be deemed cause for forfeiture of permittee's deposit and/or bond. Failure of the permittee to make corrections to comply with the provisions of this article within 24 hours after notice has been given of the defect shall constitute cause for the city to refuse to issue further excavation permits to such person until the failure is corrected. Any person who shall violate any provision of this Section shall, upon conviction, be punished as provided in Section 100.220 of the Municipal Code of the City of Ozark, Missouri.
- B. Failure to obtain a permit prior to making an excavation within a right of way shall be subject to a civil penalty not to exceed \$500.00 per day per violation. Nothing shall prohibit the city from seeking and enforcing both civil and criminal penalties.

END OF SECTION 12000